

118 N. 35th St.  
Suite 200  
Seattle, WA 98103  
T 206 634 0177  
millerhayashi.com

**Miller Hayashi Architects PLLC**

**CHC Puyallup Garage**

111 W Main

Permit # **PRCTI20221714**

12/12/23

**Revision Correction Response #1 Building (Janelle Montgomery), Engineering (Linda Lian)**

**Comment Number, Sheet Number & Correction Response Comments:**

Corrections are clouded and tagged on the updated sheets.

**Building**

**Correction #1**

*Review Comment: "Provide revised sewer connection from engineer of record. Clarify how it will tie into existing clearly not with X. Where will CO be located with ones being eliminated. Clarify how many fixtures will be on the 3" drain."*

Response: Piping reroute redrawn for clarity with DFU's labeled. No more than 9 DFU on a 3" pipe. Refer to updated Plumbing Drawing attached.

**Correction #2**

*Review Comment: "Clarify why reducing to 2" at this point between 3" line"*

Response: 3" Pipe now carried to end of run.

**Engineering:**

**Correction #4**

*Review Comment: "Engineering needs the seal"*

Response: Engineering seal has been added. Refer to attached updated Plumbing drawing.

**Correction #5**

*Review Comment: "Line is detailed very close to the common bearing wall, please verify clearance from the bearing angle of influence. Provide the city with a CCTV of the existing sewer lateral in order to determine if the lateral does not need is viable for the proposed use."*

Response: CCTV link is provided in email response.