



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2023 **Inspection Result:** **NOT READY**

Permit Number: PRPF20230347

Property Address: 2315 INTER AVE, PUYALLUP, WA 98372;

Contractor: WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406

To construct: Construct 4,987 SF pre-fabricated metal building warehouse; SEE PRMH20230349/MECH

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1
- 4
1. provide EOR approval for bar size for tension tie as discussed with contractor
2. provide min clearance from bar to forms per city approved plans
3. provide special inspection reports for structural steel placement
4. provide clarification for bar size on cross bars
5. not ready do not pour

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590