



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 21, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRRWF20230497

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor:

To construct: Proposed retaining walls within Benaroya parking lot expansion project.
* REVISION (1) - 9/1/2023 - WALL REVISIONS TO PROVIDE STRUCTURAL COMPONENTS

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. section 2 and 3 upper and lower walls approved to pour
2. section 6 lower wall provide engineering or EOR approval for wall ht that exceeds max wall ht per city approved plans DO NOT POUR

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590