



Seattle	1011 Western Avenue, Suite 810   Seattle, WA 98104   206.292.5076
Tacoma	1250 Pacific Avenue, Suite 701   Tacoma, WA 98402   253.383.2797
Portland	101 SW Main Street, Suite 280   Portland, OR 97204   503.232.3746
	<a href="http://www.pcs-structural.com">www.pcs-structural.com</a>

December 20, 2023

BCRA Design  
2106 Pacific Avenue, Suite 300  
Tacoma, WA 98402

ATTN: Rose Hillebrandt

RE: *Taco Time Main Puyallup – Permit Responses*

Dear Rose:

COMMENTS:

The purpose of this letter is to provide responses to structural comments from the City of Puyallup Permit Review Correction Letter dated December 01, 2023. See below:

Comment: The detail designation was not provided, and sheet S4.11 was not included in the plan set [Taco Time Main Puyallup -Building Permit - Plan Set, sheet S-402]

*Response – See revised drawings.*

Comment: The detail designation was not provided, and sheet S4.11 was not included in the plan set [Taco Time Main Puyallup -Building Permit - Plan Set, sheet S-402]

*Response – See revised drawings.*

Comment: Please include the detail designation and sheet number [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-401].

*Response – See revised drawings.*

Comment: Please clarify where the legend is located to determine "D" [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-401].

*Response – To clarify, there is not a legend for "D". Dimensions "D" & "T" are shown in detail B/S-401, where "D" indicates the diameter of conduits/sleeves & "T" indicates concrete thickness. The criteria per B/S-401 allows for varying sizes of miscellaneous MEP conduits and sleeves in cast-in-place concrete of varying thicknesses.*

Comment: Please include the detail designation and sheet number to easily locate the Reinforcing Wall Openings [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-401].

*Response – See revised drawings.*

BCRA Design  
Rose Hillebrandt  
*Taco Time Main Puyallup – Permit Responses*

Comment: The detail designation was not provided [Taco Time Main Puyallup - Building Permit – Plan Set, sheet S-402].

*Response – See revised drawings.*

Comment: The detail designation was not provided [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-402].

*Response – See revised drawings.*

Comment: Please verify if this leader is meant to contain a note. Please remove it if it's not needed [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-801].

*Response – See revised drawings.*


Comment: Please verify if this is meant to be a HDU5 hold-down or HD series hold-down (Simpson HD5B) [Taco Time Main Puyallup - Building Permit - Plan Set, sheet S-121].

*Response – Simpson HDU5 holddown intended per S-121 & A/S-801. See revised drawings.*

Thank you for the opportunity to be of continued service. Please contact us if you have any questions.

Very truly yours,

PCS STRUCTURAL SOLUTIONS

  
Jacob Baker, P.E.  
Project Manager

JMBeml  
23-514

Reviewed by:

Luke Heath, S.E.  
Associate Principal

