



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 02, 2024

Inspection Result: **PASSED**

Permit Number: PRFS20231647

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: PATRIOT FIRE PROTECTION 2707 70TH AVE E TACOMA, WA 98424

To construct: Customer installed a new security in their parking lot which now obstructs the FDC and fire hydrant perimeter. We would like to rotate the FDC 90 degrees, and the fire hydrant 180 degrees as recommended by the fire marshall.

On this day we have inspected your construction for **Suppression System Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 Ownership was supposed to remove all vegetation around fire hydrant and FDC. Once this is completed, the Final will be approved.

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org