



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 16, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20221725

**Property Address:** 201 W MAIN, PUYALLUP, WA 98371;

**Contractor:** ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

**To construct:** New electrical trenching- Install new sidewalk- Grading for new enclosed stair - COMMUNITY HEALTHCARE - CANNERY BLDG  
PRCTI20221698STOP WORK ORDER generated on 08/01/2023 by username 'Jeff Hill'.STOP WORK ORDER removed on 09/27/2023 by username 'Jeff Hill'.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** The soils disturbed from working on the power need to be stabilized.  
The parking lot and roadway need to be cleaned due to track out.

**Corrections:**

- 1 Stabilize all exposed soils

Sincerely,

Jeff Hill  
Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424