

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jan 16, 2024	Inspection Result:	PARTIAL PASS
Denne it Niemele en			
Permit Number:			
Property Address:	1601 39TH AVE SE, PUYALLUP, WA 98374;		
Contractor:	ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152		
To construct:	New ~54,000 SF building containing labs, classrooms, faculty and		
	student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS &		
	DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS		
	(NO CHANGE IN SQ FTG OR COST)		

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. level 1 north west and north wall vapor barrier approved

Corrections:

- complete insulation in areas that are displaced by plumbing or conduits
 complete insulation at exterior corners
 - 3. remove wet insulation stop the water intrusion prior to re insulating
 - 4. complete insulation where exterior wall can be seen as discussed with contractor

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590