



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 18, 2024

Inspection Result: **FAILED**

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR *

REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING
TO HC STALL

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. provide birc clips at floating sides of ceiling as discussed with contractor
- 2.provide positive connection at diffusers
3. provide positive connection of perimeter wires that attach to wall
4. complete 3 turns at wire attachment at lights

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590