

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jan 19, 2024	Inspection Result:	PARTIAL PASS
Permit Number: Property Address:	PRCCP20230336 2315 INTER AVE, PUYAL	LUP, WA 98372;	
Contractor:	WESTMARK CONSTRUC 98406	TION, INC 6102 N 9TH S	T #100 TACOMA, WA
To construct:	Site development to cor WAREHOUSE	nstruct new warehouse st	torage building CIMCO

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Pro vac onsite at 8am to vac out the hyd/fire line tie in.

The water was shut down at 9am. The water was drained through the existing 6" GV from the old removed hyd. existing line removed, 8"x8"x8" tee, 8" PIV, 8"x6" reducer, 2 sleeves, and a half eco block installed. The water was turned back on at 5pm. the contractor bedded the pipe then secured the hole.

The sidewalk was undermined to connect the main and will need to be replaced. see conditions.

Corrections:

Sincerely,

Jeff Hill Engineering Tech IV Jhill@PuyallupWA.gov (253) 841-5424