



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 22, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20230247

**Property Address:** 733 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

**To construct:** TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR \*  
REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING  
TO HC STALL

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** The new wheel chair ramp is out of ADA standards. (12.7% vs 8.3%)

**Corrections:**

- 1 Remove and replace the new wheelchair ramp to current ADA standards.

Sincerely,

Jeff Hill  
Engineering Tech IV  
[Jhill@PuyallupWA.gov](mailto:Jhill@PuyallupWA.gov)  
(253) 841-5424