



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 29, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRDE20231749

**Property Address:** 2007 SHAW RD, PUYALLUP, WA 98372;

**Contractor:** DSE EXCAVATING INC 14603 154TH ST E ORTING, WA 98360-9575

**To construct:** Demolish existing vacant residence and carport. Demolition ordered by city, case no. 17-000151.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** -Construction entrance may need to be extended into the site farther for trucking to exporting demo debris. If trackout occurs trucking will be stopped until entrance is extended.  
-Do not back trucks into the site from Shaw. Pull in only!  
-Site to be stabilized with straw immediately after structures are dropped and slabs removed.

**Corrections:**

Sincerely,

Michael Rosenau  
Engineering Tech IV  
MRosenau@PuyallupWA.gov  
(253) 841-5411