



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 30, 2024

Inspection Result: **FAILED**

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR *

REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING
TO HC STALL

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

2 LIFE SAFETY

1. complete install of garage roll-up door west side of building
2. provide landing at back door that does not exceed 2%
3. complete grab bars in employee bathroom
4. complete door hardware at offices
5. complete ada signage at parking stall as per city approved plans

NON LIFE SAFETY

1. insulate main water line in unconditioned space
2. complete vapor barrier at ceiling in storage room
3. provide balance report
4. complete grill in ceiling in employee bathroom
5. complete threshold and door seal at employee bathroom
6. provide occupancy signage at front door
7. complete awnings at west side of building

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590