



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 30, 2024

Inspection Result: **FAILED**

Permit Number: PRPF20230822

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE / SONS PO BOX 44100 TACOMA, WA 98444

To construct: Ferrucci Junior High School - Athletic Storage Shed. Per RC/BO Separate permit required to close out B-20-0993.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. provide landings at exterior man doors that due not exceed 2%
2. provide gutters and downspouts and splash block

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590