



The approved construction plans, documents, and all engineering must be posted on the job at all inspections in a visible and readily accessible location.

Full sized legible color plans are required to be provided by the permittee on site for inspection.

Approval of submitted plans is not an approval of omissions or oversights by this office or non compliance with any applicable regulations of local government. The contractor is responsible for making sure that the building complies with all applicable codes and regulations of the local government.

Imagery ©2024 Google, Imagery ©2024 Airbus, Maxar Technologies, U.S. Geological Survey, Map data ©2024 20 ft

**Scope of Work:**

Remove and dispose of existing coping metal and all existing flashings. Provide and install polymat separation sheet, mechanically attached 60mil tpo roofing system, flashings for all penetrations, and new related metals. Provide 20 year NDL manufacturers warranty.

**C503.3.1 Roof replacement.**

Roof replacements shall comply with Table C402.1.3 or C402.1.4 where the existing roof assembly is part of the building thermal envelope and contains insulation entirely above the roof deck.

**City of Puyallup  
Building  
REVIEWED  
FOR  
COMPLIANCE**

BSnowden  
02/01/2024  
12:33:08 PM

