



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 09, 2024 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20230304

Property Address: 1102 E MAIN, PUYALLUP, WA 98372;

Contractor: PINNACLE CONSTRUCTION INC PO BOX 426 GLENWOOD, IA 51534

To construct: Interior building remodel. New electrical . New plumbing supply lines .
Two new bathrooms along with air supply and connections to existing
sewer. Relocate hot water heater and provide new exit door. New
insulation ceilings and cosmetic improvements throughout.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide engineering, planning, fire and electrical final approval at time of next inspection
2. submit mechanical revision to the city
3. provide signage at bathrooms
4. seal up vapor barrier in ceilings multiple areas
5. complete perimeter wires at ceiling
6. complete birc clips at ceiling
7. complete insulation at hot water lines in MECH room
8. provide correct lock at front door
9. provide signage at front door
10. provide table in lobby that meets accessibility requirements
11. remove old MECH thru roof in electrical room
12. provide copy of backflow cert at time of next inspection
13. provide ladder to inspect roof at time of next inspection
14. NOT A COMPLETE LIST



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590