



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 09, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: E-21-0313

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790
DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790

To construct: PARKING LOT EXPANSION W. 675 STALLS,CFG~SHB-TC PARKING EXPANSION/BENAROYA

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Stripe Rite is on site applying the parking lines, ADA stalls, EV stalls, and wheel stops. MCE is pulling wire for the EV ports.

Note: I let the contractor know that "NO ONE" can begin to use the parking lot until all storm devices and system are brought on line and cleaned. All bio-swales need to be completed. All storm structures, pipes, detention (all the way to the pond) need to be cleaned.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636