



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFS20240156

FIRE SPRINKLERS

Puyallup, WA

Job Address	Address: 2315 INTER AVE, PUYALLUP, WA 98372 Parcel # 2105200140	ISSUED February 13, 2024
Owner	VELASQUEZ RICK & ELLEN RAEANN 2315 INTER AVE PUYALLUP, WA 98374-4510	
Applicant	Luke Thompson 111 S Findlay St, Seattle, WA 98108 (206) 232-8569 luke@columbiafire.net COLUMBIA FIRE INC 111 S FINDLAY ST SEATTLE, WA 98108	
Contractor	WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406 tfrank@westmarkconst.com WA L&I #:	
Description of Work	NFPA13-2019, NEW SYSTEM. INSTALL A NEW WET SYSTEM INTO THE STORAGE WAREHOUSE. TOTAL SPRINKLER HEADS: 57 - CIMCO WAREHOUSE	
Permit Types	Fire Sprinklers	
Expiration Date:	August 11, 2024	
Total ESU's		

Building Components:

Quantity	Units	Description
4973	SQ FT	Automatic Fire-Sprinkler System, New
		Total Value of Work: \$18,748.21

Standard Conditions:

1. • Provide plans and permit on site for inspection.
- Cover and final inspections are required.
- Fire watch is required when sprinkler system is out of service in existing buildings.
- Contractor required at all inspections.
- Hydro test will be required on all new and existing buildings. Appointment required.
- Hydro test, two inspections will be required 2hrs apart. Call to schedule times. Am/pm is not guaranteed without appointment.
- Fire pumps will be required to be tested and witnessed by inspector.
- Tool kit required at time of final.
- NFPA placards required. The FDC will be required to address both structures on one sign.
- In existing buildings all upright fire sprinklers to remain, do not remove.
- In existing buildings all required service and maintenance to be updated prior to inspection.

- Due to unforeseeable construction design, all head locations to be field verified for compliance. Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.
David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Luke Thompson COLUMBIA FIRE
INC