



CITY OF PUYALLUP  
**Development & Permitting Services**  
 333 S. Meridian, Puyallup, WA 98371  
 (253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

**Permit No:**  
 PRFS20240028

**FIRE SPRINKLERS**  
 Puyallup, WA

<b>Job Address</b>	Address: 4621 S MERIDIAN, Unit: A915, PUYALLUP, WA 98373 Parcel # 0419102125	<b>ISSUED</b> February 13, 2024
<b>Owner</b>	MERIDIAN PLACE LLC 1875 CENTURY PARK E STE 900 LOS ANGELES, CA 97477-1186	
<b>Applicant</b>	Dan Moffett PO Box 2065 Buckley, WA 98321 (206) 276-8872 acefiresys@gmail.com	
<b>Contractor</b>	ACE FIRE SYSTEMS LLC PO BOX 2065 BUCKLEY, WA 98321 WA L&I #:	
<b>Description of Work</b>	(48) SPRINKLERS	
<b>Permit Types</b>	Fire Sprinklers	
<b>Expiration Date:</b>	August 11, 2024	
<b>Total ESU's</b>		

**Building Components:**

Quantity	Units	Description
48	HEADS	Automatic Fire-Sprinkler System, Alteration
		<b>Total Value of Work:</b> \$0.00

**Standard Conditions:**

- Provide plans and permit on site for inspection.
  - Cover and final inspections are required.
  - Fire watch is required when sprinkler system is out of service in existing buildings.
  - Contractor required at all inspections.
  - Hydro test will be required on all new and existing buildings. Appointment required.
  - Hydro test, two inspections will be required 2hrs apart. Call to schedule times. Am/pm is not guaranteed without appointment.
  - Existing space No work requires fire sprinklers, if this area lacks coverage it will be required at time of inspection.
  - Tool kit required at time of final.
  - NFPA placards required.
  - In existing buildings all upright fire sprinklers to remain, do not remove.
  - In existing buildings all required service and maintenance to be updated prior to inspection.
  - Due to unforeseeable construction design, all head locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.  
David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

**I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.**

**Applicant:**  
Dan Moffett