Calculations required to be provided by the Permittee on site for all Inspections



PRCTI20231742

City of Puyallup
Building
REVIEWED
FOR
COMPLIANCE

BSnowden 02/06/2024 11:35:48 AM



Structural Engineering # Design, Inc.

1815 Wright Ave La Verne, CA 91750 Phone: 909.596.1351 Fax; 909.596.7186

Project Name: INGERSOLL RAND

Project Number: 23-1109-15

Date: 12/11/23

Street Address: 418 VALLEY AVE NW, STE B-107

City/State: PUYALLUP, WA 98371

Scope of Work: STORAGE RACK/SHELVING







Engineering & Design Inc.

1810 Whight Ave La Veille, CA 91730 Fel. 909.090.1351 Fax. 909.090.7180	<u> 1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7</u>	186
---	---	-----

By: Bob S	Project: Ingersoll Rand		Project #: 23-1109-15
TABLE OF CONTENTS			
Title Page		1	
Table of Contents		2	
Design Data and Definition of Compone	nts	3	
Critical Configuration		4	
Seismic Loads		5 to 6	
Column		7	
Beam and Connector		8 to 9	
Bracing		10	
Anchors		11	
Base Plate		12	
Slab on Grade		13	
Other Configurations		14 10 37	



Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

~ By: Bob S

Project: Ingersoll Rand

Project #: 23-1109-15

Design Data

1) The analyses herein conforms to the requirements of the:


2018 IBC Section 2209

2022 CBC Section 2209

ANSI MH 16.1-2012 Specifications for the Design of Industrial Steel Storage Racks "2012 RMI Rack Design Manual" ASCE 7-16, section 15.5.3

- 2) Transverse braced frame steel conforms to ASTM A570, Gr.55, with minimum strength, Fy=55 ksi Longitudinal frame beam and connector steel conforms to ASTM A570, Gr.55, with minimum yield, Fy=55 ksi All other steel conforms to ASTM A36, Gr. 36 with minimum yield, Fy= 36 ksi
- 3) Anchor bolts shall be provided by installer per ICC reference on plans and calculations herein.
- 4) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.
- 5) The existing slab on grade is 5.5" thick with minimum 7123 psi compressive strength. Allowable Soil bearing capacity is 750 psf. The design of the existing slab is by others.
- 6) Load combinations for rack components correspond to 2012 RMI Section 2.1 for ASD level load criteria

Definition of Components





Engineering & Design Inc.


1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Ingersoll Rand

Project #: 23-1109-15

Configuration & Summary: TYPE 1 SELECTIVE RACK



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 50 lb

AXIAL LL= 3,200 lb

SEISMIC AXIAL Ps=+/- 3,333 lb

BASE MOMENT= 8,000 in-lb

Seismic Criteria	# Bm Lvls	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=1.28, Fa=1.2	2	42 in	192.0 in	3	120 in	Single Row

Comp	onent				Description				STRESS
Colu	imn	Fy=55 ksi	II.	NTLK LU70/3x3x	l4ga	P=325	0 lb, M=15157	in-lb	0.88-OK
Column 8	& Backer	None		None			None		N/A
Bea	am	Fy=55 ksi	Intlk 5	0E 5Hx2.75Wx0	.059"Thk	Lu=120 in	Capacity: !	5516 lb/pr	0.58-OK
Beam Co	nnector	Fy=55 ksi	Lvl 1:	3 pin OK	Mconn=9	152 in-lb	Mcap=12	691 in-lb	0.72-OK
Brace-Ho	orizontal	Fy=55 ksi			Intlk 1-1/2x1	-1/2×14ga			0.13-OK
Brace-D	iagonal	Fy=55 ksi			Intlk 1-1/2x1	-1/2x14ga			0.56-OK
Base	Plate	Fy=36 ksi		8x5)	(0.375		Fixity= 8	000 in-lb	0.63-OK
Ancl	hor	2 per Base	0.5" × 3.25" E	mbed HILTI KWIK	BOLT TZ ESR 191	7 Inspection Req	d (Net Seismic U	plift=3124 lb)	0.733-OK
Slab 8	k Soil		5.5" thk	x 7123 psi slab	on grade. 750 ps	f Soil Bearing Pr	essure		0.25-OK
Level	Load**			Story Force	Story Force	Column	Column	Conn.	Beam
	Per Level	Beam Spcg	Brace	Transv	Longit.	Axial	Moment	Moment	Connector
1	3,200 lb	96.0 in	52.0 in	374 lb	166 lb	3,250 lb	15,157 "#	9,152 "#	3 pin OK
2	3,200 lb	96.0 in	52.0 in 74.0 in	749 lb	332 lb	1,625 lb	7,968 "#	3,847 "#	3 pin OK

	_				Ī				_												Ī	Ī				_	_				_		-					Ī		_				Ī	Ī			_								Ī					Ī	_				Ī														_				Ī	Ī	Ī	Ī		Ī	_		_	_	_	_	_	_	_	_	_	_	_	_		Ī			_	Ī	_	_	_		_	Ī		Ī	Π	_	_		Ī	_	Π	Т	_	_	_	Ī
		_	_	-	_	_	_	_	_	_	_	-	_	_	-	-	-	-	-	-			-	-	-		_	_	_	_	_	_		-	-	-	-		-		-	-	-			-	-		-	-	-	-	-	-	-		-	-	-	-		_	-	-	-		-	-	-	-	-	-	-	-	-	-	-	-	-	_	-	-	-			_	_	-	_	_		_	_		_	_	_	_		_	_	_	_	_	_	_	_	_		_	_		_			-			_	_			_		_			_	

1.

Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

44,916-#

161,719-#

Engineering & Design Inc.

3,200 lb

3,200 lb

2,144 lb

2,144 lb

50 lb

50 lb

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186 Project #: 23-1109-15 Project: Ingersoll Rand By: Bob S Configuration: TYPE 1 SELECTIVE RACK **Seismic Forces** Lateral analysis is performed with regard to the requirements of the 2012 RMI ANSI MH 16.1-2012 Sec 2.6 & ASCE 7-16 sec 15.5.3 Ss= 1.280 S1 = 0.414Transverse (Cross Aisle) Seismic Load V = Cs*Ip*Ws=Cs*Ip*(0.67*P*Prf+D)Fa = 1.200Fv= 1.850 Cs1= Sds/R Sds=2/3*Ss*Fa= 1.024 = 0.2560Cs-max * Ip= 0.2560 V_{min}= 0.015 Sd1=2/3*S1*Fv= 0.511 Cs2= 0.044*Sds Eff Base Shear=Cs= 0.2560 Ca=0.4*2/3*Ss*Fa= 0.4096 = 0.0451Transverse Elevation Cs3= 0.5*S1/R $W_{S}= (0.67*PL_{RF1}*PL)+DL (RMI 2.6.2)$ (Transverse, Braced Frame Dir.) R= 4.0 = 4,388 lbIp = 1.0= 0.0518P_{RF1}= 1.0 Vtransv=Vt= 0.256 * (100 lb + 4288 lb) Cs-max = 0.2560Base Shear Coeff=Cs= 0.2560 Etransverse= 1,123 lb Pallet Height=hp= 48.0 in Limit States Level Transverse seismic shear per upright DL per Beam Lvl= 50 lb P*0.67*P_{RF1} Level PRODUCT LOAD P DL wi*hi Fi*(hi+hp/2

96 in

192 in

210,624

421,248

374.3 lb

748.7 lb

S	ım:	P=6400 lb	4,288 lb	100 lb	٧	V=4388 I	b 631,872	1	,123 lb		∑=2	06,635
ongitudinal (De	wna	isle) Seismic I	.oad									
nilarly for longitudinal s	elsmic l	oads, using R=6.0	Ws=	(0.67 * PL _{RF}	₂ * P)	+ DL	P _{RF2} =	1.0	2000	as annun	1111111	000000
Cs1=Sd1/(T*	(۶)≃ 0	.1135	= -	4,388 lb		((Longitudinal, Unbraced Dir.) R=	6.0	10000			Ydang
C:	s2= 0	.0451	Cs=Cs-max*Ip=	0.1135			T=	0.75 sec	20000		9111111	ASSESSED .
C	s3= 0	.0345	Vlong=	0.1135 * (100 II	+ 4288	3 lb)		2000	10 MONTH	gunn	27,0777,
Cs-ma	ax= 0	.1135	Elongitudinal=	498 lb	Limit	States Level	Longit. seismic shear per upright					
Level	P	RODUC LOAD P	P*0.67*P _{RF2}	DL		hi	wi*hi		Fi	Front	View	
1		3,200 lb	2,144 lb	50 lb		96 in	210,624	1	66.0 lb			
2		3,200 lb	2,144 lb	50 lb	4	192 in	421,248	3	32.0 lb			



Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Ingersoll Rand

Project #: 23-1109-15


Downaisle Seismic Loads

Configuration: TYPE 1 SELECTIVE RACK

Determine the story moments by applying portal analysis. The base plate is assumed to provide partial fixity.

Seismic Story Forces

Vlong= 498 lb Vcol=Vlong/2= 249 lb F1= 166 lb F2= 332 lb F3= 0 lb



h1-eff= h1 - beam clip height/2

Vcol

h2

= 93 in

Seismic Story Moments

<=== Default capacity

Mbase-v= (Vcol*h1eff)/2

Mbase-max= 8,000 in-lb

= 11,579 in-lb <=== Moment going to base

Mbase-eff= Minimum of Mbase-max and Mbase-v

= 8,000 in-lb

M 1-1= [Vcol * h1eff]-Mbase-eff

= (249 lb * 93 in)-8000 in-lb

= 15,157 in-lb

M 2-2= [Vcol-(F1)/2] * h2

= [249 lb - 166 lb]*96 in/2

= 7,968 in-lb

Mseis= (Mupper+Mlower)/2

Beam to Column Elevation

Mseis(1-1)= (15157 in-lb + 7968 in-lb)/2

= 11,563 in-lb

Mseis(2-2)= (7968 in-lb + 0 in-lb)/2

= 3,984 in-lb

rho= 1.0000

			Sumr	nary of Forces			
LEVEL	hi	Axial Load	Column Moment**	Mseismic**	Mend-fixity	Mconn**	Beam Connector
1	96 in	3,250 lb	15,157 in-lb	11,563 in-lb	1,512 in-lb	9,152 in-lb	3 pin OK
2	96 in	1,625 lb	7,968 in-lb	3,984 in-lb	1,512 in-lb	3,847 in-lb	3 pin OK

Mconn= (Mseismic + Mend-fixity)*0.70*rho

Mconn-allow(3 Pin)= 12,691 in-lb

**all moments based on limit states level loading



Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S


Project: Ingersoll Rand Project #: 23-1109-15

Column (Longitudinal Loads)

Configuration: TYPE 1 SELECTIVE RACK

Section Properties

Section: INTLK LU70/3x3x14ga $Aeff = 0.643 in^2$ $Iy = 0.749 in^4$ Kx = 1.7 $Ix = 1.130 in^4$ $Sy = 0.493 \text{ in}^3$ Lx = 93.5 in $Sx = 0.753 \text{ in}^3$ ry = 1.080 inKy = 1.0rx = 1.326 inFy= 55 ksi Ly = 52.0 in $\Omega f = 1.67$ Cmx = 0.85Cb = 1.0E= 29,500 ksi



Considers loads at level 1

COLUMN DL= 50 lb Critical load cases are: RMI Sec 2.1 COLUMN PL= 3,200 lb Load Case 5: : (1+0.105*Sds)D + 0.75*(1.4+0.14Sds)*B*P + 0.75*(0.7*rho*E)<= 1.0, ASD Method Mcol= 15,157 in-lb axial load coeff: 0.810264 * P seismic moment coeff: 0.5625 * Mcol Sds= 1.0240 Load Case 6: : (1+0.14*Sds)D + (0.85+0.14Sds)*B*P + (0.7*rho*E)<= 1.0, ASD Method 1+0.105*Sds= 1.1075 axial load coeff: 0.69535 seismic moment coeff: 0.7 * Mcol

1.4+0.14Sds= 1.5434 By analysis, Load case 6 governs utilizing loads as such

1+0.14Sds= 1.1434 0.85+0.14*Sds= 0.9934 Axial Load=Pax= 1.14336*50 lb + 0.99336*0.7*3200 lb Moment=Mx= 0.7*rho*Mcol B = 0.7000= 2,282 lb = 0.7 * 15157 in-lb rho= 1.0000 = 10,610 in-lb

Axial Analysis

KxLx/rx = 1.7*93.5"/1.326"KyLy/ry = 1*52"/1.08"Fe < Fy/2= 119.9= 48.1Fn= Fe $= \pi^2E/(KL/r)max^2$ Fe= $\pi^2E/(KL/r)$ max 2 Fy/2= 27.5 ksi = 20.3 ksi= 20.3ksi $Pa = Pn/\Omega c$ Pn= Aeff*Fn $\Omega c = 1.92$ = 13029 lb/1.92= 13,029 lb= 6,786 lb

Bending Analysis

P/Pa=

Check: Pax/Pa + (Cmx*Mx)/(Max* μ x) ≤ 1.0

 $P/Pao + Mx/Max \le 1.0$

0.34

Myield=My= Sx*Fy Pno= Ae*Fy Pao= Pno/Ωc = 0.643 in^2 *55000 psi = 35365lb/1.92

= 35,365 lb= 18,419 lb= 41,415 in-lb

 $Max = My/\Omega f$

Pcr= n^2EI/(KL)max^2 = 41415 in-lb/1.67 $= \pi^2*29500 \text{ ksi/}(1.7*93.5 \text{ in})^2$ = 24,799 in-lb= 13,022 lb

 $\mu x = \{1/[1-(\Omega c*P/Pcr)]\}^{-1}$

 $= \{1/[1-(1.92*2282 | b/13022 | b)]\}^{-1}$

> 0.15

= 0.66

Combined Stresses

(2282 lb/6786 lb) + (0.85*10610 in-lb)/(24799 in-lb*0.66) =0.88< 1.0, OK(EQ C5-1) (2282 lb/18419 lb) + (10610 in-lb/24799 in-lb) =0.55 < 1.0, OK (EQ C5-2)

** For comparison, total column stress computed for load case 5 is: 84.0%

izing loads 2648.2208 lb Axial and M=

= 0.753 in^3 * 55000 psi

City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186 By: Bob S Project: Ingersoll Rand Project #: 23-1109-15 Configuration: TYPE 1 SELECTIVE RACK DETERMINE ALLOWABLE MOMENT CAPACITY 2,75 in A) Check compression flange for local buckling (B2.1) 1.75 in w = c - 2*t - 2*r= 1.75 in - 2*0.059 in - 2*0.059 in = 1.514 in1.625 in w/t = 25.66 $l=lambda= [1.052/(k)^0.5] * (w/t) * (Fy/E)^0.5$ Eq. B2.1-4 5.000 in = [1.052/(4)^0.5] * 25.66 * (55/29500)^0.5 0.059 in = 0.583< 0.673, Flange is fully effective Eq. B2.1-1 B) check web for local buckling per section b2.3 f1(comp) = Fy*(y3/y2) =f2(tension) = Fy*(y1/y2) =102.95 ksi Eq. B2.3-5 Y = f2/f1Beam= Intik 50E 5Hx2.75Wx0.059"Thk = -2.012Ix= 2.916 in^4 $k = 4 + 2*(1-Y)^3 + 2*(1-Y)$ Eq. B2.3-4 Sx= 1.114 in^3 = 64.67Ycg= 3.300 in flat depth=w= y1+y3 t = 0.059 in= 4.764 inw/t= 80.74576271 OK Bend Radius=r= 0.059 in $l=lambda= [1.052/(k)^0.5] * (w/t) * (f1/E)^0.5$ Fy=Fyv= 55.00 ksi = [1.052/(64.67)^0.5] * 4.764 * (51.18/29500)^0.5 Fu=Fuv= 65.00 ksi = 0.44< 0.673 E= 29500 ksi be=w= 4.764 in b2 = be/2Eq B2.3-2 top flange=b= 1.750 in b1 = be(3-Y)= 2.38 inbottom flange= 2.750 in = 0.951Web depth= 5.000 in b1+b2=3.331 in > 1.582 in, Web is fully effective f1(comp) Determine effect of cold working on steel yield point (Fya) per section A7.2 Fya= C*Fyc + (1-C)*Fy(EQ A7.2-1) Lcorner=Lc= (p/2) * (r + t/2)0.139 in C = 2*Lc/(Lf+2*Lc)Lflange-top=Lf= 1.514 in = 0.155 indepth m = 0.192*(Fu/Fy) - 0.068(EQ A7.2-4) = 0.1590Bc= 3.69*(Fu/Fy) - 0.819*(Fu/Fy)^2 - 1.79 (EQ A7.2-3) = 1.427since fu/Fv= 1.18 < 1.2 and r/t=1< 7 OK f2(tension) then Fyc= Bc * Fy/(R/t) m (EQ A7.2-2) = 78.485 ksiThus, Fya-top= 58.64 ksi (tension stress at top) Fya-bottom= Fya*Ycg/(depth -Ycg) y1= Ycg-t-r= 3.182 in = 113.84 ksi(tension stress at bottom) y2= depth-Ycg= 1.700 in Check allowable tension stress for bottom flange y2-t-r= 1.582 in Lflange-bot=Lfb= Lbottom - 2*r*-2*t = 2.514 inCbottom=Cb= 2*Lc/(Lfb+2*Lc) = 0.100Fy-bottom=Fyb= Cb*Fyc + (1-Cb)*Fyf = 57.34 ksi

31.26 in-k

Then F*Mn=F*Fya*Sx=[

Fya= (Fya-top)*(Fyb/Fya-bottom)

= 29.54 ksiif F = 0.95

City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S Project: Ingersoll Rand

Configuration: TYPE 1 SELECTIVE RACK

oject: Ingersoll Rand Project #: 23-1109-15

RMI Section 5.2, PT II

Section

BEAM

Beam= Intlk 50E 5Hx2,75Wx0,059"Thk

Ix=Ib= 2.916 in^4 Sx= 1.114 in^3

> P=Product Load= 3,200 lb/pair D=Dead Load= 50 lb/pair

1. Check Bending Stress Allowable Loads

Mcenter=F*Mn= W*L*W*Rm/8

W=LRFD Load Factor= 1.2*D + 1.4*P+1.4*(0.125)*P RMI 2.2, item 8
FOR DL=2% of PL,

W= 1.599

Rm= 1 - [(2*F*L)/(6*E*Ib + 3*F*L)]1 - $(2*150*120 in)/[(6*29500 ksi*2.9155 in^3)+(3*150*120 in)]$ = 0.937 if F= 0.95

Then F*Mn=F*Fya*Sx= 62.06 in-k

Thus, allowable load

per beam pair=W= F*Mn*8*(# of beams)/(L*Rm*W)

= 62.06 in-k * 8 * 2/(120in * 0.937 * 1.599)

= 5,523 lb/pair allowable load based on bending stress

Mend= W*L*(1-Rm)/8

= (5523 lb/2) * 120 in * (1-0.937)/8

= 2,610 in-lb

@ 5523 lb max allowable load

= 1,512 in-lb

@ 3200 lb imposed product load

2. Check Deflection Stress Allowable Loads

Dmax= Dss*Rd

Rd = 1 - (4*F*L)/(5*F*L + 10*E*Ib)

= $1 - (4*150*120 in)/[(5*150*120 in)+(10*29500 ksi*2.9155 in^4)]$

= 0.924 in

if Dmax= L/180

Based on L/180 Deflection Criteria

and Dss= 5*W*L^3/(384*E*Ib)

 $L/180 = 5*W*L^3*Rd/(384*E*Ib*# of beams)$

solving for W yields,

 $W = 384*E*I*2/(180*5*L^2*Rd)$

 $= 384*2.9155 in^4*2/[180*5*(120 in)^2*0.924)$


= 5,516 lb/pair allowable load based on deflection limits


Thus, based on the least capacity of item 1 and 2 above:

Allowable load= 5,516 lb/pair Imposed Product Load= 3,200 lb/pair

Beam Stress= 0.58

Beam at Level 1





Allowable Deflection= L/180

Deflection at imposed Load= 0.387 in

= 0.667 in

City of Puyallup Development & Permitting Services (ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel; 909,596,1351 Fax: 909,596,7186

By: Bob S

Project: Ingersoll Rand


Project #: 23-1109-15

3 Pin Beam to Column Connection

TYPE 1 SELECTIVE RACK

The beam end moments shown herein show the result of the maximum induced fixed end monents form seismic + static loads and the code mandated minimum value of 1.5%(DL+PL)

Mconn max= (Mseismic + Mend-fixity)*0.70*Rho = 9,152 in-lb Load at level 1



rho= 1,0000

Connector Type= 3 Pin

Shear Capacity of Pin

Pin Diam= 0.44 in

Fy= 55,000 psi

Ashear= $(0.438 \text{ in})^2 * \text{Pi/4}$ = 0.1507 in^2

Pshear= 0.4 * Fv * Ashear

= 0.4 * 55000 psi * 0.1507in^2

= 3,315 lb

Bearing Capacity of Pin

tcol= 0.075 in

Fu= 65,000 psi

Omega= 2.22

a = 2.22

Pbearing= alpha * Fu * diam * tcol/Omega

= 2.22 * 65000 psi * 0.438 in * 0.075 in/2.22

= 2,135 lb

< 3315 lb

Moment Capacity of Bracket

Edge Distance=E= 1.00 in

Pin Spacing= 2.0 in

Fy= 55,000 psi

C = P1 + P2 + P3

tclip= 0.18 in

Sclip= 0.127 in^3

= P1+P1*(2.5"/4.5")+P1*(0.5"/4.5")

= 1.667 * P1

Mcap= Sclip * Fbending

C*d = Mcap = 1.667

d = E/2= 0.50 in

 $= 0.127 \text{ in}^3 * 0.66 * \text{Fy}$

= 4,610 in-lbPclip= Mcap/(1.667 * d)

Thus, P1= 2,135 lb

= 4610.1 in-lb/(1.667 * 0.5 in) = 5,531 ib

Mconn-allow= [P1*4.5"+P1*(2.5"/4.5")*2.5"+P1*(0.5"/4.5")*0.5"]

= 2135 LB*[4.5"+(2.5"/4.5")*2.5"+(0.5"/4.5")*0.5"]

= 12,691 in-lb

> Mconn max, OK

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Ingersoll Rand Project #: 23-1109-15

Transverse Brace


Configuration: TYPE 1 SELECTIVE RACK

Section Properties

Diagonal Member= Intlk 1-1/2x1-1/2x14ga Area = 0.315 in^2 r min= 0,488 in

Fy= 55,000 psi K = 1.0


 $\Omega c = 1.92$



Horizontal Member= Intlk 1-1/2x1-1/2x14ga

Area = 0.315 in^2 r min= 0.488 in Fy= 55,000 psi

K = 1.0



Frame Dimensions

Bottom Panel Height=H= 74.0 in

Frame Depth=D= 42.0 in

Column Width=B= 3.0 in

Clear Depth=D-B*2= 36.0 in

X Brace= NO

rho= 1.00

Diagonal Member

▶ 0 Load Case 6: : (1+0.104*Sds)D + [(0.85+0.14Sds)*B*P + [0.7*rho*E]<= 1.0, ASD Method

Vtransverse = 1,123 lb

Vb=Vtransv*0.7*rho= 1123 |b * 0.7 * 1

= 786 lb

Ldiag= $[(D-B*2)^2 + (H-6")^2]^1/2$

= 76.9 in

Pmax= V*(Ldiag/D) * 0.75

= 1,079 lb

axial load on diagonal brace member

Pn= AREA*Fn

= 0.315 in^2 * 11722 psi

= 3,692 lb

Pallow= Pn/Ω

= 3692 lb /1.92

= 1,923 lb

Pn/Pallow=


0.56

<= 1.0 OK

(kl/r)=(k*Ldiag)/r min $= (1 \times 76.9 \text{ in } / 0.488 \text{ in })$ = 157.6 inFe= $pi^2*E/(kl/r)^2$ = 11,722 psi

Since Fe<Fy/2,

Fn= Fe = 11,722 psi



Check End Weld

Lweld= 3.0 in

Fu= 65 ksi

tmin= 0.075 in

Weld Capacity= 0.75 * tmin * L * Fu/2.5

= 4,388 lb

Horizontal brace

Vb=Vtransv*0.7*rho= 786 lb

(kl/r)=(k*Lhoriz)/r min

 $= (1 \times 42 \text{ in}) / 0.488 \text{ in}$

= 86.1 in

Since Fe>Fy/2, Fn=Fy*(1-fy/4fe)

= 35,745 psi

Fe= $pi^2*E/(kl/r)^2$

= 39,275 psi

Pn= AREA*Fn

= 0.315in^2*35745 psi

= 11,260 lb

Fy/2= 27,500 psi

Pallow= Pn/Ωc

= 11260 lb /1.92

= 5,864 lb

Pn/Pallow=

0.13

<= 1.0 OK

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

Ingersoll Rand By: Bob S Project: Project #: 23-1109-15 **Single Row Frame Overturning** Configuration: TYPE 1 SELECTIVE RACK

Critical Load case(s):

1) RMI Sec 2.2, item 7: (0.9-0.2Sds)D + (0.9-0.20Sds)*B*Papp - E*rho

Vtrans=V=E=Qe= 1,123 lb (0.9-0.2Sds) = 0.6952DEAD LOAD PER UPRIGHT=D= 100 lb (0.9-0.2Sds) = 0.6952B = 1.0000

PRODUCT LOAD PER UPRIGHT=P= 6,400 lb

Papp=P*0.67= 4,288 lb Wst LC1=Wst1=(0.6952*D + 0.6952*Papp*1)= 3,050 lb

Product Load Top Level, Ptop= 3,200 lb

DL/LvI= 50 lb Seismic Ovt based on E, $\Sigma(Fi*hi)=139,987$ in-lb

height/depth ratio= 4.6 in

Sds= 1.0240

rho= 1.0000

Frame Depth=Df= 42.0 in


Htop-IvI=H= 192.0 in

Levels= 2

Anchors/Base= 2

h=H+hp/2= 216.0 in

hp= 48.0 in



SIDE ELEVATION

Load case 1:

A) Fully Loaded Rack

Movt= $\Sigma(Fi*hi)*E*rho$

= 139,987 in-lb

Mst= Wst1 * Df/2

Critical Level= 2

Cs*Ip= 0.2560

= 3050 lb * 42 in/2

= 64,050 in-lb

T= (Movt-Mst)/Df

= (139987 in-lb - 64050 in-lb)/42 in

= 1,808 lb

Net Uplift per Column

Net Seismic Uplift= 1,808 lb

Load case 1:

B) Top Level Loaded Only

 \bigcirc V1=Vtop= Cs * Ip * Ptop >= 350 lb for H/D >6.0

= 0.256 * 3200 lb

= 819 lb

V1eff= 819 lb

 $V2=V_{DL}= Cs*Ip*D$

= 26 lb

Mst = (0.6952*D + 0.6952*Ptop*1) * 42 in/2

= 48,177 in-lb

Movt= [V1*h + V2 * H/2]*rho

= 179,405 in-lb

T= (Movt-Mst)/Df

= (179405 in-lb - 48177 in-lb)/42 in

= 3,124 lb

Net Uplift per Column

Net Seismic Uplift= 3,124 lb

Anchor

Check (2) 0.5" x 3.25" Embed HILTI KWIKBOLT TZ anchor(s) per base plate.

Special inspection is required per ESR 1917.

Pullout Capacity=Tcap= 1,961 lb

L.A. City Jurisdiction? NO

Tcap*Phi= 1,961 lb

Shear Capacity=Vcap= 2,517 lb

Phi = 1

Vcap*Phi= 2,517 lb

 $(904 \text{ lb}/1961 \text{ lb})^1 + (280 \text{ lb}/2517 \text{ lb})^1 =$

0.57

<= 1.2 OK

Fully Loaded: Top Level Loaded:

 $(1562 lb/1961 lb)^1 + (204 lb/2517 lb)^1 =$

0.88

<= 1.2 OK

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

Project #: 23-1109-15 By: Bob S Project: Ingersoll Rand

Anchor c.c. =2*a=d = 6.00 in

N=# Anchor/Base= 2

Base Plate

Configuration: TYPE 1 SELECTIVE RACK

Section

Baseplate= 8x5x0.375

Eff Width=W = 8.00 in


Eff Depth=D = 5.00 in

Column Width=b = 3.00 in

Column Depth=dc = 3.00 in

L = 2.50 in

Plate Thickness=t = 0.375 in



Downaisle Elevation

Down Aisle Loads

Load Case 5: : (1+0.105*Sds)D + 0.75*[(1.4+0.14Sds)*B*P + 0.75*[0.7*rho*E]<= 1.0, ASD Method

COLUMN DL= 50 lb

COLUMN PL= 3,200 lb

Base Moment= 8,000 in-lb

1+0.105*Sds= 1.1075

1.4+0.14Sds= 1.5434

Axial=P= 1.10752 * 50 lb + 0.75 * (1.54336 * 0.7 * 3200 lb)

= 2,648 lb

Axial Load P = 2,648 lb

a = 3.00 in

Fy = 36,000 psi

Mb= Base Moment*0.75*0.7*rho

= 8000 in-lb * 0.75*0.7*rho

Moment Stress=fb2 = 2 * fb * L/W

= 4,200 in-lb

Effe Effe

Axial stress=fa = P/A = P/(D*W)

= 66 psi

B= 0.7000

Moment Stress=fb = $M/S = 6*Mb/[(D*B^2])$

= 78.8 psi

Moment Stress=fb1 = fb-fb2

= 29.5 psi

 $M3 = (1/2)*fb2*L*(2/3)*L = (1/3)*fb2*L^2$

= 103 in-lb

S-plate = $(1)(t^2)/6$

 $= 0.023 in^3/in$

fb/Fb = Mtotal/[(S-plate)(Fb)]

0.63

Tanchor = (Mb-(PLapp*0.75*0.46)(a))/[(d)*N/2]No Tension

Critical load case RMI Sec 2.1, Item 4: (1+0.115ds)DL + (1+0.145DS)PL*0.75+EL*0.75 <= 1.0, ASD Method

OK

= 49.2 psi

 $M1 = wL^2/2 = fa*L^2/2$ = .207 in-lb

 $M2 = fb1*L^2)/2$

= 92 in-lb

Mtotal = M1+M2+M3

= 402 in-lb/in Fb = 0.75*Fy

= 27,000 psi

F'p = 0.7*F'c

Tallow= 1,961 lb

= 4,986 psi

ÖK OK

Mbase=Mb = 4,200 in-lb

Pstatic= 2,648 lb

Cross Aisle Loads

Movt*0.75*0.7*rho= 73,493 in-lb

Frame Depth= 42.0 in

P=Pstatic+Pseismic= 4,398 lb

b =Column Depth= 3.00 in

L =Base Plate Depth-Col Depth= 2.50 in

fa = P/A = P/(D*W)

= 110 psi

 $M = wL^2/2 = fa*L^2/2$ = 344 in-lb/in

= 27,000 psi

Fbase = 0.75*Fv

Pseismic= Movt/Frame Depth

= 1,750 lb

Sbase/in = $(1)(t^2)/6$


 $= 0.023 in^3/in$

fb/Fb = M/[(S-plate)(Fb)]0.54

ОК

Check uplift load on Baseplate

Check uplift forces on baseplate with 2 or more anchors per RMI 7.2.2. "When the base plate configuration consists of two anchor bolts located on either side of the column and a net uplift force exists, the minimum base plate thickness shall be determined based on a design bending moment in the plate equal to the uplift force on one anchor times 1/2 the distance from the centerline of the anchor to the nearest edge of the rack column"



Uplift per Column= 3,124 lb

Qty Anchor per BP= 2

Net Tension per anchor=Ta= 1,562 lb

c = 2.50 in

Mu=Moment on Baseplate due to uplift= Ta*c/2

Splate= 0.117 in^3

[fb/Fb]*0.75= 0.463


Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

Project: Ingersoll Rand Project #: 23-1109-15 By: Bob S

Slab on Grade

Configuration: TYPE 1 SELECTIVE RACK



slab Cross Aisle Down Aisle Baseplate Plan View

Concrete

f'c= 7,123 psi

tslab=t= 5.5 in

teff= 5.5 in

phi=Ø= 0.6

Soil

fsoil= 750 psf

Movt= 176,947 in-lb

Frame depth= 42.0 in

Sds= 1.024

0.2*Sds = 0.205

 $\lambda = 0.600$

 $\beta = B/D = 1.600$ F'c^0.5= 84.40 psi

Base Plate

Effec. Baseplate width=B= 8.00 in Effec. Baseplate Depth=D= 5.00 in

Column Loads

width=a= 3.00 in depth=b= 3.00 in

midway dist face of column to edge of plate=c= 5,50 in

midway dist face of column to edge of plate=e= 4.00 in

RMI SEC 2.2 EQTN 5

DEAD LOAD=D= 50 lb per column

unfactored ASD load

PRODUCT LOAD=P= 3,200 lb per column

unfactored ASD load

Papp= 2,144 lb per column

P-seismic=E= (Movt/Frame depth)

= 4,213 lb per column

unfactored Limit State load

B = 0.7000

rho= 1.0000

Sds= 1.0240

0.9 - 0.20Sds= 0.6952

1.2 + 0.2*Sds= 1.4048

Load Case 1) (1.2+0.2Sds)D + (1.2+0.2Sds)*B*P+ rho*E

= 1,4048 * 50 lb + 1,4048 * 0.7 * 3200 lb + 1 * 4213 lb

= 7,430 lb

Load Case 2) (0.9-0.2Sds)D + (0.9-0.2Sds)*B*Papp + rho*E RMI SEC 2.2 EQTN 7

= 0.6952 * 50 lb + 0.6952 * 0.7 * 2144 lb + 1 * 4213 lb

= 5,291 lb

Load Case 3) 1.2*D + 1.4*P

= 1.2*50 lb + 1.4*3200 lb

= 4,540 lb

Load Case 4) 1.2*D + 1.0*P + 1.0E

= 7.473 lb

ACI 318-14 Sec 5.3.1 Eqtn 5.3.1e

RMI SEC 2.2 EQTN 1,2

Effective Column Load=Pu= 7,473 lb per column

Puncture

Apunct= [(c+t)+(e+t)]*2*t

= 225.50 in^2

Fpunct1= $[(4/3 + 8/(3*\beta)] * \lambda *(F'c^0.5)$

= 151.9 psi

Fpunct2= $2.66 * \lambda * (F'c^0.5)$

= 134.7 psi

Fpunct eff= 134.7 psi

fv/Fv= Pu/(Apunct*Fpunct)

0.246 < 1 OK

Slab Bending

Pse=DL+PL+E= 7,473 lb

Asoil= (Pse*144)/(fsoil)

 $= 1,435 in^2$

x = (L-y)/2

= 11.1 in

 $Fb = 5*(phi)*(f'c)^0.5$

= 253.19 psi

 $L= (Asoil)^0.5$

= 37.88 in

 $M = w*x^2/2$

 $= (fsoil*x^2)/(144*2)$

= 320.6 in-lb

 $y = (c*e)^0.5 + 2*t$

= 15.7 in

S-slab= 1*teff^2/6

 $= 5.04 in^3$

fb/Fb= M/(S-slab*Fb)

< 1, OK 0.251




Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S Project: Ingersoll Rand Project #: 23-1109-15

Configuration & Summary: TYPE 2 SELECTIVE RACK



**RACK COLUMN REACTIONS ASD LOADS AXIAL DL= 100 lb AXIAL LL= 5,600 lb SEISMIC AXIAL Ps=+/- 5,374 lb BASE MOMENT = 8,000 in-lb

Seismic Criteria	# Bm Lvls	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=1.28, Fa=1.2	4	42 in	192.0 in	3	94 in	Single Row

Comp	nent				Description				STRESS
Colu	mn	Fy=55 ksi	IN	ITLK LU70/3x3x:	1.4ga	P=427	75 lb, M=10754	in-lb	0.49-OK
Column 8	Backer	None		None			None		N/A
Bea	m	Fy=55 ksi	Intlk 31	1/3.31"deepx2.	75"x0.07"	Lu=94 in	Capacity: 3	3746 lb/pr	0.75-OK
Beam Co	nnector	Fy=55 ksi	Lvl 1:	2 pin OK	Mconn=8	265 in-lb	Mcap=97	726 in-lb	0.85-OK
Brace-Ho	rizontal	Fy=55 ksi			Intlk 1-1/2x1	-1/2x14ga			0.24-OK
Brace-D	agonal	Fy≒55 ksi			Intlk 1-1/2x1	-1/2x14ga			0.99-OK
Base	Plate	Fy=36 ksi		8x5>	(0.375		Fixity= 8	000 in-lb	0.92-OK
Anc	nor	2 per Base	0.5" x 3.25" Et	nbed HILTI KWIK	BOLT TZ ESR 191	7 Inspection Rec	ıd (Net Seismic U	plift=2760 ib)	0.733-OK
Slab 8	Soil		5.5" thk	x 7123 psi slab o	on grade. 750 ps	f Soil Bearing P	ressure		0.47-OK
Level	Load**			Story Force	Story Force	Column	Column	Conn.	Beam
	Per Level	Beam Spcg	Brace	Transv	Longit.	Axial	Moment	Moment	Connector
1	2,800 lb	42.0 in	52.0 in	175 lb	77 lb	5,700 lb	9,043 "#	8,265 "#	2 pin OK
2	2,800 lb	54.0 in	52.0 in	399 lb	177 lb	4,275 lb	10,754 "#	7,702 "#	2 pin OK
3	2,800 lb	48.0 in	74.0 in	599 lb	266 lb	2,850 lb	7,435 "#	5,425 "#	2 pin OK
4	2,800 lb	48.0 in		799 lb	354 lb	1,425 lb	4,249 "#	2,823 "#	2 pin OK

** Load defined as product weight per pair of beams	Total:	1,972 lb	874 lb	
Notes				
				1
				1


City of Puyallup Development & Permitting Services (ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

<u> 1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596</u>	3.7186
---	--------

By: Bob S Project: Ingersoll Rand Project #: 23-1109-15

Configuration & Summary: TYPE 3 SELECTIVE RACK



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 50 lb

AXIAL LL= 4,000 lb

SEISMIC AXIAL PS=+/- 3,690 lb

BASE MOMENT= 8,000 in-lb

Seismic Criteria	# Bm Lvls	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=1.28, Fa=1.2	2	42 in	192.0 in	3	120 in	Single Row

Compo	nent			Description						
Colun	าท	Fy=55 ksi	IN	INTLK LU70/3x3x14ga P=4050 lb, M=17110 in-lb					0.92-OK	
Column &	Backer	None		None			None	N/A		
Beam Fy=55 ksi			Intlk 5	0E 5Hx2.75Wx0	.059"Thk	Lu≔120 in	Capacity:	5516 lb/pr	0.73-OK	
Beam Connector Fy=55 ks		Fy=55 ksi	Lvl 1:	3 pin OK	Mconn=10	0349 in-lb	Mcap=12	2691 in-lb	0.82-OK	
Brace-Hor	izontal	Fy=55 ksi			Intlk 1-1/2x1	-1/2x14ga			0.17-OK	
Brace-Dia	igonal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga						0.7-OK	
Base Pl	ate	Fy≔36 ksi	8x5x0.375 Fixity= 8000 in-lb					000 in-lb	0.71-OK	
Anche	or	2 per Base	0.5" x 3.25" Embed HILTI KWIKBOLT TZ ESR 1917 Inspection Reqd (Net Seismic Uplift=3306 lb)						0.783-OK	
Slab &	Soil		5.5" thk	5.5" thk x 7123 psi slab on grade. 750 psf Soil Bearing Pressure						
Level	Load**			Story Force	Story Force	Column	Column	Conn.	Beam	
	Per Level	Beam Spcg	Brace	Transv	Longit.	Axial	Moment	Moment	Connector	
1	4,000 lb	84.0 in	52.0 in	466 lb	207 lb	4,050 lb	17,110 "#	10,349 "#	3 pin OK	
2	4,000 lb	84.0 in	52.0 in	932 lb	413 lb	2,025 lb	8,679 "#	4,361 "#	3 pin OK	
			74.0 in							

Load defined as product weight per pair of beams	Total:	1,398 lb	620 lb	
Notes				

City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

$E_{ngineering} \ \& \ D_{esign} \ I_{nc.}$


1815 Wright Ave La Verne, CA 91750 Tel: 909,596,1351 Fax: 909,596,7186

By: Bob S

Project: Ingersoll Rand

Project #: 23-1109-15

Configuration & Summary: TYPE 4 SELECTIVE RACK



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 100 lb

AXIAL LL= 5,600 lb

SEISMIC AXIAL Ps=+/- 4,838 lb

BASE MOMENT= 8,000 in-lb

Seismic Criteria	# Bm Lvis	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=1.28, Fa=1.2	4	42 in	192.0 in	3	94 in	Single Row

Compo	nent				Description				STRESS
Colur	nn	Fy=55 ksi	INTLK LU70/3x3x14ga P=57				00 lb, M=9043	0.49-OK	
Column &	Column & Backer None			None			None		N/A
Bear	Beam Fy=55 ks		Intlk 311/3.31"deepx2.75"x0.07"		Lu=94 in Capacity: 3746 lb/pr			0.75-OK	
Beam Cor	nector	Fy≔55 ksi	Lvi 1:	2 pin OK	Mconn=7	396 in-lb	Mcap=9	726 in-lb	0.76-OK
Brace-Hor	Brace-Horizontal Fy=55 ksi				Intlk 1-1/2x1	-1/2x14ga			0.24-OK
Brace-Dia	Brace-Diagonal Fy=55 ksi				Intlk 1-1/2x1	-1/2x14ga			0.99-OK
Base P	Base Plate Fy=36 ksi			8x5x0.375 Fixity= 8000 in-lb					0.89-OK
Anch	or	2 per Base	0.5" x 3.25" Embed HILTI KWIKBOLT TZ ESR 1917 Inspection Reqd (Net Seismic Uplift=2336 lb)						0.625-OK
Slab &	Soil		5.5" thk x 7123 psi slab on grade. 750 psf Soil Bearing Pressur					sure	
Level	Load**			Story Force	Story Force	Column	Column	Conn.	Beam
	Per Level	Beam Spcg	Brace	Transv	Longit.	Axial	Moment	Moment	Connector
1	2,800 lb	42.0 in	52.0 in	194 lb	86 lb	5,700 lb	9,043 "#	7,396 "#	2 pin OK
2	2,800 lb	42.0 in	52.0 in	389 lb	172 lb	4,275 lb	8,272 "#	6,816 "#	2 pin OK
3	2,800 lb	48.0 in	74.0 in	611 lb	271 lb	2,850 lb	7,386 "#	5,007 "#	2 pin OK
4	2,800 lb	36.0 in		778 lb	345 lb	1,425 lb	3,102 "#	2,421 "#	2 pin OK

** Load defined as p	product weight per pair of beams	Total:	1,972 lb	874 lb	
Notes					
1					


City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S Project: Ingersoll Rand Project #: 23-1109-15

Configuration & Summary: TYPE 5 SELECTIVE RACK



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 100 lb

AXIAL LL= 5,600 lb

SEISMIC AXIAL PS=+/- 3,558 lb

BASE MOMENT= 8,000 in-lb

Seismic Criteria	# Bm Lvls	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=1.28, Fa=1.2	4	42 in	192.0 in	3	120 in	Single Row

Compo	nent				Description				STRESS	
Colu	mn	Fy≔55 ksi	II	ITLK LU70/3x3x	1.4ga	P=5700 lb, M=11665 in-lb			0.58-OK	
Column &	Backer	None		None			None		N/A	
Beam Fy=55 ksi Beam Connector Fy=55 ksi		Intlk 5	0E 5Hx2.75Wx0	.059"Thk	Lu=120 in Capacity: 5516 lb/pr			0.51-OK		
		Lvl 1:	3 pin OK	Mconn=5	785 in-lb	Mcap=12	691 in-lb	0.46-OK		
Brace-Horizontal Fy=55 ksi			Ī		Intlk 1-1/2x1	-1/2x14ga			0.24-OK	
Brace-Di	agonal	Fy=55 ksi		Intlk 1-1/2x1-1/2x14ga						
Base F	Base Plate Fy=36 ksi			8x5x0.375				Fixity= 8000 in-lb		
Anch	or	2 per Base	0.5" x 3.25" E	0.5" x 3.25" Embed HILTI KWIKBOLT TZ ESR 1917 Inspection Reqd (Net Seismic Uplift=1488 lb)					0.375-OK	
Slab &	Soil		5.5" thk	5.5" thk x 7123 psi slab on grade. 750 psf Soil Bearing			ressure	0.36-OK		
Level	Load**			Story Force	Story Force	Column	Column	Conn.	Beam	
	Per Level	Beam Spcg	Brace	Transv	Longit.	Axial	Moment	Moment	Connector	
1	2,800 lb	48.0 in	52.0 in	303 lb	135 lb	5,700 lb	11,665 "#	5,785 "#	3 pin OK	
2	2,800 lb	12.0 in	52.0 in	379 lb	168 lb	4,275 lb	2,219 "#	2,903 "#	3 pin OK	
3	2,800 lb	24.0 in	74.0 in	531 lb	235 lb	2,850 lb	3,428 "#	3,185 "#	3 pin OK	
4	2,800 lb	36.0 in		759 lb	336 lb	1,425 lb	3,025 "#	1,985 "#	3 pin OK	

** Load defined as product weight per pair of beams	Total:	1,972 lb	874 lb		
Notes					

$E_{ngineering} \ \& \ D_{esign} \ I_{nc.}$



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

SHELVING ANALYSIS

City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

_1815 Wright Ave	La Verne, CA	91750 Tel: 909.596	1351 Fax: 909.59	3.8561
		- 	TAXI"TAV "TAXIAX	*:***

By: Bz Eng: Mgz

Project: INGERSOLL RAND

Project #: 23-1109-15

Design Data

Configuration: Type A Shelving: 87" H x 48" W x 24" D

- 1) The analyses of the light duty storage fixtures conforms to the requirements of the 2018 IBC and ASCE 7-16
- 2) All steel conforms to ASTM A36, Gr. 36 with minimum yield, Fy= 36 ksi unless otherwise noted on the plans or analysis herein.
- 3) Anchor bolts shall be provided by installer per ICC reference on the calculations herein.
- 4) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.
- 5) The above grade floor is designed by others
- 6) All Hardawre shall conform to Grade 5 properties or better, installed to snug tight fit.

Engineering & Design Inc.

1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type A Shelving: 87" H x 48" W x 24" D

	Load Level	Elevation	Load
ſ	1	3.00 in	200 lb
	2	42.00 in	200 lb
	3	42.00 in	200 lb

Load Reactions

Configuration # of Levels= 3

Axial column DL= 20 lb

Height= 87.00 in

Axial column LL= 300 lb

Width= 48.00 in

Axial column seismic load=+/- 536 lb

Depth= 24.00 in

Net Seismic Uplift per footplate= 1,035 lb

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 200 lb per shelf level

Fa= 1.200

Fv = 1.860

	Component Summary		
Column	Rousseau T Post 14ga	0.14	ОК
Shelf	20 ga Shelf	0.44	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.78	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.94	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.03	OK

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type B Shelving: 87" H x 48" W x 24" D

	Load Level	Elevation	Load	
I	1	3.00 in	160 lb	
	2	28.00 in	160 lb	
	3	28.00 in	160 lb	
	4	28.00 in	160 lb	

Load Reactions

Configuration
of Levels= 4

Axial column DL= 25 lb

Height= 87.00 in

Axial column LL= 320 lb

Width= 48.00 in

Axial column seismic load=+/- 546 lb

Main= 48.00 in

Net Seismic Uplift per footplate= 1,040 lb

Depth= 24.00 in

•

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1= 0.440

Product Load= 160 lb per shelf level

Fa= 1.200

Fv= 1.860

V** V** * (*	Component Summary		
Column	Rousseau T Post 14ga	0.12	ОК
Shelf	20 ga Shelf	0.35	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.80	ОК
X Brace	1" x 13ga strap w/(1) 0.25 in diam bolt per end (Grade 5 Bolt)	0.18	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.95	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.17	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.04	ОК

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type C Shelving: 87" H x 48" W x 24" D

	Load Level	Elevation	Load
ı	1	3.00 in	120 lb
	2	21.00 in	120 lb
	3	21.00 in	120 lb
	4	21.00 in	120 lb
	5	21.00 in	120 lb

Load Reactions

Configuration # of Levels= 5

Axiai column DL= 30 lb

Axial column LL= 300 lb

Height= 87.00 in

Axial column seismic load=+/- 509 lb

Width= 48.00 in

Depth= 24.00 in

Net Seismic Uplift per footplate= 963 lb

Seismic Coeff:

Ss = 1.280

Steel Fy= 33,000 psi

S1 = 0.440Fa= 1.200 Product Load= 120 lb per shelf level

Fv = 1.860

of the community of the control of t	Component Summary		
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.26	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.74	ОК
X Brace	1" x 13ga strap w/(1) 0.25 in diam bolt per end (Grade 5 Bolt)	0.17	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.88	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	OK
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.03	ОК

City of Puyallup Development & Permitting Services (ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

Engineering & Design Inc.

1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type C1 Shelving: 87" H x 48" W x 24" D

_	Load Level	Elevation	Load	
Γ	1	3.00 in	120 lb	
	2	21.00 in	120 lb	
	3	21.00 in	120 lb	
	4	21.00 in	120 lb	
	5	21.00 in	120 lb	

Load Reactions

of Levels= 5

Axial column DL= 30 lb

Height= 87.00 in

Axial column LL= 300 lb

Width= 48.00 in

Axial column seismic load=+/- 509 lb

Depth= 24.00 in

Net Seismic Uplift per footplate= 963 lb

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 120 lb per shelf level

Fa= 1.200

Fv= 1.860

Column	Component Summary Rousseau T Post 14ga	0.11	Ok
Shelf	20 ga Shelf	0.26	OF
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.74	Ok
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.88	Ok
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	OF
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.03	Ok

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type D Shelving: 87" H x 48" W x 24" D

L	oad Level	Elevation	Load
	1	3.00 in	100 lb
	2	17.00 in	100 lb
	3	17.00 in	100 lb
	4	17.00 in	100 lb
	5	17.00 in	100 lb
	6	16.00 in	100 lb

Load Reactions

Configuration

Axial column DL= 35 lb

Axial column LL= 300 lb

Axial column seismic load=+/- 512 lb

Net Seismic Uplift per footplate= 966 lb

of Levels= 6

Height= 87.00 in

Width= 48.00 in

Depth= 24.00 in

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 100 lb per shelf level

Fa= 1.200

Fv = 1.860

and the second second second second	Component Summary	1 - 10-10	
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.22	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.75	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Regd During Install	0.88	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.03	OK



Engineering & Design Inc.

1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type D1 Shelving: 87" H x 48" W x 24" D

Load Level	Elevation	Load
1	3.00 in	100 lb
2	17.00 in	100 lb
3	17.00 in	100 lb
4	17.00 in	100 lb
5	17.00 in	100 lb
6	16.00 in	100 lb

Load Reactions

Configuration # of Levels= 6

Axial column DL= 35 lb

Height= 87.00 in

Axial column LL= 300 lb

Width= 48.00 in

Axial column seismic load=+/- 512 lb

Net Seismic Uplift per footplate= 966 lb

Depth= 24.00 in

Seismic Coeff:

Ss = 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 100 lb per shelf level

Fa= 1.200

Fv= 1.860

and the first of the state of the state of	Component Summary	745 - 200 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	. Y. W
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.22	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.75	OK
X Brace	1" x 13ga strap w/(1) 0.25 in diam bolt per end (Grade 5 Bolt)	0.17	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.88	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.03	ОК

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type E Shelving: 87" H x 48" W x 24" D

	Load Level	Elevation	Load	
I	1	3.00 in	90 lb	
	2	14.00 in	90 lb	
	3	14.00 in	90 lb	
	4	14.00 in	90 lb	
	5	14.00 in	90 lb	
	6	14.00 in	90 lb	
	7	14.00 in	90 lb	

Load Reactions

Configuration # of Levels= 7

Axial column DL= 40 lb

Height= 87.00 in

Axial column LL= 315 lb

Width= 48.00 in

Axial column seismic load=+/- 535 lb

Depth= 24.00 in

Net Seismic Uplift per footplate= 1,004 lb

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 90 lb per shelf level

Fa= 1.200

Fv= 1.860

	Component Summary		
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.20	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.78	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.93	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.17	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.04	ОК

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type F Shelving: 87" H x 48" W x 24" D

	Load Level	Elevation	Load
ſ	1	3.00 in	75 lb
	2	12.00 in	75 lb
	3	12.00 in	75 lb
	4	12.00 in	75 lb
	5	12.00 in	75 lb
	6	12.00 in	75 lb
	7	12.00 in	75 lb
	8	12.00 ln	75 lb

Load Reactions

Seismic Coeff:

Configuration # of Levels= 8

Axial column DL= 45 lb

Height= 87.00 in

Axial column LL= 300 lb

Width= 48.00 in

Axial column seismic load=+/- 519 lb

Net Seismic Uplift per footplate= 972 lb

Depth= 24.00 in

Steel Fy= 33,000 psi

Ss= 1.280 S1 = 0.440

Product Load= 75 lb per shelf level

Fa= 1.200

Fv = 1.860

	Component Summary		
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.16	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.76	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.89	ОК
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.16	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.04	OK

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596,1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Summary of Results

Configuration: Type G Shelving: 87" H x 48" W x 24" D

Load Level	Elevation	Load
1	3.00 in	70 lb
2	10.50 in	70 lb
3	10.50 in	70 lb
4	10.50 in	70 lb
5	10.50 in	70 lb
6	10.50 in	70 lb
7	10.50 in	70 lb
8	10.50 in	70 lb
9	10.50 in	70 lb

Load Reactions

Configuration

Axial column DL= 50 lb

of Levels= 9 Height= 87.00 in

Axial column LL= 315 lb

Width= 48,00 in

Axial column seismic load=+/- 546 lb

Depth= 24.00 in

Net Seismic Uplift per footplate= 1,022 lb

Seismic Coeff:

Ss= 1.280

Steel Fy= 33,000 psi

S1 = 0.440

Product Load= 70 lb per shelf level

Fa= 1.200

Fv= 1.860

de la colonia	Component Summary		
Column	Rousseau T Post 14ga	0.11	ОК
Shelf	20 ga Shelf	0.15	ОК
Steel Panel	24 ga Back Panel with (1) 1/4" diam bolt at 18" o.c., 24 ga Side Panel with weld or bolt at 12" o.c.	0.80	ОК
Anchor**	(2)3/8" x 2-1/2" Embed HILTI KB TZ2 (ICC ESR 4266) per footplate. Special Inspec. Reqd During Install	0.94	OK
Footplate	5.5 in * 4 in * 0.25 in Thk [with (1) 1/4"Diam Gr5 M.B. to Post]	0.17	ОК
Slab	5.5 in thick x 7123 psi slab/750 psf soil	0.04	OK

City of Puyallup Development & Permitting Services ISSUED PERMIT Building Planning Engineering Public Works Fire Traffic

$E_{ngineering} \ \& \ D_{esign} \ I_{nc.}$

1815	Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.	593.8561
By: Bz Eng: Mqz	Project: INGERSOLL RAND	Project #: 23-1109-15
Seismic Forces Confi	guration: Type A Shelving: 87" H x 48" W x 24" D	
V1= S _{DS} *W/R		
$V2= [0.4*ap*S_{DS}*Ws*(3)]$	1+2*z/h)/(Rp/Ip)]	# Load Levels= 3
V3= 0.044*Sds		Ss= 1,280
V4 = 0.5*S1/R	$V_{minlmum} = 0.015$	S1= 0.440
		Fa= 1.200
V1= 0.4096		Fv= 1.860
V2= 0.1638		Sds= 1.024
V3= 0.0451		Sd1 = 0.546
V4= 0.0000		Rp=2.5
Selsmic Coeff=Cs= 0.4096		ap= 1.0
(Either Direction)	W = DL + LL*0.67	Ip= 1.00
	= 442 lb	R=Rp= 2.50
Cs * Ip = 0.4096	A.	z/h = 0.00
		Grnd Floor Install
V= Cs * W		Depth=D= 24.0 in
= 181 lb		



$E_{ngineering} \ \& \ D_{esign} \ I_{nc.}$

eismic Forces	mic Forces Configuration: Type A Shelving: 87" H x 48" W x 24" D					
ransverse Distribution						
Level	LL	DL	hi	wi*hi	Fi	Fi*hi
1	200 lb	10 lb	3 in	630	4.0 lb	12 in-ib
2	200 lb	10 lb	45 in	9,450	60.3 lb	2,715 in-lb
3	200 lb	10 lb	87 in	18,270	116.6 lb	10,148 in-lb

Sum: 600 lb 40 lb 28,350 181 lb 12,875 in-# = Movt

Transverse Column Loads

All lateral loads taken by the closed steel panels or X bracing

Axial DL per post= 20 lb Axial LL per post= 300 lb

Movt= 12,875 in-lb

Pseismic= Movt/D = 536 lb

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

 $\Omega f = 1.67$

Cb = 1.0

Cmx= 0.85

Kx = 1.0

Ky = 1.0

Lx = 42.0 in

Ly = 42.0 in

E= 29,500 ksi

Project #: 23-1109-15

Rear Double "T" Post

Configuration: Type A Shelving: 87" H x 48" W x 24" D

Net Section Properties

Column= Rousseau T Post 14ga

 $Aeff = 0.297 in^2$

Ix (downaisle) = 0.057 in⁴

 $Sx (downaisle) = 0.070 in^3$

rx (downaisle) = 0.438 in

Iy (crossaisle) = 0.081 in⁴

Sy (crossaisle) = 0.063 in³

ry (crossaisle) = 0.525 in

Fy= 33 ksi Axial DL= 20 lb

Axial LL= 300 lb

Pseismic= 536 lb

Load Case: (Fully Loaded) Axial=P= DL+0.75LL+0.75*0.7*Pseismic

= 526 lb

Moment=My= 0 in-lb



Loads

KxLx/rx = 1*42"/0.438"

= 95.9

KyLy/ry = 1*42"/0.525"

= 80.0

Fy/2 = 16.5 ksi

 $\Omega c = 1.92$

Fe= $\pi^2E/(KL/r)$ max^2


= 31.7ksi


Pn= Aeff*Fn

= 7,247 lb

P/Pa= 0.14

< 0.15





Fe > Fy/2

Fn= Fy(1-Fy/4Fe)

= 33 ksi*[1-33 ksi/(4*31.7 ksi)]

= 24.4 ksi

Pa= Pn/Ωc

= 7247 lb/1.92

= 3,775 lb

Bending Analysis

Check: $P/Pa + My/May \le 1.0$

Pno= Ae*Fv

= 0.297 in^2 *33000 psi

= 9,801 lb

May= My/Ωf

= 2079 in-lb/1.67

= 1,245 in-lb

 $\mu = \{1/[1-(\Omega c^*P/Pcr)]\}^{-1}$

 $= \{1/[1-(1.92*526 \text{ lb/9408 lb})]\}^{-1}$

= 0.89

Pao= Pno/Ωc

= 9801lb/1.92

= 5,105 lb

Pcr= $\pi^2EI/(KL)$ max 2

 $= \pi^2*29500000 \text{ psi/(1*42 in)}^2$

= 9,408 lb

Myield=My= Sy*Fy

= 0.063 in^3 * 33000 psi

= 2,079 in-lb

Combined Stresses

(526 lb/3775 lb) + (0 in-lb/1245 in-lb) =

0.10

< 1.0, OK



Engineering & Design Inc.

1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593,8561

By: Bz Eng: Mgz

Project: INGERSOLL RAND

 $\Omega f = 1.67$

Cb = 1.0

Cmx= 0.85

Kx = 1.0

Ky = 1.0

Lx = 0.0 in

Ly = 42.0 in

E= 29,500 ksi

Project #: 23-1109-15

Front Box Post

Configuration: Type A Shelving: 87" H x 48" W x 24" D

Net Section Properties

Column= Rousseau T Post 14ga

 $Aeff = 0.297 in^2$

Ix (downaisle) = 0.057 in 4

 $Sx (downaisle) = 0.070 in^3$

rx (downaisle) = 0.438 in

Iy (crossaisle) = 0.081 in^4

Sy (crossaisle) = 0.063 in³

ry (crossaisle) = 0.5 in

Fy= 33 ksi

Axial DL= 20 lb


Axial LL= 300 lb

Pseismic= 536 lb

Load Case: (Fully Loaded)

526 lb

Moment=Mx= 0 in-lb





KxLx/rx = 1*0"/0.438"

= 0.0

KyLy/ry = 1*42"/0.525"

= 80.0

Fy/2 = 16.5 ksi

 $\Omega c = 1.92$


Fe= $\pi^2E/(KL/r)$ max²

= 45.5 ksi

Pn= Aeff*Fn

= 8,024 lb

P/Pa= 0.13 ≤ 0.15



Fe > Fy/2

Fn= Fy(1-Fy/4Fe)

 $= 33 \text{ ksi}^{1-33} \text{ ksi}/(4*45.5 \text{ ksi})$

= 27.0 ksi

Pa= Pn/Ωc

= 8024 lb/1.92

= 4,179 lb

Bending Analysis

Check: $P/Pa + My/May \le 1.0$

Pno= Ae*Fy

= 0.297 ln^2 *33000 psi

= 9,801 lb

May= My/ Ωf

= 2310 in-lb/1.67

= 1,383 in-lb

 $\mu = \{1/[1-(\Omega_{c}*P/P_{cr})]\}^{-1}$

 $= \{1/[1-(1.92*526 \text{ lb}/13369 \text{ lb})]\}^{-1}$

Pao= Pno/Ωc

= 9801lb/1.92

= 5,105 lb

 $Pcr = \pi^2EI/(KL)max^2$

 $= \pi^2*29500000 \text{ psi/(1*42 in)}^2$

= 13,369 lb

Myield=My= Sx*Fy

= 0.07 in^3 * 33000 psi

= 2,310 in-lb

Combined Stresses

(526 lb/4179 lb) + (0 in-lb/1383 in-lb) =

0.10

< 1.0, OK

(EQ C5-3)





1815 Wright Ave., La Verne, CA 91750 Tel: 909,596,1351 Fax: 909,593,8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Configuration: Type A Shelving: 87" H x 48" W x 24" D

It is assumed that the downaisle lips will carry 2/3 of the total shelf load, with the remainder carried by the transverse lips

Beam Type= 20 ga Shelf

Ix= 0.0350 in^4


Sx= 0.046 in^3


Fy-beam= 33,000 psi

Shelf Span=L= 48 in

Max Shelf LL= 200 lb

Load=w=LL*(2/3)/(2*L)=16.5 plf





Check Beam Bending

 $M = w * L^2/8$

= 396 in-lb

fb= M/Sy

= 8,609 psi

Fb= 0.6 * Fy 19,800 psi

fb/Fb=

0.44

Check Beam Deflection


E= 29,500,000 psi

 $D = 5 * w * L^4/(384 * E * Ix)$

= 0.0950 in

Dallow= L/180

0.27 in OK







1815 Wright Ave., La Verne, CA 91750 Tel: 909.596,1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Closed Back Panel

Configuration: Type A Shelving: 87" H x 48" W x 24" D

The closed back and side panels will act as a steel diaphragm transferring the lateral loads to the floor.

Shear per Frame=V= 181 lb

L= 48.0 in

Height= 87.0 in

Movt= Σ (Fi*hi)*1.15*0.7

= 29,613 in-#

Omega= 2,0

Bolt Frequency= 12 in o.c.

Bolt/Post=N= 9

Seismic Load per bolt=Vb= (Movt/D)/N

= 69 lb

Check Bolt

Fv= 28,000 psi

Fu= 65,000 psi

Bolt Diam= 0.25 in

tmin= 0.0300 in

Bolt Shear Capacity= Bolt Area * Fv/Omega


= 687 lb OI

Bolt Bearing Capacity= 1.2 * Bolt Diam *tmin * Fu /Omega

= 293 lb

Bolt Stress= 0.24

OK OK



Front Elevation

Closed Side Panel

The closed back and side panels will act as a steel diaphragm transferring the lateral loads to the floor.

Shear per Frame=V= 181 lb

Frame Depth=d= 24.0 in

Height= 87.0 in

Movt= 29,613 in-#

Omega= 2.0

Weld Frequency= 12 in o.c.

Bolt/Post=N= 8

Seismic Load per bolt=Vb= (Movt/D)/N

= 154 lb

Check Weld on Formed Steel

Lweld= 0.375 in

Fu= 65 ksi


tmin= 0.024 in

Weld Capacity= [1-(0.01*L/t)]*L*Fu*1.0/2.5

= 197 lb

Weld Stress= 0.78

OK



Side Elevation

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596,1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Anchors

Configuration: Type A Shelving: 87" H x 48" W x 24" D

Loads

Check load case: 0.9D + 0.9*0.67LL + V

Type= Sgl Row Units

Vtrans=V*n= 181 lb

DL/Frame*n≈ 40 lb

LL/Frame*n= 600 lb

Wst=0.9*(DL+ 0.67LL)total= 398 lb LL @ TOP= 200 lb

DL/Lvl= 10 lb

DL*0.9= 9 lb

Lateral Ovt Forces= Σ (Fi*hi)*1.15*n= 14,806 in-lb


Frame Depth*n=D= 24.0 in

Htop-lvl= 87.0 in

Levels= 3

Anchors/Post= 2

n= 1



1) Fully Loaded rack

Vtrans= 181 lb

Movt= $\Sigma(Fi*hi)$

= 29,613 in-lb

Mst= Wst * D/2

= 398 lb * 24 in/2

= 4,776 in-lb

Uplift=T= (Movt-Mst)/D

= (29613 in-lb - 4776 in-lb)/24 in

= 1,035 lb

2) Top Level Loaded Only

Critical Level= 3

Vtop= 0.4096 * (200 lb + 10 lb)

= 86 lb

Mst = 0.6*(DL-total + LL-top)*D/2

= (200 lb * 0.67 + 10 lb*0.6) * 24 in/2

= 1,896 in-lb

Hgt @ Lvl 3= 87.0 in

Movt= Vtop*Htop*1.15

= 86 lb * 87 in * 1.15

= 17,208 in-lb

Uplift=T= (Movt-Mst)/D

= (17208 in-lb - 1896 in-lb)/24 in

= 638 lb

Check (2) 3/8" x 2-1/2" Embed HILTI KB TZ2 anchor(s) per footplate Special inspection is required per ICC ESR 4266 in SDC C,D&E

Net Uplift1= 1,035 lb

Net Uplift2= 638 lb

Pullout Capacity=Tcap= 500 lb

Shear Capacity=Vcap= 500 lb

Phi= 1.00

Tcap*Phi= 500 lb Vcap*Phi= 500 lb

Fully Loaded:

1.13

Top Level Loaded:

 $(518 \text{ lb/500 lb})^1 + (45 \text{ lb/500 lb})^1 =$ $(319 \text{ lb/}500 \text{ lb})^1 + (22 \text{ lb/}500 \text{ lb})^1 =$

0.68

<= 1.2 OK

<= 1.2 OK

Check Attachment of Post to Base Plate

Bolt Diam= 0.25 in

Bolt=N= 1

Fv = 21,000 psi

Fu-steel= 58,000 psi t-min= 0.150 in

Bolt Shear= Uplift*0.525

= 543 lb

Shear Capacity= Bolt Area * N * Fv

= 1,031 lb

OK

Bearing Capacity= Bolt Diam * t-min * 1.2 * Fu

= 2,610 lb

OK

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

By: Bz Eng: Mqz

Project: INGERSOLL RAND

Project #: 23-1109-15

Base Plate

Configuration: Type A Shelving: 87" H x 48" W x 24" D

Section

Actual base plate size is 5.5 in x 4 in x 0.25 in thk


Eff Width=W = 5.50 in Eff Depth=D = 4.00 in


Plate Thickness=t = 0.250 in

Column Width=b = 1.625 in Column depth=b = 2.000 in

L = 2.00 inFy = 36,000 psi

DL+0.75LL + 0.75*0.7*Pseismic= 526 lb





Cross Aisle Loads

Axial DL= 20 lb

Axial L= 300 lb

Pseismic= 536 lb

L = Base Plate Depth-Col Depth

= 1.94 in

fa = P/A = P/(D*W)

= 24 psi

 $M = wL^2/2 = fa*L^2/2$

= 45 in-lb/in

Sbase/in = $(1)(t^2)/6$

 $= 0.01 in^3/in^3$

Fbase = 0.75*Fy

= 27,000 psi

fb/Fb = M/[(S-plate)(Fb)]

0.16

ОК

Engineering & Design Inc.



1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561


By: Bz Eng: Mgz

Project: INGERSOLL RAND

Project #: 23-1109-15

Slab on Grade

Configuration: Type A Shelving: 87" H x 48" W x 24" D




Base Plate

B= 5.50 in

D = 4.00 in

width=a= 1.63 in depth=b= 2.00 in



Concrete f'c= 7,123 psi tslab=t= 5.5 in phi=Ø= 0.60

> Soil fsoil= 750 psf Movt= 12,875 in-lb

Baseplate Plan View

eff. baseplate width=c= 3.56 in eff. baseplate depth=e= 3.00 in

Load Case 1: Product + Seismic

Product DL= 30 lb

Product LL= 300 lb

P-seismic=E= (Movt/Frame depth)

(Strength Design Loads)

Puncture

Pu= 1.2DL + 1.0LL + 1.0*E

Apunct= [(c+t)+(e+t)]*2*t

= 193.19 in^2

= 872 lb

Slab Bending

Asoil= (P*144)/(fsoil) = 168 in^2

x = (L-y)/2

= 0.0 in

Fb= 5*(phi)*(fc)^0.5

= 253.19 psi

= 536 lb

Fpunct= 2.66*sqrt(fc)*phi = 134.7 psifv/Fv= Pu/(Apunct*Fpunct)

> 0.03 < 1.0 OK

L= (Asoil)^0.5

= 12.96 in

 $M = w*x^2/2$ $= (fsoil*x^2)/(144*2)$

= 0 in-lb

 $y=(c*e)^0.5 + t*2$

= 14.3 in

S-slab= 1*t^2/6 $= 5.04 in^3$

fb/Fb= M/(S-slab*Fb) 0.00

< 1.0 OK

Load Case 2: Static Loads

PDL= 30 lb

PLL= 300 lb

Puncture

Pu= 1.2*PDL + 1.6*PLL

= 516 lb

Apunct= [(c+t)+(e+t)]*2*t

= 193 in^2

Slab Bending

Asoil= (Pu*144)/(fsoil)

= 99 in^2

x = (L-y)/2

= 0.0 inFb= 5*(phi)*(f'c)^0.5

= 253.19 psi

L= (Asoil)^0.5

= 9.95 in

 $M = w*x^2/2$

 $= (fsoil*x^2)/(144*2)$

= 0 in-lb

= 134.7 psi fv/Fv= Pu/(Apunct*Fpunct)

Fpunct= 2.66*sqrt(f'c)*phi

< 1.0 OK

0.02

 $y = (c*e)^0.5 + t*2$

= 14.3 inS-slab= 1*t^2/6

 $= 5.04 in^3$

fb/Fb= M/(S-slab*Fb)

0.00 < 1.0, OK