



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 14, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCTI20230447

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION INC. PO BOX 899 AUBURN, WA 98071-0899

To construct: Installation of manufacturing equipment and machines, crane structure, assembly and testing workstations and storage racking within existing warehouse building. Work includes existing slab modifications for new equipment foundations, equipment anchorage, and new roof penetrations for equipment exhaust piping. * REVISION (1) - 10/6/2023 - ADDITION OF (1) LAB SINK, (1) HAND SINK AND (2) FLOOR SINKS IN THE TEST LAB

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. complete DWV thru roof and retest
2. insulate hot water lines
3. provide signage at non potable sink as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org