

City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 16, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCCP20221725

Property Address: 201 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

To construct: New electrical trenching- Install new sidewalk- Grading for new

enclosed stair - COMMUNITY HEALTHCARE - CANNERY BLDG PRCTI20221698STOP WORK ORDER generated on 08/01/2023 by username 'Jeff Hill'.STOP WORK ORDER removed on 09/27/2023 by

username 'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Archer installed the 1-1/2" water service out of the RPBA stopping before entering the building.

The water service street patch was not tee cut, no tack, no collar around the valve box and done in 4" plus lifts. This makes it a temp patch and all of the asphalt will need to be removed and replaced before the grind and overlay top 2" is paved.

Corrections:

- 1 When blocking the sidewalk the contractor must have sidewalk closed ahead, sidewalk closed, and a pedestrian detour set up.
- 2 install catch basin socks along the frontage.

Sincerely,

Jeff Hill Engineering Tech IV Jhill@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

(253) 841-5424