



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Feb 16, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20221725

**Property Address:** 201 W MAIN, PUYALLUP, WA 98371;

**Contractor:** ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

**To construct:** New electrical trenching- Install new sidewalk- Grading for new enclosed stair - COMMUNITY HEALTHCARE - CANNERY BLDG  
PRCTI20221698STOP WORK ORDER generated on 08/01/2023 by username 'Jeff Hill'.STOP WORK ORDER removed on 09/27/2023 by username 'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Archer installed the 1-1/2" water service out of the RPBA stopping before entering the building.

The water service street patch was not tee cut, no tack, no collar around the valve box and done in 4" plus lifts. This makes it a temp patch and all of the asphalt will need to be removed and replaced before the grind and overlay top 2" is paved.

**Corrections:**

- 1 When blocking the sidewalk the contractor must have sidewalk closed ahead, sidewalk closed , and a pedestrian detour set up.
- 2 remove temp paving from the water service trench, tee cut, and full depth pave.

Sincerely,

Jeff Hill  
Engineering Tech IV  
[Jhill@PuyallupWA.gov](mailto:Jhill@PuyallupWA.gov)



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 841-5424