City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 16, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRGR20230972

Property Address: 2902 E PIONEER, PUYALLUP, WA 98372

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Early Clear, Grade, and Fill for the associated East Town Crossing Civil

Permit submittal (2902 E PIONEER, PUYALLUP, WA 98372)

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: McKee is mowing the high grass and brush. Another crew is preparing the grade along Shaw Rd. for fencing. Fencing is scheduled for next week. They are installing advanced warning signs along Pioneer, east and west from construction entrance.

See Corrections below. Corrections for TESC will be an ongoing reminder.

Corrections:

- 1 Need CESCLE on board for construction SWPPP and inspection reports. Need construction entrance installed.
 - Trucks are cutting the corners and beginning stain and track out. Install Silt fencing ASAP.

Install silt socks along north bound Shaw Rd.

Besides silt fence along Pioneer, be prepared to protect the ditch.


Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636