



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 22, 2024                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCNC20221036

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** LEVEL 0

- 1. SE stairwell entry wall rated top out approved
- 2. walls next to elevator shaft one side only approved

LEVEL ONE

- 1. vestibule 1 west end of building ok to cover exterior walls one side only

**Corrections:**

1 LEVEL TWO

- 1. MECH shaft next to room 207 south, east, and west wall complete fire stop do not insulate
- 2. north wall approved
- 3. MECH shaft next IDF room north wall approved
- 4. west wall complete putty packs around electrical boxes do not insulate
- 5. elevator shaft east and south wall approved
- 6. MECH shaft next to elevator shaft east, west, and north wall approved
- 7. stairwell wall at SE corner complete putty packs at electrical boxes do not insulate

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Kevin Spruell

Building Inspector I

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590