

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Feb 22, 2024	Inspection Result:	PARTIAL PASS
Permit Number:			
Property Address:	1601 39TH AVE SE, PUYALLUP, WA 98374;		
Contractor:	ABSHER CONSTRU	CTION CO. PO BOX 280 P	UYALLUP, WA 98371-0152
To construct:	New ~54,000 SF building containing labs, classrooms, faculty and		
	student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS &		
	DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS		
	(NO CHANGE IN SQ FTG OR COST)		

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

LEVEL ONE

 hard lid at MECH shaft next to elevator provide listing for rated ceiling not approved
 2.custodial room 121 next to MDF room missing return duct R/I approved
 LEVEL TWO
 1. bathroom hard lids approved
 2.soffits at southwest end of building approved
 LEVEL THREE
 1.MECH approved for insulation except as noted on city approved plans page M203

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org