



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 26, 2024

Inspection Result: **FAILED**

Permit Number: PRRASF20221703

Property Address: 1404 SHAW RD, PUYALLUP, WA 98372;

Contractor: MICHAEL E ALLEN CONST INC 3623 32ND AVE E TACOMA, WA 98443-1600

To construct: Building an addition of 2,905 square feet with a 2 car garage of 732 square feet.

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete insulation at rim joist at west wall.
- 2 ; complete twine at wall insulation above beam.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684