

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection:	Feb 26, 2024	Inspection Result:	PARTIAL PASS
Permit Number: Property Address:		e, puyallup, wa 98374;	
		JCTION CO. PO BOX 280 Foulding containing labs, class	PUYALLUP, WA 98371-0152 ssrooms, faculty and
	student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS		
	(NO CHANGE IN S		ILC SET OF DOCUMENTS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: LEVEL 0 1. head out entry to stair well approved one side LEVEL TWO 1.rated stair wall in room 208 at SE stairwell approved 2.progression inspection approved 3.drywall next to mech shaft next IDF room approved 4. provide install instructions for access doors for fire dampener's at MECH shafts next to elevator due not tape

## Corrections:

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org