



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 26, 2024

Inspection Result: NOT READY

Permit Number: PRCTI20230304

Property Address: 1102 E MAIN, PUYALLUP, WA 98372;

Contractor: PINNACLE CONSTRUCTION INC PO BOX 426 GLENWOOD, IA 51534

To construct: Interior building remodel. New electrical . New plumbing supply lines . Two new bathrooms along with air supply and connections to existing sewer. Relocate hot water heater and provide new exit door. New insulation ceilings and cosmetic improvements throughout * REV (1)
2.13.2024 - ADDITION OF MINI SPLIT HEAT PUMP SYSTEM ROOFTOP

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide install instruction for MECH equipment on sit at time of next inspection as discussed with john

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590