



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 29, 2024

Inspection Result: **PASSED**

Permit Number: PRCTI20221019

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

To construct: Tenant Improvement to build an a new office within an existing warehouse suite and revise an existing toilet partition to meet ADA standards in the existing men's restroom. Area of work: 2,755 SF No change to existing. - PROLOGIS SUITE 103

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide fire, engineering, and planning final approval prior to next inspection
2. provide balance report
3. provide plumbing boot at drain at break room sink
4. insulate recirc lines at hot water tank in janitors closet
5. complete birc clips
6. complete perimeter wires
7. provide occupancy signage at front door
8. complete plumbing boots at sinks in mens and womens bathrooms
9. complete partitions at existing mens bathrooms per city approved plans

Sincerely,

Monty Johnson



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sr Building Inspector

Monty@PuyallupWA.gov

(253) 770-3326