



February 15, 2024

Brian Snowden
Building Division, City of Puyallup

Project Name: MultiCare Health System
Sign Permit Number: PRSG20240079

Dear Mr. Snowden,

I hope this letter finds you well. We have thoroughly reviewed the feedback provided and are dedicated to ensuring our project aligns with all city regulations and guidelines.

Please see our responses below:

1. **Anchors:** We will be using ITW Buildex - Tapcon 28375 Anchors 1/4" x 1-3/4", ESR-1671 which requires a special inspection. The WABO certified inspector will be Colin Wright from Materials Testing & Consulting Inc. his contact number is 360-755-1990 and email: colin.wright@mtc-inc.net.
2. **Weight:** The overall weight of the sign is 60 lbs.

For expedited responses, we kindly request that you also contact our Project Administrators, **Michelle Cena** at michelle@clearwaysigns.com and **Pauline Ross** at pauline@clearwaysigns.com. They will be readily available to provide any additional information or clarification.

We appreciate your time and consideration in reviewing our responses. If there are any additional steps or information required, please do not hesitate to contact us.

Thank you.

Sincerely,

Zach Sevener
Project Manager, Clearway Signs
zach@clearwaysigns.com