



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 05, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: LEVEL THREE

1.areas on exterior walls that where wet approved for insulation except on radius wall

Corrections:

1 LEVEL TWO

1. southeast stair wall complete insulation as discussed with contractor do not cover
- 2.MECH shaft next to room 207 south wall complete insulation as discussed with contractor do not cover
- 3.east, west, and north wall approved
- 4.elevator shaft east and south wall approved
- 5.MECH shaft next to elevator east,west,south and north walls approved
- 6.MECH shaft next to IDF room north and west wall approved

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 841-5590