



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 06, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCTI20221698

**Property Address:** 201 W MAIN, PUYALLUP, WA 98371;

**Contractor:** ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

**To construct:** Remodel of existing office building to a medical/dental clinic - CHC  
CANNERY \* REVISION (1) - 1/26/2024 - CORRECT OCCUPANCY, FULL  
RE-ROOF AND WALL ASSEMBLIES

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 this inspection is for first floor from grid line 10 to south exterior to include one side of wall of corridor to north
  - 1.room 141 provide nail plate at plumbing by sink
  - 2.room 142 complete head out mech in wall
  3. room 149 complete fastener at studs in NE corner
  - 4.provide floor support at west exterior wall as discussed with contractor
  - 5.room 128 provide nail plate at plumbing at sink
  - 6.in corridor at north wall at room 136 provide nail plate at plumbing
  7. ok to insulate

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)