



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 12, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: LEVEL TWO

1. fur out wall in room 231 at east exterior approved

LEVEL THREE

MECH shaft in room 308 fill ins at north and south wall approved

Corrections:

1 LEVEL TWO

1.MECH shaft next to room 207 south, east,and west wall complete fire stop do not insulate

2.north wall approved

3.MECH shaft next IDF room north wall approved

4.west wall complete putty packs around electrical boxes do not insulate

5. elevator shaft east and south wall approved

6.MECH shaft next to elevator shaft east,west,and north wall approved

7.stairwell wall at SE corner complete putty packs at electrical boxes do not insulate

Sincerely,

Kevin Spruell



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590