



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 13, 2024

Inspection Result: **FAILED**

Permit Number: PRDE20240287

Property Address: 2317 SHAW RD, PUYALLUP, WA 98374;

Contractor:

To construct: DEMO BARN & SHED ON PROPERTY

On this day we have inspected your construction for **Utility Capping Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The utilities are still attached to the structures. Excavate and cap all utilities away from the structures.

Corrections:

- 1 All utilities must be capped from their source away from the demolition.

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424