



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 15, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221698

Property Address: 201 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

To construct: Remodel of existing office building to a medical/dental clinic - CHC
CANNERY * REVISION (1) - 1/26/2024 - CORRECT OCCUPANCY, FULL
RE-ROOF AND WALL ASSEMBLIES

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved 2nd layer of drywall nailing for sound walls 6 at rooms - 120,121,127,129 only.

2 ; Drywall nailing complete at 1st floor exterior walls at grid line - (B,10-14) (14,B-G) (G,7-14)

Corrections:

- 1 1. zone 1 no exteriors approved
2.rooms 127A and 126A first layer approved

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org