



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 15, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20230656

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA
98134 Sam Eastman 2500 Holgate St Tacoma, WA 98402

To construct: An 853 SF tenant improvement to the the existing Women's Clinic Suite
3100, located on the 3rd floor, including exam rooms and patient and
staff support areas. MULTICARE WOMEN'S CLINIC

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide balance report with O.S.A. as per city approved plans.
- 2 ; T.C.O. approved for 10 working days from 3/15/2024

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org