

Hydraulic Calculations for

Project: Homewood Suites
3500 South Meridian
Puyallup, WA. 98373

Drawing no.: FS-9
Date: 3/3/2024

Design

Remote area number: Area 1
Remote area location: 5th Floor Room 502-504
Occupancy classification: Light Hazard
Density: 0.10 gpm./ft.2
Area of application: 4 remote sprinklers
Coverage per sprinkler: 153 sq.ft. maximum
Type of sprinklers calculated: Residential Concealed Sidewall
No. of sprinklers calculated: 4
In rack demand: 0 gpm.
Hose streams: 100 gpm. outside + 0 gpm. inside
Total water required (including hose streams): 169.16 gpm at 34.74 psi [17.2 psi safety margin]
Type of system: wet pipe
Volume of dry or preaction system:

Water Supply Information

Date: 01-26-2024
Location: 3601 9th Street Southwest
Source: Fruitland Mutual Water Company


Contractor: Discount Fire Protection, LLC.
4 Red Bluff Court
Mansfield, TX. 76063

Name of designer: Timothy McBride
Authority having jurisdiction:

Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

Hydraulic Demand Graph



Water Source:
A) 52 psi Static
B) 200 gpm at 51.91 psi

Demand at Source:
C) 169.2 gpm at 34.74 psi

Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.94	169.16	34.74

Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	34.740	-169.161
M01	-4.000	ref	36.760	100.000
AT1	51.333	ref	18.305	0.000
AB1	44.000	ref	32.036	0.000
AP1	44.000	ref	47.607	0.000
AP5	44.000	ref	95.170	0.000
AT2	51.333	ref	25.112	0.000
AB2	44.000	ref	42.578	0.000
AP6	44.000	ref	95.625	0.000
AP7	44.000	ref	97.281	0.000
AP8	44.000	ref	107.595	0.000
AP9	40.667	ref	114.088	0.000
Z12	40.667	ref	114.589	0.000
Z13	20.333	ref	123.422	0.000
Z14	13.667	ref	126.318	0.000
ZP1	13.667	ref	126.485	0.000
TR2	13.667	ref	126.550	0.000
BR2	2.000	ref	131.655	0.000
BR1	2.000	ref	131.660	0.000
SOP	2.000	ref	29.814	0.000
BOR	2.000	ref	34.156	0.000
101	52.333	K=4.20	15.350	16.455
102	52.333	K=4.20	13.270	15.300
103	52.333	K=4.20	21.269	19.370
104	52.333	K=4.20	18.441	18.036

Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
101	52.333	4.2	q= 16.455 Q= -16.455	0.75	1PE=14.092 1PTS=2.013	1.167 16.105 17.272	C=150	Pt= 15.350 Pe= -0.433 Pf= -2.522	Mat="1-CPVC"
AT1	51.333								
AT1	51.333		q= 0.000 Q= -31.755	0.75	1PE=14.092	7.333 14.092	C=150	Pt= 18.305 Pe= -3.175	Mat="1-CPVC"
AB1	44.000					21.425	0.493	Pf=-10.556	
AB1	44.000		q= 0.000 Q= -31.755	0.75	1PE=14.092 1PTS=2.013	15.500 16.105	C=150	Pt= 32.036 Pe= 0.000	Mat="1-CPVC"
AP1	44.000					31.605	0.493	Pf=-15.571	
AP1	44.000		q= 0.000 Q= -69.161	0.75	1PTR=6.039	16.833 6.039	C=150	Pt= 47.607 Pe= 0.000	Mat="1-CPVC"
AP5	44.000					22.873	2.079	Pf=-47.563	
102	52.333	4.2	q= 15.300 Q= -15.300	0.75	2PE=28.184 1PTR=6.039	1.833 34.224	C=150	Pt= 13.270 Pe= -0.433	Mat="1-CPVC"
AT1	51.333					36.057	0.128	Pf= -4.601	
103	52.333	4.2	q= 19.370 Q= -19.370	0.75	1PE=14.092 1PTS=2.013	1.167 16.105	C=150	Pt= 21.269 Pe= -0.433	Mat="1-CPVC"
AT2	51.333					17.272	0.197	Pf= -3.410	
AT2	51.333		q= 0.000 Q= -37.405	0.75	1PE=14.092	7.333 14.092	C=150	Pt= 25.112 Pe= -3.175	Mat="1-CPVC"
AB2	44.000					21.425	0.667	Pf=-14.291	
AB2	44.000		q= 0.000 Q= -37.405	0.75	1PTR=6.039	1.500 6.039	C=150	Pt= 42.578 Pe= 0.000	Mat="1-CPVC"
AP1	44.000					7.539	0.667	Pf= -5.029	
104	52.333	4.2	q= 18.036 Q= -18.036	0.75	2PE=28.184 1PTR=6.039	1.833 34.224	C=150	Pt= 18.441 Pe= -0.433	Mat="1-CPVC"
AT2	51.333					36.057	0.173	Pf= -6.238	
AP5	44.000		q= 0.000 Q= -69.161	2		12.417 0.000	C=150	Pt= 95.170 Pe= 0.000	Mat="1-CPVC"
AP6	44.000					12.417	0.037	Pf= -0.455	
AP6	44.000		q= 0.000 Q= -69.161	2	1PTR=12.965	32.250 12.965	C=150	Pt= 95.625 Pe= 0.000	Mat="1-CPVC"
AP7	44.000					45.215	0.037	Pf= -1.657	
AP7	44.000		q= 0.000 Q= -69.161	2	1PE=14.261	267.250 14.261	C=150	Pt= 97.281 Pe= 0.000	Mat="1-CPVC"
AP8	44.000					281.511	0.037	Pf=-10.314	
AP8	44.000		q= 0.000 Q= -69.161	2	3E=18.294 1C=13.416	7.500 45.125	C=120	Pt=107.595 Pe= -1.443	Mat="1-WLML" Pdev=-3.0 psi
AP9	40.667					52.625	0.039	Pf= -2.050	
						1E=6.098			
AP9	40.667		q= 0.000 Q= -69.161	2	1T=12.196	0.667 12.196	C=120	Pt=114.088 Pe= 0.000	Mat="1-WLML"
Z12	40.667					12.863	0.039	Pf= -0.501	
Z12	40.667		q= 0.000 Q= -69.161	4		20.333 0.000	C=120	Pt=114.589 Pe= -8.804	Mat="1-WL10"
Z13	20.333					20.333	0.001	Pf= -0.029	

Pipe Information, cont.

Node 1 Node 2	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
Z13	20.333		q= 0.000 Q= -69.161	4 4.26		6.667 0.000		Pt=123.422 Pe= -2.887	Mat="1-WL10"
Z14	13.667					6.667	0.001	Pf= -0.009	
Z14	13.667		q= 0.000 Q= -69.161	4 4.26	2E=26.334 1B=15.800	50.750 68.469	C=120	Pt=126.318 Pe= 0.000	Mat="1-WL10"
ZP1	13.667				1T=26.334	119.219	0.001	Pf= -0.167	
ZP1	13.667		q= 0.000 Q= -69.161	4 4.26	1T=26.334	19.500 26.334	C=120	Pt=126.485 Pe= 0.000	Mat="1-WL10"
TR2	13.667					45.834	0.001	Pf= -0.064	
TR2	13.667		q= 0.000 Q= -69.161	4 4.26	1T=26.334	11.667 26.334	C=120	Pt=126.550 Pe= -5.052	Mat="1-WL10"
BR2	2.000					38.001	0.001	Pf= -0.053	
BR2	2.000		q= 0.000 Q= -69.161	3 3.26		1.000 0.000	C=120	Pt=131.655 Pe= 0.000	Mat="1-WL10"
BR1	2.000					1.000	0.005	Pf= -0.005	
BR1	2.000		q= 0.000 Q= -69.161	3 3.26	2G=2.688 1C=21.503	6.500 33.599	C=120	Pt=131.660 Pe= 0.000	Mat="1-WL10"
SOP	2.000				1E=9.408	40.099	0.005	Pf= -0.207	Pdev=102.05 psi
SOP	2.000		q= 0.000 Q= -69.161	3 3.26	1E=9.408	5.000 9.408	C=120	Pt= 29.814 Pe= 0.000	Mat="1-WL10"
BOR	2.000					14.408	0.005	Pf= -0.074	Pdev=-4.27 psi
BOR	2.000		q= 0.000 Q= -69.161	6 6.065	1E=14.000	10.000 14.000	C=120	Pt= 34.156 Pe= -2.598	Mat="S40"
M01	-4.000					24.000	0.000	Pf= -0.006	
M01	-4.000		q= 100.000 Q=-169.161	6 6.08	1G=4.588 1E=21.411	96.000 71.880	C=150	Pt= 36.760 Pe= 2.165	Mat="1-PVC"
CTY	1.000				1T=45.881	167.880	0.001	Pf= -0.144	

Material Codes

Pipe Material
 S40 - Schedule 40 Steel
 1-PVC - PVC C900 Underround Pipe
 1-CPVC - Blazemaster
 1-WL10 - Wheatland's schedule 10
 1-WLML - Wheatland's MLT

Fittings
 B - Butterfly Valve
 C - Check Valve
 E - Standard 90 degree elbow
 G - Gate Valve
 T - Tee - Flow turn 90 degrees
 PE - CPVC 90 degree elbow
 PTR - CPVC Tee - Flow turn 90 degree
 PTS - CPVC Tee - Flow straight thru path