

Hydraulic Calculations for

Project: Homewood Suites
3500 South Meridian
Puyallup, WA. 98373

Drawing no.: FS-9
Date: 3/3/2024

Design

Remote area number: Area 2
Remote area location: 5th Floor Corridor
Occupancy classification: Light Hazard
Density: 0.10 gpm./ft.2
Area of application: 5 remote sprinklers
Coverage per sprinkler: 130 sq.ft. maximum
Type of sprinklers calculated: Residential Concealed Sidewall
No. of sprinklers calculated: 5
In rack demand: 0 gpm.
Hose streams: 100 gpm. outside + 0 gpm. inside
Total water required (including hose streams): 166.49 gpm at -42.99 psi [94.92 psi safety margin]
Type of system: wet pipe
Volume of dry or preaction system:

Water Supply Information

Date: 01-26-2024
Location: 3601 9th Street Southwest
Source: Fruitland Mutual Water Company


Contractor: Discount Fire Protection, LLC.
4 Red Bluff Court
Mansfield, TX. 76063

Name of designer: Timothy McBride
Authority having jurisdiction:

Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

Hydraulic Demand Graph



Water Source:

A) 52 psi Static

B) 200 gpm at 51.91 psi

Demand at Source:

C) 166.5 gpm at -42.99 psi

Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.94	166.49	-42.99

Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	-42.986	-166.488
M01	-4.000	ref	-40.961	100.000
AT3	52.333	ref	10.942	0.000
AB3	44.000	ref	16.668	0.000
AP2	44.000	ref	18.115	0.000
AT4	52.333	ref	11.517	0.000
BT4	44.000	ref	17.346	0.000
AP3	44.000	ref	18.143	0.000
AT5	52.333	ref	11.081	0.000
BT5	44.000	ref	16.832	0.000
AP4	44.000	ref	18.241	0.000
AT6	52.333	ref	12.437	0.000
BT6	44.000	ref	17.575	0.000
AT7	52.333	ref	11.273	0.000
BT7	44.000	ref	17.058	0.000
AP5	44.000	ref	18.430	0.000
AP6	44.000	ref	18.740	0.000
AP7	44.000	ref	20.280	0.000
AP8	44.000	ref	29.869	0.000
AP9	40.667	ref	36.218	0.000
Z12	40.667	ref	36.683	0.000
Z13	20.333	ref	45.514	0.000
Z14	13.667	ref	48.410	0.000
ZP1	13.667	ref	48.564	0.000
TR2	13.667	ref	48.624	0.000
BR2	2.000	ref	53.725	0.000
BR1	2.000	ref	53.730	0.000
SOP	2.000	ref	-48.098	0.000
BOR	2.000	ref	-43.565	0.000
201	52.333	K=4.20	9.580	13.000
202	52.333	K=4.20	10.089	13.340
203	52.333	K=4.20	9.703	13.083
204	52.333	K=4.20	10.902	13.868
205	52.333	K=4.20	9.873	13.197

Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
201	52.333	4.2	q= 13.000 Q= -13.000	0.75 0.874	1PE=14.092	0.333 14.092 14.425	C=150	Pt= 9.580 Pe= 0.000 Pf= -1.362	Mat="1-CPVC"
AT3	52.333								
AT3	52.333		q= 0.000 Q= -13.000	0.75 0.874	1PE=14.092	8.333 14.092 22.425	C=150	Pt= 10.942 Pe= -3.608 Pf= -2.117	Mat="1-CPVC"
AB3	44.000								
AB3	44.000		q= 0.000 Q= -13.000	0.75 0.874	2PTR=12.079	3.250 12.079 15.329	C=150	Pt= 16.668 Pe= 0.000 Pf= -1.447	Mat="1-CPVC"
AP2	44.000								
202	52.333	4.2	q= 13.340 Q= -13.340	0.75 0.874	1PE=14.092	0.333 14.092 14.425	C=150	Pt= 10.089 Pe= 0.000 Pf= -1.429	Mat="1-CPVC"
AT4	52.333								
AT4	52.333		q= 0.000 Q= -13.340	0.75 0.874	1PE=14.092	8.333 14.092 22.425	C=150	Pt= 11.517 Pe= -3.608 Pf= -2.221	Mat="1-CPVC"
BT4	44.000								
BT4	44.000		q= 0.000 Q= -13.340	0.75 0.874	1PTR=6.039	2.000 6.039 8.039	C=150	Pt= 17.346 Pe= 0.000 Pf= -0.796	Mat="1-CPVC"
AP3	44.000								
203	52.333	4.2	q= 13.083 Q= -13.083	0.75 0.874	1PE=14.092	0.333 14.092 14.425	C=150	Pt= 9.703 Pe= 0.000 Pf= -1.378	Mat="1-CPVC"
AT5	52.333								
AT5	52.333		q= 0.000 Q= -13.083	0.75 0.874	1PE=14.092	8.333 14.092 22.425	C=150	Pt= 11.081 Pe= -3.608 Pf= -2.142	Mat="1-CPVC"
BT5	44.000								
BT5	44.000		q= 0.000 Q= -13.083	0.75 0.874	2PTR=12.079	2.667 12.079 14.746	C=150	Pt= 16.832 Pe= 0.000 Pf= -1.409	Mat="1-CPVC"
AP4	44.000								
204	52.333	4.2	q= 13.868 Q= -13.868	0.75 0.874	1PE=14.092	0.333 14.092 14.425	C=150	Pt= 10.902 Pe= 0.000 Pf= -1.535	Mat="1-CPVC"
AT6	52.333								
AT6	52.333		q= 0.000 Q= -13.868	0.75 0.874	1PTR=6.039	8.333 6.039 14.373	C=150	Pt= 12.437 Pe= -3.608 Pf= -1.529	Mat="1-CPVC"
BT6	44.000								
BT6	44.000		q= 0.000 Q= -13.868	0.75 0.874	1PTR=6.039	2.000 6.039 8.039	C=150	Pt= 17.575 Pe= 0.000 Pf= -0.855	Mat="1-CPVC"
AP5	44.000								
205	52.333	4.2	q= 13.197 Q= -13.197	0.75 0.874	1PE=14.092	0.333 14.092 14.425	C=150	Pt= 9.873 Pe= 0.000 Pf= -1.400	Mat="1-CPVC"
AT7	52.333								
AT7	52.333		q= 0.000 Q= -13.197	0.75 0.874	1PE=14.092	8.333 14.092 22.425	C=150	Pt= 11.273 Pe= -3.608 Pf= -2.177	Mat="1-CPVC"
BT7	44.000								
BT7	44.000		q= 0.000 Q= -13.197	0.75 0.874	2PTR=12.079	5.250 12.079 17.329	C=150	Pt= 17.058 Pe= 0.000 Pf= -1.682	Mat="1-CPVC"
AP6	44.000								

Pipe Information, cont.

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
AP2	44.000		q= 0.000 Q= -13.000	2 2.003	1PTS=1.296	15.250 1.296	C=150	Pt= 18.115 Pe= 0.000	Mat="1-CPVC"
AP3	44.000					16.546	0.002	Pf= -0.028	
AP3	44.000		q= 0.000 Q= -26.340	2 2.003	1PTS=1.296	14.667 1.296	C=150	Pt= 18.143 Pe= 0.000	Mat="1-CPVC"
AP4	44.000					15.963	0.006	Pf= -0.098	
AP4	44.000		q= 0.000 Q= -39.423	2 2.003	1PTS=1.296	13.333 1.296	C=150	Pt= 18.241 Pe= 0.000	Mat="1-CPVC"
AP5	44.000					14.630	0.013	Pf= -0.189	
AP5	44.000		q= 0.000 Q= -53.291	2 2.003	1PTS=1.296	12.417 1.296	C=150	Pt= 18.430 Pe= 0.000	Mat="1-CPVC"
AP6	44.000					13.713	0.023	Pf= -0.310	
AP6	44.000		q= 0.000 Q= -66.488	2 2.003	1PTR=12.965	32.250 12.965	C=150	Pt= 18.740 Pe= 0.000	Mat="1-CPVC"
AP7	44.000					45.215	0.034	Pf= -1.540	
AP7	44.000		q= 0.000 Q= -66.488	2 2.003	1PE=14.261	267.250 14.261	C=150	Pt= 20.280 Pe= 0.000	Mat="1-CPVC"
AP8	44.000					281.511	0.034	Pf= -9.589	
AP8	44.000		q= 0.000 Q= -66.488	2 2.153	3E=18.294 1C=13.416	7.500 45.125	C=120	Pt= 29.869 Pe= -1.443	Mat="1-WLML" Pdev=-3.0 psi
AP9	40.667					52.625	0.036	Pf= -1.905	
						1E=6.098			
AP9	40.667		q= 0.000 Q= -66.488	2 2.153	1T=12.196	0.667 12.196	C=120	Pt= 36.218 Pe= 0.000	Mat="1-WLML"
Z12	40.667					12.863	0.036	Pf= -0.466	
Z12	40.667		q= 0.000 Q= -66.488	4 4.26		20.333 0.000	C=120	Pt= 36.683 Pe= -8.804	Mat="1-WL10"
Z13	20.333					20.333	0.001	Pf= -0.027	
Z13	20.333		q= 0.000 Q= -66.488	4 4.26		6.667 0.000	C=120	Pt= 45.514 Pe= -2.887	Mat="1-WL10"
Z14	13.667					6.667	0.001	Pf= -0.009	
Z14	13.667		q= 0.000 Q= -66.488	4 4.26	2E=26.334 1B=15.800	50.167 68.469	C=120	Pt= 48.410 Pe= 0.000	Mat="1-WL10"
ZP1	13.667					118.635	0.001	Pf= -0.155	
ZP1	13.667		q= 0.000 Q= -66.488	4 4.26	1T=26.334	19.500 26.334	C=120	Pt= 48.564 Pe= 0.000	Mat="1-WL10"
TR2	13.667					45.834	0.001	Pf= -0.060	
TR2	13.667		q= 0.000 Q= -66.488	4 4.26	1T=26.334	11.667 26.334	C=120	Pt= 48.624 Pe= -5.052	Mat="1-WL10"
BR2	2.000					38.001	0.001	Pf= -0.050	
BR2	2.000		q= 0.000 Q= -66.488	3 3.26		1.000 0.000	C=120	Pt= 53.725 Pe= 0.000	Mat="1-WL10"
BR1	2.000					1.000	0.005	Pf= -0.005	
BR1	2.000		q= 0.000 Q= -66.488	3 3.26	2G=2.688 1C=21.503	6.500 33.599	C=120	Pt= 53.730 Pe= 0.000	Mat="1-WL10" Pdev=102.02 psi
SOP	2.000					40.099	0.005	Pf= -0.193	

Pipe Information, cont.

Node 1	Elev	Discharge & Flow	Nom i.d.	Fittings num & length	L [ft]	C factor	total elev (Pe)	Notes
Node 2	[ft]	[gpm]	[in]	[ft]	F [ft]	psi/ft	frict (Pf)	
SOP	2.000	Q= 0.000 Q= -66.488	3 3.26	1E=9.408	5.000 9.408		Pt=-48.098 Pe= 0.000	Mat="1-WL10" Pdev=-4.46 psi
BOR	2.000				14.408	0.005	Pf= -0.069	
BOR	2.000	Q= 0.000 Q= -66.488	6 6.065	1E=14.000	10.000 14.000		Pt=-43.565 Pe= -2.598	Mat="S40"
M01	-4.000				24.000	0.000	Pf= -0.006	
M01	-4.000	Q= 100.000 Q=-166.488	6 6.08	1G=4.588 1E=21.411	96.000 71.880		Pt=-40.961 Pe= 2.165	Mat="1-PVC"
CTY	1.000			1T=45.881	167.880	0.001	Pf= -0.140	

Material Codes

Pipe Material

S40 - Schedule 40 Steel
 1-PVC - PVC C900 Underround Pipe
 1-CPVC - Blazemaster
 1-WL10 - Wheatland's schedule 10
 1-WLML - Wheatland's MLT

Fittings

B - Butterfly Valve
 C - Check Valve
 E - Standard 90 degree elbow
 G - Gate Valve
 T - Tee - Flow turn 90 degrees
 PE - CPVC 90 degree elbow
 PTR - CPVC Tee - Flow turn 90 degree
 PTS - CPVC Tee - Flow straight thru path