

Hydraulic Calculations for

Project: Homewood Suites
3500 South Meridian
Puyallup, WA. 98373

Drawing no.: FS-4
Date: 3/3/2024

Design

Remote area number: Area 6
Remote area location: 1st Floor Remote
Occupancy classification: Light Hazard
Density: 0.10 gpm./ft.2
Area of application: 950 sq.ft.
Coverage per sprinkler: 148 sq.ft. maximum
Type of sprinklers calculated: Concealed Pendent
No. of sprinklers calculated: 9
In rack demand: 0 gpm.
Hose streams: 100 gpm. outside + 0 gpm. inside
Total water required (including hose streams): 262.29 gpm at -25.16 psi [77.02 psi safety margin]
Type of system: wet pipe
Volume of dry or preaction system:

Water Supply Information

Date: 01-26-2024
Location: 3601 9th Street Southwest
Source: Fruitland Mutual Water Company


Contractor: Discount Fire Protection, LLC.
4 Red Bluff Court
Mansfield, TX. 76063

Name of designer: Timothy McBride
Authority having jurisdiction:

Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

Hydraulic Demand Graph



Water Source:
A) 52 psi Static
B) 400 gpm at 51.69 psi

Demand at Source:
C) 262.3 gpm at -25.16 psi

Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.86	262.29	-25.16

Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	-25.160	-262.287
F01	13.000	ref	12.065	0.000
F02	13.000	ref	12.798	0.000
FP1	13.000	ref	17.537	0.000
F03	13.000	ref	9.963	0.000
F04	13.000	ref	10.596	0.000
FP2	13.000	ref	12.846	0.000
FP3	13.000	ref	17.708	0.000
F05	13.000	ref	12.112	0.000
F06	13.000	ref	5.982	0.000
F07	13.000	ref	6.430	0.000
F08	13.000	ref	8.102	0.000
FP4	13.000	ref	11.936	0.000
FP5	13.000	ref	18.731	0.000
F09	13.000	ref	11.157	0.000
GP2	13.000	ref	35.475	0.000
GP3	13.000	ref	37.768	0.000
GP6	13.000	ref	39.188	0.000
GP8	13.000	ref	41.673	0.000
HP5	13.000	ref	43.049	0.000
HP6	13.000	ref	47.501	0.000
TR1	13.000	ref	53.412	0.000
BR1	2.000	ref	71.954	0.000
SOP	2.000	ref	-28.308	0.000
BOR	2.000	ref	-25.947	0.000
M01	-4.000	ref	-23.320	100.000
601	8.500	K=5.60	12.793	20.030
602	8.500	K=5.60	13.723	20.745
603	12.167	K=5.60	9.771	17.505
604	12.167	K=5.60	10.373	18.036
605	9.750	K=5.60	12.415	19.732
606	9.000	K=5.60	7.032	14.850
607	9.000	K=5.60	7.591	15.429
608	9.000	K=5.60	9.155	16.944
609	9.750	K=5.60	11.533	19.017

Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
601	8.500	5.6	q= 20.030 Q= -20.030	1 1.101	1PE=13.388	4.500 13.388 17.888	C=150	Pt= 12.793 Pe= 1.948 Pf= -1.220	Mat="1-CPVC"
F01	13.000								
F01	13.000		q= 0.000 Q= -20.030	1 1.101	1PTS=1.913	8.833 1.913 10.746	C=150	Pt= 12.065 Pe= 0.000 Pf= -0.733	Mat="1-CPVC"
F02	13.000								
F02	13.000		q= 0.000 Q= -40.774	1 1.101	1PTR=9.563	9.083 9.563 18.646	C=150	Pt= 12.798 Pe= 0.000 Pf= -4.739	Mat="1-CPVC"
FP1	13.000								
602	8.500	5.6	q= 20.745 Q= -20.745	1 1.101	1PTR=9.563	4.500 9.563 14.063	C=150	Pt= 13.723 Pe= 1.948 Pf= -1.024	Mat="1-CPVC"
F02	13.000								
603	12.167	5.6	q= 17.505 Q= -17.505	1 1.101	1PTR=9.563	0.833 9.563 10.396	C=150	Pt= 9.771 Pe= 0.361 Pf= -0.553	Mat="1-CPVC"
F03	13.000								
F03	13.000		q= 0.000 Q= -17.505	1 1.101	1PTS=1.913	10.000 1.913 11.913	C=150	Pt= 9.963 Pe= 0.000 Pf= -0.633	Mat="1-CPVC"
F04	13.000								
F04	13.000		q= 0.000 Q= -35.541	1 1.101	1PTS=1.913	9.500 1.913 11.413	C=150	Pt= 10.596 Pe= 0.000 Pf= -2.250	Mat="1-CPVC"
FP2	13.000								
FP2	13.000		q= 0.000 Q= -55.272	1 1.101	1PTR=9.563	1.333 9.563 10.896	C=150	Pt= 12.846 Pe= 0.000 Pf= -4.862	Mat="1-CPVC"
FP3	13.000								
604	12.167	5.6	q= 18.036 Q= -18.036	1 1.101	1PTR=9.563	0.833 9.563 10.396	C=150	Pt= 10.373 Pe= 0.361 Pf= -0.584	Mat="1-CPVC"
F04	13.000								
605	9.750	5.6	q= 19.732 Q= -19.732	1 1.101	1PE=13.388	3.250 13.388 16.638	C=150	Pt= 12.415 Pe= 1.407 Pf= -1.104	Mat="1-CPVC"
F05	13.000								
F05	13.000		q= 0.000 Q= -19.732	1 1.101	1PTR=9.563	1.500 9.563 11.063	C=150	Pt= 12.112 Pe= 0.000 Pf= -0.734	Mat="1-CPVC"
FP2	13.000								
606	9.000	5.6	q= 14.850 Q= -14.850	1 1.101	1PE=13.388	4.000 13.388 17.388	C=150	Pt= 7.032 Pe= 1.732 Pf= -0.682	Mat="1-CPVC"
F06	13.000								
F06	13.000		q= 0.000 Q= -14.850	1 1.101	1PTS=1.913	9.500 1.913 11.413	C=150	Pt= 5.982 Pe= 0.000 Pf= -0.448	Mat="1-CPVC"
F07	13.000								
F07	13.000		q= 0.000 Q= -30.279	1 1.101	1PTS=1.913	9.500 1.913 11.413	C=150	Pt= 6.430 Pe= 0.000 Pf= -1.672	Mat="1-CPVC"
F08	13.000								
F08	13.000		q= 0.000 Q= -47.223	1 1.101	1PTS=1.913	9.583 1.913 11.496	C=150	Pt= 8.102 Pe= 0.000 Pf= -3.833	Mat="1-CPVC"
FP4	13.000								

Pipe Information, cont.

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
FP4	13.000		q= 0.000 Q= -66.240	1 1.101	1PTR=9.563	1.333 9.563	C=150	Pt= 11.936 Pe= 0.000	Mat="1-CPVC"
FP5	13.000					10.896	0.624	Pf= -6.795	
607	9.000	5.6	q= 15.429 Q= -15.429	1 1.101	1PTR=9.563	4.000 9.563	C=150	Pt= 7.591 Pe= 1.732	Mat="1-CPVC"
F07	13.000					13.563	0.042	Pf= -0.571	
608	9.000	5.6	q= 16.944 Q= -16.944	1 1.101	1PTR=9.563	4.000 9.563	C=150	Pt= 9.155 Pe= 1.732	Mat="1-CPVC"
F08	13.000					13.563	0.05	Pf= -0.679	
609	9.750	5.6	q= 19.017 Q= -19.017	1 1.101	1PE=13.388	3.250 13.388	C=150	Pt= 11.533 Pe= 1.407	Mat="1-CPVC"
F09	13.000					16.638	0.062	Pf= -1.031	
F09	13.000		q= 0.000 Q= -19.017	1 1.101	1PTR=9.563	3.000 9.563	C=150	Pt= 11.157 Pe= 0.000	Mat="1-CPVC"
FP4	13.000					12.563	0.062	Pf= -0.779	
FP1	13.000		q= 0.000 Q= -40.774	2 2.003	1PTS=1.296	11.083 1.296	C=150	Pt= 17.537 Pe= 0.000	Mat="1-CPVC"
FP3	13.000					12.380	0.014	Pf= -0.171	
FP3	13.000		q= 0.000 Q= -96.047	2 2.003	1PTS=1.296	13.917 1.296	C=150	Pt= 17.708 Pe= 0.000	Mat="1-CPVC"
FP5	13.000					15.213	0.067	Pf= -1.023	
FP5	13.000		q= 0.000 Q=-162.287	2 2.003		94.333 0.000	C=150	Pt= 18.731 Pe= 0.000	Mat="1-CPVC"
GP2	13.000					94.333	0.178	Pf=-16.745	
GP2	13.000		q= 0.000 Q=-162.287	2 2.003		12.917 0.000	C=150	Pt= 35.475 Pe= 0.000	Mat="1-CPVC"
GP3	13.000					12.917	0.178	Pf= -2.293	
GP3	13.000		q= 0.000 Q=-162.287	2 2.003		8.000 0.000	C=150	Pt= 37.768 Pe= 0.000	Mat="1-CPVC"
GP6	13.000					8.000	0.178	Pf= -1.420	
GP6	13.000		q= 0.000 Q=-162.287	2 2.003		14.000 0.000	C=150	Pt= 39.188 Pe= 0.000	Mat="1-CPVC"
GP8	13.000					14.000	0.178	Pf= -2.485	
GP8	13.000		q= 0.000 Q=-162.287	2 2.003		7.750 0.000	C=150	Pt= 41.673 Pe= 0.000	Mat="1-CPVC"
HP5	13.000					7.750	0.178	Pf= -1.376	
HP5	13.000		q= 0.000 Q=-162.287	2 2.003		25.083 0.000	C=150	Pt= 43.049 Pe= 0.000	Mat="1-CPVC"
HP6	13.000					25.083	0.178	Pf= -4.452	
HP6	13.000		q= 0.000 Q=-162.287	2 2.003	1PTR=12.965	20.333 12.965	C=150	Pt= 47.501 Pe= 0.000	Mat="1-CPVC"
TR1	13.000					33.298	0.178	Pf= -5.911	
TR1	13.000		q= 0.000 Q=-162.287	2 2.153	1C=13.416 1B=7.318	12.000 45.125	C=120	Pt= 53.412 Pe= -4.763	Mat="1-WLML" Pdev=-3.0 psi
BR1	2.000				2T=24.392	57.125	0.189	Pf=-10.779	

Pipe Information, cont.

Node 1	Elev	Discharge & Flow	Nom i.d.	Fittings num & length	L [ft]	C factor	total elev (Pe)	Notes
Node 2	[ft]	K-factor [gpm]	[in]	[ft]	F [ft]	psi/ft	frict (Pf)	
BR1	2.000	q= 0.000 Q=-162.287	3 3.26	2G=2.688 1C=21.503	6.500 33.599		Pt= 71.954 Pe= 0.000	Mat="1-WL10" Pdev=101.26 psi
SOP	2.000			1E=9.408	40.099	0.025	Pf= -1.003	
SOP	2.000	q= 0.000 Q=-162.287	3 3.26	1E=9.408	5.000 9.408		Pt=-28.308 Pe= 0.000	Mat="1-WL10" Pdev=-2.0 psi
BOR	2.000				14.408	0.025	Pf= -0.360	
BOR	2.000	q= 0.000 Q=-162.287	6 6.065	1E=14.000	10.000 14.000		Pt=-25.947 Pe= -2.598	Mat="S40"
M01	-4.000				24.000	0.001	Pf= -0.029	
M01	-4.000	q= 100.000 Q=-262.287	6 6.08	1G=4.588 1E=21.411	96.000 71.880		Pt=-23.320 Pe= 2.165	Mat="1-PVC"
CTY	1.000			1T=45.881	167.880	0.002	Pf= -0.325	

Material Codes

Pipe Material

- S40 - Schedule 40 Steel
- 1-PVC - PVC C900 Underround Pipe
- 1-CPVC - Blazemaster
- 1-WL10 - Wheatland's schedule 10
- 1-WLML - Wheatland's MLT

Fittings

- B - Butterfly Valve
- C - Check Valve
- E - Standard 90 degree elbow
- G - Gate Valve
- T - Tee - Flow turn 90 degrees
- PE - CPVC 90 degree elbow
- PTR - CPVC Tee - Flow turn 90 degree
- PTS - CPVC Tee - Flow straight thru path