

Hydraulic Calculations for

Project: Homewood Suites
3500 South Meridian
Puyallup, WA. 98373

Drawing no.: FS-4
Date: 3/3/2024

Design

Remote area number: Area 7
Remote area location: 1st Floor Laundry
Occupancy classification: ordinary hazard group I
Density: 0.15 gpm./ft.2
Area of application: 950 sq.ft.
Coverage per sprinkler: 130 sq.ft. maximum
Type of sprinklers calculated: Concealed Pendent
No. of sprinklers calculated: 11
In rack demand: 0 gpm.
Hose streams: 250 gpm. outside + 0 gpm. inside
Total water required (including hose streams): 462.87 gpm at -24.44 psi [76.03 psi safety margin]
Type of system: wet pipe
Volume of dry or preaction system:

Water Supply Information

Date: 01-26-2024
Location: 3601 9th Street Southwest
Source: Fruitland Mutual Water Company


Contractor: Discount Fire Protection, LLC.
4 Red Bluff Court
Mansfield, TX. 76063

Name of designer: Timothy McBride
Authority having jurisdiction:

Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

Hydraulic Demand Graph



Water Source:
A) 52 psi Static
B) 754 gpm at 51 psi
C) 800 gpm at 50.88 psi

Demand at Source:
D) 462.9 gpm at -24.44 psi

(D)



Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.59	462.87	-24.44

Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	-24.437	-462.870
G01	13.000	ref	9.299	0.000
G02	13.000	ref	10.296	0.000
GP1	13.000	ref	12.217	0.000
GP2	13.000	ref	21.054	0.000
G03	13.000	ref	11.596	0.000
G04	13.000	ref	14.705	0.000
G05	13.000	ref	15.631	0.000
GP3	13.000	ref	21.382	0.000
G06	13.000	ref	10.147	0.000
GP4	13.000	ref	10.598	0.000
GP5	13.000	ref	13.022	0.000
GP6	13.000	ref	22.028	0.000
G07	13.000	ref	9.950	0.000
G08	13.000	ref	12.126	0.000
G09	13.000	ref	11.661	0.000
G10	13.000	ref	12.137	0.000
GP7	13.000	ref	14.412	0.000
GP8	13.000	ref	24.480	0.000
G11	13.000	ref	13.572	0.000
HP5	13.000	ref	26.752	0.000
HP6	13.000	ref	34.107	0.000
TR1	13.000	ref	43.871	0.000
BR1	2.000	ref	69.440	0.000
SOP	2.000	ref	-28.571	0.000
BOR	2.000	ref	-25.847	0.000
M01	-4.000	ref	-23.200	250.000
701	12.167	K=5.60	8.962	16.764
702	10.000	K=5.60	10.858	18.453
703	12.000	K=5.60	11.164	18.711
704	10.000	K=5.60	14.730	21.493
705	10.000	K=5.60	15.883	22.318
706	10.000	K=5.60	10.514	18.158
707	10.000	K=5.60	10.332	18.000
708	10.000	K=5.60	12.344	19.675
709	12.167	K=5.60	11.166	18.713
710	10.000	K=5.60	12.592	19.871
711	10.000	K=5.60	13.682	20.714

Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
701	12.167	5.6	q= 16.764 Q= -16.764	1 1.101	1PE=13.388	0.833 13.388	C=150	Pt= 8.962 Pe= 0.361	Mat="1-CPVC"
G01	13.000					14.221	0.049	Pf= -0.698	
G01	13.000		q= 0.000 Q= -16.764	1 1.101	1PE=13.388 1PTS=1.913	5.000 15.300	C=150	Pt= 9.299 Pe= 0.000	Mat="1-CPVC"
G02	13.000					20.300	0.049	Pf= -0.997	
G02	13.000		q= 0.000 Q= -35.217	1 1.101	1PTS=1.913	8.000 1.913	C=150	Pt= 10.296 Pe= 0.000	Mat="1-CPVC"
GP1	13.000					9.913	0.194	Pf= -1.921	
GP1	13.000		q= 0.000 Q= -53.928	1 1.101	1PTR=9.563	11.167 9.563	C=150	Pt= 12.217 Pe= 0.000	Mat="1-CPVC"
GP2	13.000					20.729	0.426	Pf= -8.837	
702	10.000	5.6	q= 18.453 Q= -18.453	1 1.101	1PTR=9.563	3.000 9.563	C=150	Pt= 10.858 Pe= 1.299	Mat="1-CPVC"
G02	13.000					12.563	0.059	Pf= -0.736	
703	12.000	5.6	q= 18.711 Q= -18.711	1 1.101	1PE=13.388	1.000 13.388	C=150	Pt= 11.164 Pe= 0.433	Mat="1-CPVC"
G03	13.000					14.388	0.06	Pf= -0.865	
G03	13.000		q= 0.000 Q= -18.711	1 1.101	1PTR=9.563	0.750 9.563	C=150	Pt= 11.596 Pe= 0.000	Mat="1-CPVC"
GP1	13.000					10.313	0.06	Pf= -0.620	
704	10.000	5.6	q= 21.493 Q= -21.493	1 1.101	1PE=13.388	3.000 13.388	C=150	Pt= 14.730 Pe= 1.299	Mat="1-CPVC"
G04	13.000					16.388	0.078	Pf= -1.274	
G04	13.000		q= 0.000 Q= -21.493	1 1.101	1PTS=1.913	10.000 1.913	C=150	Pt= 14.705 Pe= 0.000	Mat="1-CPVC"
G05	13.000					11.913	0.078	Pf= -0.926	
G05	13.000		q= 0.000 Q= -43.811	1 1.101	1PTR=9.563	10.250 9.563	C=150	Pt= 15.631 Pe= 0.000	Mat="1-CPVC"
GP3	13.000					19.813	0.29	Pf= -5.751	
705	10.000	5.6	q= 22.318 Q= -22.318	1 1.101	1PTR=9.563	3.000 9.563	C=150	Pt= 15.883 Pe= 1.299	Mat="1-CPVC"
G05	13.000					12.563	0.083	Pf= -1.047	
706	10.000	5.6	q= 18.158 Q= -18.158	1 1.101	1PE=13.388	3.000 13.388	C=150	Pt= 10.514 Pe= 1.299	Mat="1-CPVC"
G06	13.000					16.388	0.057	Pf= -0.933	
G06	13.000		q= 0.000 Q= -18.158	1 1.101	1PTS=1.913	6.000 1.913	C=150	Pt= 10.147 Pe= 0.000	Mat="1-CPVC"
GP4	13.000					7.913	0.057	Pf= -0.450	
GP4	13.000		q= 0.000 Q= -36.158	1 1.101	1PTS=1.913	10.000 1.913	C=150	Pt= 10.598 Pe= 0.000	Mat="1-CPVC"
GP5	13.000					11.913	0.203	Pf= -2.424	
GP5	13.000		q= 0.000 Q= -55.833	1 1.101	1PTR=9.563	10.250 9.563	C=150	Pt= 13.022 Pe= 0.000	Mat="1-CPVC"
GP6	13.000					19.813	0.455	Pf= -9.006	

Pipe Information, cont.

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
707	10.000	5.6	q= 18.000 Q= -18.000	1 1.101	1PE=13.388	3.000 13.388	C=150	Pt= 10.332 Pe= 1.299	Mat= "1-CPVC"
G07	13.000					16.388	0.056	Pf= -0.918	
G07	13.000		q= 0.000 Q= -18.000	1 1.101	1PTR=9.563	2.000 9.563	C=150	Pt= 9.950 Pe= 0.000	Mat= "1-CPVC"
GP4	13.000					11.563	0.056	Pf= -0.647	
708	10.000	5.6	q= 19.675 Q= -19.675	1 1.101	1PE=13.388	3.000 13.388	C=150	Pt= 12.344 Pe= 1.299	Mat= "1-CPVC"
G08	13.000					16.388	0.066	Pf= -1.082	
G08	13.000		q= 0.000 Q= -19.675	1 1.101	1PTR=9.563	4.000 9.563	C=150	Pt= 12.126 Pe= 0.000	Mat= "1-CPVC"
GP5	13.000					13.563	0.066	Pf= -0.895	
709	12.167	5.6	q= 18.713 Q= -18.713	1 1.101	1PE=13.388	0.833 13.388	C=150	Pt= 11.166 Pe= 0.361	Mat= "1-CPVC"
G09	13.000					14.221	0.06	Pf= -0.856	
G09	13.000		q= 0.000 Q= -18.713	1 1.101	1PTS=1.913	6.000 1.913	C=150	Pt= 11.661 Pe= 0.000	Mat= "1-CPVC"
G10	13.000					7.913	0.06	Pf= -0.476	
G10	13.000		q= 0.000 Q= -38.584	1 1.101	1PTS=1.913	8.000 1.913	C=150	Pt= 12.137 Pe= 0.000	Mat= "1-CPVC"
GP7	13.000					9.913	0.229	Pf= -2.275	
GP7	13.000		q= 0.000 Q= -59.298	1 1.101	1PTR=9.563	10.250 9.563	C=150	Pt= 14.412 Pe= 0.000	Mat= "1-CPVC"
GP8	13.000					19.813	0.508	Pf= -10.068	
710	10.000	5.6	q= 19.871 Q= -19.871	1 1.101	1PTR=9.563	3.000 9.563	C=150	Pt= 12.592 Pe= 1.299	Mat= "1-CPVC"
G10	13.000					12.563	0.067	Pf= -0.845	
711	10.000	5.6	q= 20.714 Q= -20.714	1 1.101	1PE=13.388	3.000 13.388	C=150	Pt= 13.682 Pe= 1.299	Mat= "1-CPVC"
G11	13.000					16.388	0.073	Pf= -1.190	
G11	13.000		q= 0.000 Q= -20.714	1 1.101	1PTR=9.563	2.000 9.563	C=150	Pt= 13.572 Pe= 0.000	Mat= "1-CPVC"
GP7	13.000					11.563	0.073	Pf= -0.839	
GP2	13.000		q= 0.000 Q= -53.928	2 2.003	1PTS=1.296	12.917 1.296	C=150	Pt= 21.054 Pe= 0.000	Mat= "1-CPVC"
GP3	13.000					14.213	0.023	Pf= -0.329	
GP3	13.000		q= 0.000 Q= -97.739	2 2.003	1PTS=1.296	8.000 1.296	C=150	Pt= 21.382 Pe= 0.000	Mat= "1-CPVC"
GP6	13.000					9.296	0.069	Pf= -0.646	
GP6	13.000		q= 0.000 Q= -153.572	2 2.003	1PTS=1.296	14.000 1.296	C=150	Pt= 22.028 Pe= 0.000	Mat= "1-CPVC"
GP8	13.000					15.296	0.16	Pf= -2.452	
GP8	13.000		q= 0.000 Q= -212.870	2 2.003		7.750 0.000	C=150	Pt= 24.480 Pe= 0.000	Mat= "1-CPVC"
HP5	13.000					7.750	0.293	Pf= -2.272	

Pipe Information, cont.

Node 1	Elev	Discharge & Flow	Nom i.d.	Fittings num & length	L [ft]	C factor	total (Pt) elev (Pe)	Notes
Node 2	[ft]	[gpm]	[in]	[ft]	F [ft] T [ft]	psi/ft	frict (Pf)	
HP5	13.000	q= 0.000 Q=-212.870	2 2.003		25.083 0.000		Pt= 26.752 Pe= 0.000	Mat="1-CPVC"
HP6	13.000				25.083	0.293	Pf= -7.355	
HP6	13.000	q= 0.000 Q=-212.870	2 2.003	1PTR=12.965	20.333 12.965		Pt= 34.107 Pe= 0.000	Mat="1-CPVC"
TR1	13.000				33.298	0.293	Pf= -9.764	
TR1	13.000	q= 0.000 Q=-212.870	2 2.153	1C=13.416 1B=7.318	12.000 45.125		Pt= 43.871 Pe= -4.763	Mat="1-WLML" Pdev=-3.0 psi
BR1	2.000			2T=24.392	57.125	0.312	Pf=-17.806	
BR1	2.000	q= 0.000 Q=-212.870	3 3.26	2G=2.688 1C=21.503	6.500 33.599		Pt= 69.440 Pe= 0.000	Mat="1-WL10" Pdev=99.67 psi
SOP	2.000			1E=9.408	40.099	0.041	Pf= -1.657	
SOP	2.000	q= 0.000 Q=-212.870	3 3.26		5.000 9.408		Pt=-28.571 Pe= 0.000	Mat="1-WL10" Pdev=-2.13 psi
BOR	2.000				14.408	0.041	Pf= -0.596	
BOR	2.000	q= 0.000 Q=-212.870	6 6.065	1E=14.000	10.000 14.000		Pt=-25.847 Pe= -2.598	Mat="S40"
M01	-4.000				24.000	0.002	Pf= -0.048	
M01	-4.000	q= 250.000 Q=-462.870	6 6.08	1G=4.588 1E=21.411	96.000 71.880		Pt=-23.200 Pe= 2.165	Mat="1-PVC"
CTY	1.000			1T=45.881	167.880	0.006	Pf= -0.929	

Material Codes

- | | |
|--|---|
| <p><u>Pipe Material</u></p> <ul style="list-style-type: none"> S40 - Schedule 40 Steel 1-PVC - PVC C900 Underround Pipe 1-CPVC - Blazemaster 1-WL10 - Wheatland's schedule 10 1-WLML - Wheatland's MLT | <p><u>Fittings</u></p> <ul style="list-style-type: none"> B - Butterfly Valve C - Check Valve E - Standard 90 degree elbow G - Gate Valve T - Tee - Flow turn 90 degrees PE - CPVC 90 degree elbow PTR - CPVC Tee - Flow turn 90 degree PTS - CPVC Tee - Flow straight thru path |
|--|---|