

# Hydraulic Calculations for

**Project:** Homewood Suites  
5233 Katella Avenue  
Cypress, CA. 90630

**Drawing no.:** FS-4  
**Date:** 3/3/2024

## Design

**Remote area number:** Area 8  
**Remote area location:** 1st Floor Pool  
**Occupancy classification:** light hazard  
**Density:** 0.10 gpm./ft.2  
**Area of application:** 900 sq.ft.  
**Coverage per sprinkler:** 156 sq.ft. maximum  
**Type of sprinklers calculated:** Concealed Pendent  
**No. of sprinklers calculated:** 7  
**In rack demand:** 0 gpm.  
**Hose streams:** 100 gpm. outside + 0 gpm. inside  
**Total water required (including hose streams):** 224.6 gpm at -49.02 psi [ 100.91 psi safety margin ]  
**Type of system:** wet pipe  
**Volume of dry or preaction system:**

## Water Supply Information

**Date:** 01-26-2024  
**Location:** 3601 9th Street Southwest  
**Source:** Fruitland Mutual Water Company


**Contractor:** Discount Fire Protection, LLC.  
4 Red Bluff Court  
Mansfield, TX. 76063

**Name of designer:** Timothy McBride  
**Authority having jurisdiction:**

## Notes

Pdev at node BOR to SOP - 3" AMEs 3000SS Backflow Preventer

### Hydraulic Demand Graph



Water Source:  
A) 52 psi Static  
B) 400 gpm at 51.69 psi

Demand at Source:  
C) 224.6 gpm at -49.02 psi

## Supply Analysis

Node at	Static Pressure [psi]	Residual Pressure [psi]	Flow [gpm]	Available Pressure [psi]	Total Demand [gpm]	Required Pressure [psi]
CTY	52.0	51.0	754.0	51.89	224.6	-49.02

## Node Analysis

Node Tag	Elev [ft]	Type	Pressure [psi]	Discharge [gpm]
CTY	1.000	source	-49.015	-224.597
H01	13.000	ref	6.905	0.000
H02	13.000	ref	7.546	0.000
H03	13.000	ref	9.958	0.000
HP1	13.000	ref	18.797	0.000
H04	13.000	ref	7.083	0.000
H05	13.000	ref	7.736	0.000
H06	13.000	ref	10.171	0.000
HP2	13.000	ref	19.067	0.000
H07	13.000	ref	17.839	0.000
HP3	13.000	ref	20.046	0.000
HP4	13.000	ref	22.332	0.000
HP5	13.000	ref	28.565	0.000
HP6	13.000	ref	31.296	0.000
TR1	13.000	ref	34.921	0.000
BR1	2.000	ref	49.295	0.000
SOP	2.000	ref	-51.931	0.000
BOR	2.000	ref	-49.710	0.000
M01	-4.000	ref	-47.094	100.000
801	9.333	K=5.60	7.760	15.600
802	9.333	K=5.60	8.514	16.340
803	9.333	K=5.60	10.776	18.383
804	9.333	K=5.60	7.923	15.763
805	9.833	K=5.60	8.511	16.337
806	9.833	K=5.60	10.799	18.403
807	9.833	K=5.60	18.018	23.771

## Pipe Information

negative pipe flow (Q) indicates flow is from node 2 towards node 1

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
801	9.333	5.6	Q= 15.600	1	1PE=13.388	3.667		Pt= 7.760	Mat="1-CPVC"
H01	13.000		Q= -15.600	1.101		13.388	C=150	Pe= 1.588	
						17.054	0.043	Pf= -0.733	
H01	13.000		Q= 0.000	1	1PTS=1.913	13.000		Pt= 6.905	Mat="1-CPVC"
			Q= -15.600	1.101		1.913	C=150	Pe= 0.000	
H02	13.000					14.913	0.043	Pf= -0.641	
H02	13.000		Q= 0.000	1	1PTS=1.913	13.000		Pt= 7.546	Mat="1-CPVC"
			Q= -31.940	1.101		1.913	C=150	Pe= 0.000	
H03	13.000					14.913	0.162	Pf= -2.412	
H03	13.000		Q= 0.000	1	1PTR=9.563	14.000		Pt= 9.958	Mat="1-CPVC"
			Q= -50.323	1.101		9.563	C=150	Pe= 0.000	
HP1	13.000					23.563	0.375	Pf= -8.838	
802	9.333	5.6	Q= 16.340	1	1PTR=9.563	3.667		Pt= 8.514	Mat="1-CPVC"
			Q= -16.340	1.101		9.563	C=150	Pe= 1.588	
H02	13.000					13.229	0.047	Pf= -0.619	
803	9.333	5.6	Q= 18.383	1	1PTR=9.563	3.667		Pt= 10.776	Mat="1-CPVC"
			Q= -18.383	1.101		9.563	C=150	Pe= 1.588	
H03	13.000					13.229	0.058	Pf= -0.770	
804	9.333	5.6	Q= 15.763	1	1PE=13.388	3.667		Pt= 7.923	Mat="1-CPVC"
			Q= -15.763	1.101		13.388	C=150	Pe= 1.588	
H04	13.000					17.054	0.044	Pf= -0.747	
H04	13.000		Q= 0.000	1	1PTS=1.913	13.000		Pt= 7.083	Mat="1-CPVC"
			Q= -15.763	1.101		1.913	C=150	Pe= 0.000	
H05	13.000					14.913	0.044	Pf= -0.653	
H05	13.000		Q= 0.000	1	1PTS=1.913	13.000		Pt= 7.736	Mat="1-CPVC"
			Q= -32.100	1.101		1.913	C=150	Pe= 0.000	
H06	13.000					14.913	0.163	Pf= -2.435	
H06	13.000		Q= 0.000	1	1PTR=9.563	14.000		Pt= 10.171	Mat="1-CPVC"
			Q= -50.503	1.101		9.563	C=150	Pe= 0.000	
HP2	13.000					23.563	0.378	Pf= -8.897	
805	9.833	5.6	Q= 16.337	1	1PTR=9.563	3.167		Pt= 8.511	Mat="1-CPVC"
			Q= -16.337	1.101		9.563	C=150	Pe= 1.371	
H05	13.000					12.729	0.047	Pf= -0.596	
806	9.833	5.6	Q= 18.403	1	1PTR=9.563	3.167		Pt= 10.799	Mat="1-CPVC"
			Q= -18.403	1.101		9.563	C=150	Pe= 1.371	
H06	13.000					12.729	0.058	Pf= -0.743	
807	9.833	5.6	Q= 23.771	1	1PTR=9.563	3.167		Pt= 18.018	Mat="1-CPVC"
			Q= -23.771	1.101		9.563	C=150	Pe= 1.371	
H07	13.000					12.729	0.094	Pf= -1.192	
H07	13.000		Q= 0.000	1	1PTR=9.563	14.000		Pt= 17.839	Mat="1-CPVC"
			Q= -23.771	1.101		9.563	C=150	Pe= 0.000	
HP3	13.000					23.563	0.094	Pf= -2.207	
HP1	13.000		Q= 0.000	2	1PTS=1.296	12.000		Pt= 18.797	Mat="1-CPVC"
			Q= -50.323	2.003		1.296	C=150	Pe= 0.000	
HP2	13.000					13.296	0.02	Pf= -0.271	

Pipe Information, cont.

Node 1	Elev [ft]	K-factor	Discharge & Flow [gpm]	Nom i.d. [in]	Fittings num & length [ft]	L [ft] F [ft] T [ft]	C factor psi/ft	total (Pt) elev (Pe) frict (Pf)	Notes
HP2	13.000		q= 0.000 Q=-100.827	2 2.003	1PTS=1.296	12.000 1.296	C=150	Pt= 19.067 Pe= 0.000	Mat="1-CPVC"
HP3	13.000					13.296	0.074	Pf= -0.978	
HP3	13.000		q= 0.000 Q=-124.597	2 2.003		21.000 0.000	C=150	Pt= 20.046 Pe= 0.000	Mat="1-CPVC"
HP4	13.000					21.000	0.109	Pf= -2.286	
HP4	13.000		q= 0.000 Q=-124.597	2 2.003	2PTR=25.929	31.333 25.929	C=150	Pt= 22.332 Pe= 0.000	Mat="1-CPVC"
HP5	13.000					57.263	0.109	Pf= -6.234	
HP5	13.000		q= 0.000 Q=-124.597	2 2.003		25.083 0.000	C=150	Pt= 28.565 Pe= 0.000	Mat="1-CPVC"
HP6	13.000					25.083	0.109	Pf= -2.731	
HP6	13.000		q= 0.000 Q=-124.597	2 2.003	1PTR=12.965	20.333 12.965	C=150	Pt= 31.296 Pe= 0.000	Mat="1-CPVC"
TR1	13.000					33.298	0.109	Pf= -3.625	
TR1	13.000		q= 0.000 Q=-124.597	2 2.153	1C=13.416 1B=7.318	12.000 45.125	C=120	Pt= 34.921 Pe= -4.763	Mat="1-WLML" Pdev=-3.0 psi
BR1	2.000				2T=24.392	57.125	0.116	Pf= -6.611	
BR1	2.000		q= 0.000 Q=-124.597	3 3.26	2G=2.688 1C=21.503	6.500 33.599	C=120	Pt= 49.295 Pe= 0.000	Mat="1-WL10" Pdev=101.84 psi
SOP	2.000				1E=9.408	40.099	0.015	Pf= -0.615	
SOP	2.000		q= 0.000 Q=-124.597	3 3.26	1E=9.408	5.000 9.408	C=120	Pt=-51.931 Pe= 0.000	Mat="1-WL10" Pdev=-2.0 psi
BOR	2.000					14.408	0.015	Pf= -0.221	
BOR	2.000		q= 0.000 Q=-124.597	6 6.065	1E=14.000	10.000 14.000	C=120	Pt=-49.710 Pe= -2.598	Mat="S40"
M01	-4.000					24.000	0.001	Pf= -0.018	
M01	-4.000		q= 100.000 Q=-224.597	6 6.08	1G=4.588 1E=21.411	96.000 71.880	C=150	Pt=-47.094 Pe= 2.165	Mat="1-PVC"
CTY	1.000				1T=45.881	167.880	0.001	Pf= -0.244	

**Material Codes**

- Pipe Material**
- S40 - Schedule 40 Steel
  - 1-PVC - PVC C900 Underround Pipe
  - 1-CPVC - Blazemaster
  - 1-WL10 - Wheatland's schedule 10
  - 1-WLML - Wheatland's MLT

- Fittings**
- B - Butterfly Valve
  - C - Check Valve
  - E - Standard 90 degree elbow
  - G - Gate Valve
  - T - Tee - Flow turn 90 degrees
  - PE - CPVC 90 degree elbow
  - PTR - CPVC Tee - Flow turn 90 degree
  - PTS - CPVC Tee - Flow straight thru path