

# Sway Bracing Calculation

For

**Homewood Suites**

3500 South Meridian  
Puyallup, WA. 98373

By

**Discount Fire Protection, LLC.**

4 Red Bluff Court  
Mansfield, TX. 76063

**Homewood Suites – Puyallup, W.A.**

Earthquake Calculations for 4" standpipe

Refer to NFPA. 13(2016)

- a. Brace shape and size (from Table 9.3.5.11.8(b)):
  - 1" Sch. 40 (l/r – 200)
  - Angle from vertical = 45°- 90°
  - Maximum horizontal load = 1310 lb.
  - Allowable Load on Brace (from Table 9.3.5.2.3) = 1310/1.414 = 926 lb.
  
- b. Lateral braces every 29' – meet piping at right angles  
Longitudinal braces every 29' – aligned with piping
  
- c. Sprinkler system load
  - 1. Load on lateral braces =  $F_{pw} = 196.43$  lb.  
Using Sch. 10 pipe (Table A-9.3.5.9)
    - 29' of 4" x (11.78/2) = 170.81
    - Add 15 % of load for fittings = 25.62
    - Sprinkler system load,  $F_{pw} = 170.81 + 25.62 = 196.43$
  - 2. Load on longitudinal braces =  $F_{pw} = 196.43$  lb.  
Using Sch. 10 pipe (Table A-9.3.5.9)
    - 29' of 4" x 5.89 = 170.81
    - Add 15 % of load for fittings = 25.62
    - Sprinkler system load,  $F_{pw} = 170.81 + 25.62 = 196.43$
  
- d. All expected loads are less than maximum loads permitted.
  
- e. Fasteners will be 1/2" x 2-1/2" through bolts in wood. Method of attachment will be one of the following from NFPA. 13(2016), Table 9.3.5.12.2(1)
  - Maximum load for (B) = 200 lb.      Maximum load for (C) = 240 lb.
  - Maximum load for (E) = 280 lb.      Maximum load for (F) = 480 lb.
  - Maximum load for (H) = 275 lb.      Maximum load for (I) = 410 lb.

**Result: for 4" standpipe**

- Maximum length of brace = 7'-0"
- Lateral braces with no branch every 29' – meet piping at right angles
- Longitudinal braces every 29' – aligned with piping

**Homewood Suites – Puyallup, W.A.**

Earthquake Calculations for 6” standpipe

Refer to NFPA. 13(2016)

- a. Brace shape and size (from Table 9.3.5.11.8(b)):
  - 1” Sch. 40 (l/r – 200)
  - Angle from vertical = 45°- 90°
  - Maximum horizontal load = 1310 lb.
  - Allowable Load on Brace (from Table 9.3.5.2.3) = 1310/1.414 = 926 lb.
  
- b. Lateral braces every 15’ – meet piping at right angles  
Longitudinal braces every 15’ – aligned with piping
  
- c. Sprinkler system load
  - 1. Load on lateral braces =  $F_{pw} = 198.64$  lb.  
Using Sch. 10 pipe (Table A-9.3.5.9)
    - 15’ of 6” x 11.515 = 172.73
    - Add 15 % of load for fittings = 25.91
    - Sprinkler system load,  $F_{pw} = 172.73 + 25.91 = 198.64$
  - 2. Load on longitudinal braces =  $F_{pw} = 198.64$  lb.  
Using Sch. 10 pipe (Table A-9.3.5.9)
    - 15’ of 6” x 11.515 = 172.73
    - Add 15 % of load for fittings = 25.91
    - Sprinkler system load,  $F_{pw} = 172.73 + 25.91 = 198.64$
  
- d. All expected loads are less than maximum loads permitted.
  
- e. Fasteners will be 1/2” x 2-1/2” through bolts in wood. Method of attachment will be one of the following from NFPA. 13(2016), Table 9.3.5.12.2(1)
  - Maximum load for (B) = 200 lb.      Maximum load for (C) = 240 lb.
  - Maximum load for (E) = 280 lb.      Maximum load for (F) = 480 lb.
  - Maximum load for (H) = 275 lb.      Maximum load for (I) = 410 lb.

**Result: for 6” standpipe**

- Maximum length of brace = 7’-0”
- Lateral braces with no branch every 15’ – meet piping at right angles
- Longitudinal braces every 15’ – aligned with piping

**Homewood Suites – Puyallup, W.A.**

Earthquake Calculations for 2” CPVC pipe

Refer to NFPA. 13(2016)

a. Brace shape and size (from Table 9.3.5.11.8(b)):

1” Sch. 40 (l/r – 200)

Angle from vertical = 45°- 90°

Maximum horizontal load = 1310 lb.

Allowable Load on Brace (from Table 9.3.5.2.3) =  $1310/1.414 = 926$  lb.

b. Longitudinal braces every 75’ – aligned with piping

c. Sprinkler system load

1. Load on longitudinal braces =  $F_{pw} = 189.75$  lb.

Using Blazemaster pipe

75’ of 2” x 2.20 = 165.00

Add 15 % of load for fittings = 24.75

Sprinkler system load,  $F_{pw} = 165.00 + 24.75 = 189.75$

d. All expected loads are less than maximum loads permitted.

e. Fasteners will be 1/2” x 2-1/2” through bolts in wood. Method of attachment will be one of the following from NFPA. 13(2016), Table 9.3.5.12.2(1)

Maximum load for (B) = 200 lb.      Maximum load for (C) = 240 lb.

Maximum load for (E) = 280 lb.      Maximum load for (F) = 480 lb.

Maximum load for (H) = 275 lb.      Maximum load for (I) = 410 lb.

**Result: for 2” CPVC pipe**

Maximum length of brace = 7’-0”

Longitudinal braces every 75’ – aligned with piping