



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 18, 2024

Inspection Result: PASSED

Permit Number: PRDE20240287

Property Address: 2317 SHAW RD, PUYALLUP, WA 98374;

Contractor:

To construct: DEMO BARN & SHED ON PROPERTY

On this day we have inspected your construction for **Utility Capping Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424