



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Mar 18, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20221698

**Property Address:** 201 W MAIN, PUYALLUP, WA 98371;

**Contractor:** ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

**To construct:** Remodel of existing office building to a medical/dental clinic - CHC  
CANNERY \* REVISION (1) - 1/26/2024 - CORRECT OCCUPANCY, FULL  
RE-ROOF AND WALL ASSEMBLIES

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 1.remove drywall in zones 3 and 4 where covered with out inspections as discussed with contractor

Sincerely,

Kevin Spruell  
Building Inspector I  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590