



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Mar 19, 2024 **Inspection Result:** NOT READY

**Permit Number:** PRCTI20221714

**Property Address:** 111 W MAIN, PUYALLUP, WA 98371;

**Contractor:** ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021  
Randy Carlson 6218 Rocky Mountain Drive Southwest Olympia, WA 98512

**To construct:** Remodel office space on the ground floor of an existing parking structure - COMMUNITY HEALTHCARE \* REV (1) - 11/20/2023 - REVISE SIDE SEWER CONNECTION LOCATION \* REV (2) - 2.22.2024 - IDENTIFY REVISION TO APPLICABLE BUILDING CODE COMPLIANCE TO 2018 INTERNATIONAL EXISTING BUILDING CODE, WITH RESPECTIVE CODE REFERENCES.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 ROOM 107 PHARMACY WAITING ROOM
  1. complete insulation that is missing above ceiling at exterior wall (west)
  2. complete framing at ceiling as discussed with contractor
  3. provide cover approval for fire as discussed with contractor at time of next inspection
  4. not ready

Sincerely,

Kevin Spruell  
Building Inspector I



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590