




Job Number: S23-90

| | |
|-----------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  Expires DEC 31, 24 | WASHINGTON STATE |
| | CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS |
| Theodore M. Queen 4930-0205-C Level 3 Archer Construction, Inc. ARCHEI*219DR | |
|  | 3-14-24 |
| Signature | Date |

| | | | |
|--------------------------------------------|-------------------------|--------------|---------------|
| Contractor | | | |
| | Contractor Number 22 | Contact Name | Contact Title |
| Name of Contractor: Archer Construction | | Phone | Extension |
| Address 1 7855 South 206th ST | | FAX | |
| Address 2 Kent, WA 98032 | | E-mail | |
| Address 3 | | Web Site | |



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static Pressure

51.00

Residual Pressure

38.00 @ 2460.00

Available Pressure at Time of Test

50.43 @ 452.43

System Demand

46.26 @ 352.43

System Demand (including Hose Allowance at Source)

46.26 @ 452.43



Summary Of Outflowing Devices

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Device | | Actual Flow (gpm) | Minimum Flow (gpm) | K-Factor (K) | Pressure (psi) | | |
|-------------|------|----------------------|-----------------------|-----------------|-------------------|--|--|
| ⇒ Sprinkler | 1001 | 20.00 | 20.00 | 5.6 | 12.76 | | |
| Sprinkler | 1002 | 22.21 | 14.82 | 5.6 | 15.73 | | |
| Sprinkler | 1003 | 20.74 | 14.82 | 5.6 | 13.71 | | |
| Sprinkler | 1004 | 20.62 | 14.82 | 5.6 | 13.56 | | |
| Sprinkler | 1005 | 22.25 | 14.82 | 5.6 | 15.79 | | |
| Sprinkler | 1006 | 24.34 | 14.82 | 5.6 | 18.88 | | |
| Sprinkler | 1007 | 21.96 | 18.20 | 5.6 | 15.38 | | |
| Sprinkler | 1008 | 24.44 | 14.82 | 5.6 | 19.05 | | |
| Sprinkler | 1009 | 24.72 | 14.82 | 5.6 | 19.49 | | |
| Sprinkler | 1010 | 25.45 | 14.82 | 5.6 | 20.65 | | |
| Sprinkler | 1011 | 27.26 | 14.82 | 5.6 | 23.69 | | |
| Sprinkler | 1012 | 25.02 | 14.82 | 5.6 | 19.96 | | |
| Sprinkler | 1013 | 25.06 | 14.82 | 5.6 | 20.02 | | |
| Sprinkler | 1014 | 25.21 | 15.40 | 5.6 | 20.27 | | |
| Sprinkler | 1015 | 23.15 | 19.20 | 5.6 | 17.09 | | |

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Node | Elevation(Foot) | Fittings | Pressure(psi) | Discharge(gpm) |
|------|-----------------|-----------------------|---------------|----------------|
| 1 | -4-0 | S | 46.26 | 352.43 |
| 1001 | 8-6 | Spr(-12.76), fd(23-0) | 12.76 | 20.00 |
| 1002 | 10-3 | Spr(-15.73) | 15.73 | 22.21 |
| 1003 | 8-0 | Spr(-13.71), fd(23-0) | 13.71 | 20.74 |
| 1004 | 8-0 | Spr(-13.56), fd(34-0) | 13.56 | 20.62 |
| 1005 | 8-6 | Spr(-15.79), fd(23-0) | 15.79 | 22.25 |
| 1006 | 8-6 | Spr(-18.88), fd(23-0) | 18.88 | 24.34 |
| 1007 | 8-6 | Spr(-15.38), fd(23-0) | 15.38 | 21.96 |
| 1008 | 10-3 | Spr(-19.05) | 19.05 | 24.44 |
| 1009 | 10-3 | Spr(-19.49) | 19.49 | 24.72 |
| 1010 | 10-3 | Spr(-20.65) | 20.65 | 25.45 |
| 1011 | 10-3 | Spr(-23.69) | 23.69 | 27.26 |
| 1012 | 10-3 | Spr(-19.96) | 19.96 | 25.02 |
| 1013 | 10-3 | Spr(-20.02) | 20.02 | 25.06 |
| 1014 | 10-3 | Spr(-20.27) | 20.27 | 25.21 |
| 1015 | 8-6 | Spr(-17.09), fd(23-0) | 17.09 | 23.15 |
| 7 | 0-0 | | 38.50 | |
| 8 | -4-0 | T(47-3½) | 46.22 | |
| 9 | 2-0 | PO(20-0) | 37.57 | |
| 84 | 23-6½ | fE(5-0) | 24.61 | |
| 101 | 19-5½ | PO(20-0), C(20-0) | 26.38 | |
| 105 | 10-6 | fT(16-0) | 30.32 | |
| 107 | 10-3 | E(2-0) | 16.21 | |
| 108 | 10-3 | T(9-11) | 16.39 | |
| 109 | 10-3 | PO(5-0) | 15.64 | |
| 110 | 10-3 | PO(5-0) | 23.36 | |
| 112 | 10-3 | T(9-11) | 23.66 | |
| 113 | 10-3 | PO(5-0) | 19.47 | |
| 114 | 10-3 | PO(5-0) | 17.95 | |
| 116 | 10-3 | T(9-11) | 24.02 | |
| 117 | 10-3 | PO(5-0) | 18.95 | |
| 119 | 10-3 | PO(5-0) | 21.11 | |
| 120 | 10-6 | fT(16-0) | 30.16 | |
| 123 | 19-3½ | PO(20-0) | 26.41 | |
| 175 | 24-4 | fE(5-0) | 24.22 | |
| 635 | 20-4 | | 25.99 | |
| 636 | 20-4 | | 25.97 | |
| 754 | 12-0½ | fE(6-9½) | 31.10 | |
| 818 | 12-0½ | fT(16-0) | 30.62 | |
| 860 | 10-6 | fE(6-9½) | 30.35 | |
| 861 | 12-0 | fE(6-9½) | 29.79 | |
| 905 | 12-0 | E(10-0) | 29.67 | |
| 907 | 11-10 | E(13-2) | 29.59 | |
| 1036 | 9-7½ | PO(9-11) | 28.06 | |
| 1038 | 9-7½ | PO(9-11) | 28.06 | |
| 1040 | 9-7½ | PO(9-11) | 28.16 | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|--------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| Route 1 | | | | | | | | |
| DY | 1.0490 | 20.00 | 7.42 | 120 | | 0.130131 | 0-0 | Pf 3.64 |
| 1001 | 8-6 | 20.00 | 5.6 | 12.76 | | Sprinkler, | 28-0 | Pe -0.76 |
| 109 | 10-3 | | | 15.64 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 20.00 | 2.89 | 120 | | 0.013055 | 7-0½ | Pf 0.09 |
| 109 | 10-3 | | | 15.64 | | | 7-0½ | Pe |
| 1002 | 10-3 | | | 15.73 | | | | Pv |
| BL | 1.6820 | 42.21 | 6.09 | 120 | | 0.051991 | 2-9 | Pf 0.66 |
| 1002 | 10-3 | 22.21 | 5.6 | 15.73 | | Sprinkler, | 9-11 | Pe |
| 108 | 10-3 | | | 16.39 | | T(9-11) | 12-7½ | Pv |
| BL | 1.6820 | 62.95 | 9.09 | 120 | | 0.108890 | 6-11 | Pf 1.56 |
| 108 | 10-3 | 20.74 | | 16.39 | | Flow (q) from Route 5 | 7-5 | Pe 0.00 |
| 114 | 10-3 | | | 17.95 | | 3LtE(2-5½) | 14-4 | Pv |
| BL | 1.6820 | 83.57 | 12.07 | 120 | | 0.183919 | 8-3 | Pf 1.52 |
| 114 | 10-3 | 20.62 | | 17.95 | | Flow (q) from Route 4 | | Pe |
| 113 | 10-3 | | | 19.47 | | | 8-3 | Pv |
| BL | 1.6820 | 105.82 | 15.28 | 120 | | 0.284648 | 4-10 | Pf 4.19 |
| 113 | 10-3 | 22.25 | | 19.47 | | Flow (q) from Route 6 | 9-11 | Pe |
| 112 | 10-3 | | | 23.66 | | T(9-11) | 14-8½ | Pv |
| DY | 1.6820 | 130.15 | 18.79 | 120 | | 0.417463 | 0-0 | Pf 4.13 |
| 112 | 10-3 | 24.34 | | 23.66 | | Flow (q) from Route 7 | 9-11 | Pe 0.27 |
| 1036 | 9-7½ | | | 28.06 | | PO(9-11) | 9-11 | Pv |
| CM | 3.2600 | 150.17 | 5.77 | 120 | | 0.021674 | 111-8½ | Pf 2.64 |
| 1036 | 9-7½ | 20.01 | | 28.06 | | Flow (q) from Route 13 | 10-0 | Pe -0.38 |
| 105 | 10-6 | | | 30.32 | | 2fE(5-0) | 121-8½ | Pv |
| CM | 4.2600 | 173.43 | 3.90 | 120 | | 0.007688 | 81-7½ | Pf 0.96 |
| 105 | 10-6 | 23.26 | | 30.32 | | Flow (q) from Route 11 | 43-2 | Pe -0.66 |
| 818 | 12-0½ | | | 30.62 | | 4fE(6-9½), fT(16-0) | 124-9½ | Pv |
| CM | 4.2600 | 352.43 | 7.93 | 120 | | 0.028543 | 9-10½ | Pf 0.48 |
| 818 | 12-0½ | 179.00 | | 30.62 | | Flow (q) from Route 2 | 6-9½ | Pe |
| 754 | 12-0½ | | | 31.10 | | fE(6-9½) | 16-8 | Pv |
| CM | 4.0260 | 352.43 | 8.88 | 120 | | 0.037583 | 11-0 | Pf 2.13 |
| 754 | 12-0½ | | | 31.10 | | | 45-7 | Pe 4.35 |
| 9 | 2-0 | | | 37.57 | | 2fE(6-9½), BV(12-0), PO(20-0) | 56-7 | Pv |
| UG | 6.3570 | 352.43 | 3.56 | 120 | | 0.004063 | 2-10 | Pf 0.06 |
| 9 | 2-0 | | | 37.57 | | | 11-4 | Pe 0.87 |
| 7 | 0-0 | | | 38.50 | | LtE(11-4) | 14-2 | Pv |
| UG | 6.2800 | 352.43 | 3.65 | 140 | | 0.003242 | 168-7 | Pf 5.99 |
| 7 | 0-0 | | | 38.50 | | | 135-6½ | Pe 1.73 |
| 8 | -4-0 | | | 46.22 | | 4E(22-1), BFP(-5.00), T(47-3½) | 304-1 | Pv |
| UG | 8.3900 | 352.43 | 2.05 | 140 | | 0.000791 | 50-8½ | Pf 0.04 |
| 8 | -4-0 | | | 46.22 | | | | Pe |
| 1 | -4-0 | | | 46.26 | | Water Supply | 50-8½ | Pv |
| | | 100.00 | | | | Hose Allowance At Source | | |
| 1 | | 452.43 | | | | | | |
| Route 2 | | | | | | | | |
| DY | 1.0490 | 21.96 | 8.15 | 120 | | 0.154706 | 0-0 | Pf 4.33 |
| 1007 | 8-6 | 21.96 | 5.6 | 15.38 | | Sprinkler, | 28-0 | Pe -0.76 |
| 117 | 10-3 | | | 18.95 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 21.96 | 3.17 | 120 | | 0.015521 | 6-7 | Pf 0.10 |
| 117 | 10-3 | | | 18.95 | | | 6-7 | Pe |
| 1008 | 10-3 | | | 19.05 | | | | Pv |
| BL | 1.6820 | 46.40 | 6.70 | 120 | | 0.061946 | 7-1 | Pf 0.44 |
| 1008 | 10-3 | 24.44 | 5.6 | 19.05 | | Sprinkler | | Pe |
| 1009 | 10-3 | | | 19.49 | | | 7-1 | Pv |
| BL | 1.6820 | 71.13 | 10.27 | 120 | | 0.136509 | 8-6 | Pf 1.16 |
| 1009 | 10-3 | 24.72 | 5.6 | 19.49 | | Sprinkler | | Pe |
| 1010 | 10-3 | | | 20.65 | | | 8-6 | Pv |
| BL | 1.6820 | 96.58 | 13.94 | 120 | | 0.240383 | 4-1½ | Pf 3.37 |
| 1010 | 10-3 | 25.45 | 5.6 | 20.65 | | Sprinkler, | 9-11 | Pe |
| 116 | 10-3 | | | 24.02 | | T(9-11) | 14-0 | Pv |
| DY | 1.6820 | 123.83 | 17.88 | 120 | | 0.380748 | 0-0 | Pf 3.77 |
| 116 | 10-3 | 27.26 | | 24.02 | | Flow (q) from Route 10 | 9-11 | Pe 0.27 |
| 1038 | 9-7½ | | | 28.06 | | PO(9-11) | 9-11 | Pv |
| CM | 3.2600 | 103.82 | 3.99 | 120 | | 0.010950 | 8-11 | Pf 0.10 |
| 1038 | 9-7½ | | | 28.06 | | | | Pe |
| 1040 | 9-7½ | | | 28.16 | | | 8-11 | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| CM | 3.2600 | 202.26 | 7.77 | 120 | 0.037603 | 53-4 | Pf 2.38 |
| 1040 | 9-7½ | 98.44 | | 28.16 | Flow (q) from Route 3 | 10-0 | Pe -0.38 |
| 120 | 10-6 | | | 30.16 | 2fE(5-0) | 63-4 | Pv |
| CM | 4.2600 | 179.00 | 4.03 | 120 | 0.008151 | 16-11½ | Pf 0.19 |
| 120 | 10-6 | | | 30.16 | | 6-9½ | Pe |
| 860 | 10-6 | | | 30.35 | fE(6-9½) | 23-9 | Pv |
| CM | 4.0260 | 179.00 | 4.51 | 120 | 0.010732 | 1-6 | Pf 0.09 |
| 860 | 10-6 | | | 30.35 | | 6-9½ | Pe -0.65 |
| 861 | 12-0 | | | 29.79 | fE(6-9½) | 8-3½ | Pv |
| CM | 4.2600 | 179.00 | 4.03 | 120 | 0.008151 | 87-0½ | Pf 0.84 |
| 861 | 12-0 | | | 29.79 | | 16-0 | Pe -0.01 |
| 818 | 12-0½ | | | 30.62 | fT(16-0) | 103-0½ | Pv |
| Route 3 | | | | | | | |
| DY | 1.0490 | 23.15 | 8.59 | 120 | 0.170599 | 0-0 | Pf 4.78 |
| 1015 | 8-6 | 23.15 | 5.6 | 17.09 | Sprinkler, | 28-0 | Pe -0.76 |
| 119 | 10-3 | | | 21.11 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 98.44 | 14.21 | 120 | 0.249028 | 7-5 | Pf 6.78 |
| 119 | 10-3 | 75.29 | | 21.11 | Flow (q) from Route 8 | 19-9½ | Pe 0.27 |
| 1040 | 9-7½ | | | 28.16 | T(9-11), PO(9-11) | 27-2½ | Pv |
| Route 4 | | | | | | | |
| DY | 1.0490 | 20.62 | 7.65 | 120 | 0.137666 | 0-0 | Pf 5.37 |
| 1004 | 8-0 | 20.62 | 5.6 | 13.56 | Sprinkler, | 39-0 | Pe -0.98 |
| 114 | 10-3 | | | 17.95 | PO(5-0), fd(34-0) | 39-0 | Pv |
| Route 5 | | | | | | | |
| DY | 1.0490 | 20.74 | 7.70 | 120 | 0.139127 | 0-0 | Pf 3.48 |
| 1003 | 8-0 | 20.74 | 5.6 | 13.71 | Sprinkler, | 25-0 | Pe -0.98 |
| 107 | 10-3 | | | 16.21 | E(2-0), fd(23-0) | 25-0 | Pv |
| BL | 1.6820 | 20.74 | 2.99 | 120 | 0.013958 | 2-8 | Pf 0.18 |
| 107 | 10-3 | | | 16.21 | | 9-11 | Pe |
| 108 | 10-3 | | | 16.39 | T(9-11) | 12-6½ | Pv |
| Route 6 | | | | | | | |
| DY | 1.0490 | 22.25 | 8.26 | 120 | 0.158527 | 0-0 | Pf 4.44 |
| 1005 | 8-6 | 22.25 | 5.6 | 15.79 | Sprinkler, | 28-0 | Pe -0.76 |
| 113 | 10-3 | | | 19.47 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 7 | | | | | | | |
| DY | 1.0490 | 24.34 | 9.03 | 120 | 0.187078 | 0-0 | Pf 5.24 |
| 1006 | 8-6 | 24.34 | 5.6 | 18.88 | Sprinkler, | 28-0 | Pe -0.76 |
| 110 | 10-3 | | | 23.36 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 24.34 | 3.51 | 120 | 0.018768 | 5-11 | Pf 0.30 |
| 110 | 10-3 | | | 23.36 | | 9-11 | Pe |
| 112 | 10-3 | | | 23.66 | T(9-11) | 15-10 | Pv |
| Route 8 | | | | | | | |
| BL | 1.6820 | 75.29 | 10.87 | 120 | 0.151643 | 5-6 | Pf 0.84 |
| 1014 | 10-3 | 50.07 | 5.6 | 20.27 | Sprinkler, Flow (q) from Route 9 | | Pe |
| 119 | 10-3 | | | 21.11 | | 5-6 | Pv |
| Route 9 | | | | | | | |
| BL | 1.6820 | 25.02 | 3.61 | 120 | 0.019752 | 3-2½ | Pf 0.06 |
| 1012 | 10-3 | 25.02 | 5.6 | 19.96 | Sprinkler | | Pe |
| 1013 | 10-3 | | | 20.02 | | 3-2½ | Pv |
| BL | 1.6820 | 50.07 | 7.23 | 120 | 0.071309 | 3-7 | Pf 0.25 |
| 1013 | 10-3 | 25.06 | 5.6 | 20.02 | Sprinkler | | Pe |
| 1014 | 10-3 | | | 20.27 | | 3-7 | Pv |
| Route 10 | | | | | | | |
| BL | 1.6820 | 27.26 | 3.94 | 120 | 0.023148 | 4-4½ | Pf 0.33 |
| 1011 | 10-3 | 27.26 | 5.6 | 23.69 | Sprinkler, | 9-11 | Pe |
| 116 | 10-3 | | | 24.02 | T(9-11) | 14-3½ | Pv |
| Route 11 | | | | | | | |
| CM | 3.0680 | 9.30 | 0.40 | 120 | 0.000170 | 151-3½ | Pf 0.03 |
| 175 | 24-4 | | | 24.22 | | 40-0 | Pe 0.35 |
| 84 | 23-6½ | | | 24.61 | 8fE(5-0) | 191-3½ | Pv |
| CM | 4.0260 | 9.30 | 0.23 | 120 | 0.000045 | 37-6 | Pf 0.00 |
| 84 | 23-6½ | | | 24.61 | | 53-7 | Pe 1.77 |
| 101 | 19-5½ | | | 26.38 | 2fE(6-9½), PO(20-0), C(20-0) | 91-1 | Pv |
| CM | 4.0260 | 23.26 | 0.59 | 120 | 0.000246 | 207-5½ | Pf 0.06 |
| 101 | 19-5½ | 13.96 | | 26.38 | Flow (q) from Route 14 | 20-0 | Pe 3.23 |
| 905 | 12-0 | | | 29.67 | 2E(10-0) | 227-5½ | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|----------------------|-----------|-----------|----------|-------|------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| CM | 4.2600 | 23.26 | 0.52 | 120 | 0.000187 | | |
| 905 | 12-0 | | | 29.67 | | 1-6 | Pf 0.00 |
| 105 | 10-6 | | | 30.32 | fT(16-0) | 16-0 | Pe 0.65 |
| | | | | | | 17-6 | Pv |
| ***** Route 12 ***** | | | | | | | |
| CM | 4.2600 | 23.26 | 0.52 | 120 | 0.000187 | | |
| 120 | 10-6 | | | 30.16 | fT(16-0) | 1-4 | Pf 0.01 |
| 907 | 11-10 | | | 29.59 | E(13-2) | 29-2 | Pe -0.58 |
| | | | | | | 30-6 | Pv |
| CM | 4.0260 | 23.26 | 0.59 | 120 | 0.000246 | | |
| 907 | 11-10 | | | 29.59 | | 207-5½ | Pf 0.06 |
| 123 | 19-3½ | | | 26.41 | E(10-0), PO(20-0) | 30-0 | Pe -3.23 |
| | | | | | | 237-5½ | Pv |
| CM | 4.0260 | 9.30 | 0.23 | 120 | 0.000045 | | |
| 123 | 19-3½ | | | 26.41 | | 36-1 | Pf 0.00 |
| 175 | 24-4 | | | 24.22 | 4fE(6-9½), fE(5-0) | 32-2 | Pe -2.20 |
| | | | | | | 68-3 | Pv |
| ***** Route 13 ***** | | | | | | | |
| CM | 3.2600 | 20.01 | 0.77 | 120 | 0.000521 | | |
| 1038 | 9-7½ | | | 28.06 | | 7-0 | Pf 0.00 |
| 1036 | 9-7½ | | | 28.06 | | 7-0 | Pe |
| | | | | | | | Pv |
| ***** Route 14 ***** | | | | | | | |
| CM | 4.0260 | 13.96 | 0.35 | 120 | 0.000096 | | |
| 635 | 20-4 | 13.96 | | 25.99 | Flow (q) from Route 15 | 88-0½ | Pf 0.01 |
| 101 | 19-5½ | | | 26.38 | 2fE(6-9½), PO(20-0), C(20-0) | 53-7 | Pe 0.38 |
| | | | | | | 141-7½ | Pv |
| ***** Route 15 ***** | | | | | | | |
| CM | 3.0680 | 13.96 | 0.61 | 120 | 0.000360 | | |
| 636 | 20-4 | | | 25.97 | | 46-10½ | Pf 0.02 |
| 635 | 20-4 | | | 25.99 | | 46-10½ | Pe |
| | | | | | | | Pv |
| ***** Route 16 ***** | | | | | | | |
| CM | 4.0260 | 13.96 | 0.35 | 120 | 0.000096 | | |
| 123 | 19-3½ | | | 26.41 | | 82-9 | Pf 0.01 |
| 636 | 20-4 | | | 25.97 | 2fE(6-9½) | 13-7 | Pe -0.45 |
| | | | | | | 96-4 | Pv |

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

| Value Of C | 100 | 130 | 140 | 150 |
|--------------------|-------|------|------|------|
| Multiplying Factor | 0.713 | 1.16 | 1.33 | 1.51 |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 1 - Provider - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------------|---------------|---------------|---------------------------------------------------------------|-----|---------------|-----------------|----------------------------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | Fittings | Total Length | |
| Pipe Type Legend | | Units Legend | | | | Fittings Legend | |
| AO | Arm-Over | Diameter | Inch | | | ALV | Alarm Valve |
| BL | Branch Line | Elevation | Foot | | | AngV | Angle Valve |
| CM | Cross Main | Flow | gpm | | | b | Bushing |
| DN | Drain | Discharge | gpm | | | BalV | Ball Valve |
| DR | Drop | Velocity | fps | | | BFP | Backflow Preventer |
| DY | Dynamic | Pressure | psi | | | BV | Butterfly Valve |
| FM | Feed Main | Length | Foot | | | C | Cross Flow Turn 90° |
| FR | Feed Riser | Friction Loss | psi/Foot | | | cplg | Coupling |
| MS | Miscellaneous | HWC | Hazen-Williams Constant | | | Cr | Cross Run |
| OR | Outrigger | Pt | Total pressure at a point in a pipe | | | CV | Check Valve |
| RN | Riser Nipple | Pn | Normal pressure at a point in a pipe | | | DeIV | Deluge Valve |
| SP | Sprig | Pf | Pressure loss due to friction between points | | | DPV | Dry Pipe Valve |
| ST | Stand Pipe | Pe | Pressure due to elevation difference between indicated points | | | E | 90° Elbow |
| UG | Underground | Pv | Velocity pressure at a point in a pipe | | | EE | 45° Elbow |
| | | | | | | Ee1 | 11¼° Elbow |
| | | | | | | Ee2 | 22½° Elbow |
| | | | | | | f | Flow Device |
| | | | | | | fd | Flex Drop |
| | | | | | | FDC | Fire Department Connection |
| | | | | | | fE | 90° FireLock(TM) Elbow |
| | | | | | | fEE | 45° FireLock(TM) Elbow |
| | | | | | | flg | Flange |
| | | | | | | FN | Floating Node |
| | | | | | | fT | FireLock(TM) Tee |
| | | | | | | g | Gauge |
| | | | | | | GloV | Globe Valve |
| | | | | | | GV | Gate Valve |
| | | | | | | Ho | Hose |
| | | | | | | Hose | Hose |
| | | | | | | HV | Hose Valve |
| | | | | | | Hyd | Hydrant |
| | | | | | | LtE | Long Turn Elbow |
| | | | | | | mecT | Mechanical Tee |
| | | | | | | Noz | Nozzle |
| | | | | | | P1 | Pump In |
| | | | | | | P2 | Pump Out |
| | | | | | | PIV | Post Indicating Valve |
| | | | | | | PO | Pipe Outlet |
| | | | | | | PRV | Pressure Reducing Valve |
| | | | | | | PrV | Pressure Relief Valve |
| | | | | | | red | Reducer/Adapter |
| | | | | | | S | Supply |
| | | | | | | sCV | Swing Check Valve |
| | | | | | | Spr | Sprinkler |
| | | | | | | St | Strainer |
| | | | | | | T | Tee Flow Turn 90° |
| | | | | | | Tr | Tee Run |
| | | | | | | U | Union |
| | | | | | | WirF | Wirsbo |
| | | | | | | WMV | Water Meter Valve |
| | | | | | | Z | Cap |




Report Description: Light Hazard - Level 2 - Reception - Floor Area

Page 1



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure

51.00

Residual: Pressure

38.00 @ 2460.00

Available Pressure at Time of Test

50.09 @ 584.73

System Demand

44.58 @ 484.73

System Demand (including Hose Allowance at Source)

44.58 @ 584.73



Summary Of Outflowing Devices

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Device | | Actual Flow (gpm) | Minimum Flow (gpm) | K-Factor (K) | Pressure (psi) | | |
|-------------|------|----------------------|-----------------------|-----------------|-------------------|--|--|
| Sprinkler | 2001 | 14.47 | 10.90 | 4.2 | 11.86 | | |
| Sprinkler | 2002 | 14.62 | 11.11 | 4.2 | 12.11 | | |
| Sprinkler | 2003 | 14.03 | 11.11 | 4.2 | 11.15 | | |
| Sprinkler | 2004 | 14.27 | 11.11 | 4.2 | 11.55 | | |
| Sprinkler | 2005 | 14.59 | 11.11 | 4.2 | 12.06 | | |
| Sprinkler | 2006 | 14.28 | 11.11 | 4.2 | 11.56 | | |
| Sprinkler | 2007 | 13.71 | 11.11 | 4.2 | 10.66 | | |
| Sprinkler | 2008 | 13.49 | 11.11 | 4.2 | 10.31 | | |
| Sprinkler | 2009 | 13.80 | 11.11 | 4.2 | 10.79 | | |
| ⇒ Sprinkler | 2010 | 14.21 | 14.21 | 4.2 | 11.45 | | |
| Sprinkler | 2011 | 13.37 | 11.11 | 4.2 | 10.13 | | |
| Sprinkler | 2012 | 13.48 | 11.11 | 4.2 | 10.30 | | |
| Sprinkler | 2013 | 13.05 | 11.11 | 4.2 | 9.65 | | |
| Sprinkler | 2014 | 13.53 | 11.11 | 4.2 | 10.38 | | |
| Sprinkler | 2015 | 13.24 | 11.11 | 4.2 | 9.94 | | |
| Sprinkler | 2016 | 13.05 | 11.11 | 4.2 | 9.65 | | |
| Sprinkler | 2017 | 13.29 | 11.11 | 4.2 | 10.01 | | |
| Sprinkler | 2018 | 13.60 | 11.11 | 4.2 | 10.49 | | |
| Sprinkler | 2019 | 14.22 | 14.21 | 4.2 | 11.46 | | |
| Sprinkler | 2020 | 13.60 | 11.11 | 4.2 | 10.49 | | |
| Sprinkler | 2021 | 13.40 | 11.11 | 4.2 | 10.18 | | |
| Sprinkler | 2022 | 13.23 | 11.11 | 4.2 | 9.92 | | |
| Sprinkler | 2023 | 13.55 | 11.11 | 4.2 | 10.40 | | |
| Sprinkler | 2024 | 13.84 | 11.11 | 4.2 | 10.86 | | |
| Sprinkler | 2025 | 13.88 | 11.11 | 4.2 | 10.92 | | |
| Sprinkler | 2026 | 14.34 | 11.11 | 4.2 | 11.66 | | |
| Sprinkler | 2027 | 13.88 | 11.11 | 4.2 | 10.92 | | |
| Sprinkler | 2028 | 13.92 | 11.11 | 4.2 | 10.99 | | |
| Sprinkler | 2029 | 13.96 | 13.72 | 4.2 | 11.05 | | |
| Sprinkler | 2030 | 13.84 | 11.11 | 4.2 | 10.86 | | |
| Sprinkler | 2031 | 14.28 | 11.11 | 4.2 | 11.57 | | |
| Sprinkler | 2032 | 14.34 | 11.11 | 4.2 | 11.67 | | |
| Sprinkler | 2033 | 14.37 | 11.11 | 4.2 | 11.71 | | |
| Sprinkler | 2034 | 14.05 | 11.11 | 4.2 | 11.19 | | |
| Sprinkler | 2035 | 13.97 | 11.11 | 4.2 | 11.06 | | |

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Node | Elevation(Foot) | Fittings | Pressure(psi) | Discharge(gpm) |
|------|-----------------|-----------------------|---------------|----------------|
| 1 | -4-0 | S | 44.58 | 484.73 |
| 2001 | 23-2 | Spr(-11.86), fd(23-0) | 11.86 | 14.47 |
| 2002 | 23-2 | Spr(-12.11), fd(23-0) | 12.11 | 14.62 |
| 2003 | 22-8 | Spr(-11.15), fd(34-0) | 11.15 | 14.03 |
| 2004 | 23-2 | Spr(-11.55), fd(23-0) | 11.55 | 14.27 |
| 2005 | 25-8½ | Spr(-12.06) | 12.06 | 14.59 |
| 2006 | 27-0½ | Spr(-11.56) | 11.56 | 14.28 |
| 2007 | 22-8 | Spr(-10.66), fd(23-0) | 10.66 | 13.71 |
| 2008 | 26-5 | Spr(-10.31) | 10.31 | 13.49 |
| 2009 | 25-2½ | Spr(-10.79) | 10.79 | 13.80 |
| 2010 | 23-2 | Spr(-11.45), fd(23-0) | 11.45 | 14.21 |
| 2011 | 22-8 | Spr(-10.13), fd(34-0) | 10.13 | 13.37 |
| 2012 | 22-8 | Spr(-10.30), fd(23-0) | 10.30 | 13.48 |
| 2013 | 26-9½ | Spr(-9.65) | 9.65 | 13.05 |
| 2014 | 24-9½ | Spr(-10.38) | 10.38 | 13.53 |
| 2015 | 22-8 | Spr(-9.94), fd(34-0) | 9.94 | 13.24 |
| 2016 | 22-8 | Spr(-9.65), fd(34-0) | 9.65 | 13.05 |
| 2017 | 26-3 | Spr(-10.01) | 10.01 | 13.29 |
| 2018 | 25-0 | Spr(-10.49) | 10.49 | 13.60 |
| 2019 | 23-2 | Spr(-11.46), fd(23-0) | 11.46 | 14.22 |
| 2020 | 22-8 | Spr(-10.49), fd(23-0) | 10.49 | 13.60 |
| 2021 | 22-8 | Spr(-10.18), fd(23-0) | 10.18 | 13.40 |
| 2022 | 26-3 | Spr(-9.92) | 9.92 | 13.23 |
| 2023 | 25-0 | Spr(-10.40) | 10.40 | 13.55 |
| 2024 | 24-3 | Spr(-10.86), fd(23-0) | 10.86 | 13.84 |
| 2025 | 24-3 | Spr(-10.92), fd(23-0) | 10.92 | 13.88 |
| 2026 | 22-8 | Spr(-11.66), fd(23-0) | 11.66 | 14.34 |
| 2027 | 24-3 | Spr(-10.92), fd(23-0) | 10.92 | 13.88 |
| 2028 | 24-3 | Spr(-10.99), fd(23-0) | 10.99 | 13.92 |
| 2029 | 22-8 | Spr(-11.05), fd(23-0) | 11.05 | 13.96 |
| 2030 | 22-8 | Spr(-10.86), fd(23-0) | 10.86 | 13.84 |
| 2031 | 20-7 | Spr(-11.57), fd(23-0) | 11.57 | 14.28 |
| 2032 | 23-2 | Spr(-11.67), fd(23-0) | 11.67 | 14.34 |
| 2033 | 23-2 | Spr(-11.71), fd(23-0) | 11.71 | 14.37 |
| 2034 | 22-8 | Spr(-11.19), fd(34-0) | 11.19 | 14.05 |
| 2035 | 22-8 | Spr(-11.06), fd(34-0) | 11.06 | 13.97 |
| 7 | 0-0 | | 36.00 | |
| 8 | -4-0 | T(47-3½) | 44.51 | |
| 9 | 2-0 | PO(20-0) | 35.03 | |
| 200 | 24-11½ | PO(5-0) | 12.85 | |
| 201 | 24-11½ | PO(5-0) | 12.38 | |
| 202 | 24-11½ | PO(5-0) | 12.46 | |
| 203 | 26-1½ | PO(5-0) | 12.10 | |
| 204 | 26-1½ | PO(5-0) | 12.58 | |
| 205 | 24-11½ | PO(5-0) | 12.62 | |
| 206 | 24-11½ | PO(5-0) | 12.90 | |
| 207 | 24-11½ | PO(5-0) | 12.47 | |
| 208 | 24-4 | PO(9-11) | 13.58 | |
| 209 | 24-4 | PO(9-11) | 13.60 | |
| 210 | 24-11½ | PO(5-0) | 12.55 | |
| 211 | 23-5½ | fE(5-0) | 17.11 | |
| 212 | 24-4 | PO(5-0) | 13.65 | |
| 213 | 24-4 | PO(9-11) | 13.56 | |
| 214 | 24-4 | PO(9-11) | 13.50 | |
| 215 | 24-4 | PO(9-11) | 13.29 | |
| 216 | 24-4 | PO(9-11) | 13.26 | |
| 217 | 24-4 | PO(9-11) | 13.09 | |
| 218 | 24-4 | PO(9-11) | 13.07 | |
| 219 | 24-4 | PO(9-11) | 13.05 | |
| 220 | 24-4 | PO(9-11) | 13.04 | |
| 221 | 24-4 | PO(9-11) | 13.04 | |
| 222 | 24-4 | PO(9-11) | 13.06 | |



Node Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Node | Elevation(Foot) | Fittings | Pressure(psi) | Discharge(gpm) |
|------|-----------------|----------|---------------|----------------|
| 223 | 24-4 | PO(9-11) | 13.07 | |
| 224 | 24-4 | PO(9-11) | 13.12 | |
| 225 | 24-4 | PO(9-11) | 13.12 | |
| 226 | 24-4 | fE(5-0) | 16.98 | |
| 227 | 24-11½ | PO(5-0) | 11.55 | |
| 228 | 24-11½ | PO(5-0) | 12.79 | |
| 229 | 24-11½ | PO(5-0) | 11.92 | |
| 230 | 24-11½ | PO(5-0) | 11.32 | |
| 231 | 24-11½ | PO(5-0) | 11.29 | |
| 232 | 24-11½ | PO(5-0) | 12.84 | |
| 233 | 24-3½ | PO(5-0) | 13.01 | |
| 234 | 24-11½ | PO(5-0) | 12.64 | |
| 235 | 24-3½ | PO(5-0) | 11.77 | |
| 236 | 24-11½ | PO(5-0) | 11.07 | |
| 237 | 24-11½ | PO(5-0) | 10.97 | |
| 238 | 24-11½ | PO(5-0) | 10.93 | |
| 239 | 24-11½ | PO(5-0) | 11.71 | |
| 240 | 26-9½ | PO(5-0) | 9.99 | |
| 241 | 27-1 | PO(5-0) | 11.76 | |
| 242 | 23-10 | PO(5-0) | 12.11 | |
| 243 | 24-9½ | E(2-0) | 10.73 | |
| 244 | 18-4½ | PO(26-4) | 20.61 | |
| 245 | 12-0 | E(13-2) | 23.67 | |
| 246 | 11-10 | E(13-2) | 23.78 | |
| 247 | 18-4½ | PO(26-4) | 20.68 | |
| 248 | 20-3½ | fE(6-9½) | 19.79 | |
| 249 | 20-4 | fE(6-9½) | 19.81 | |
| 250 | 10-6 | fT(16-0) | 24.78 | |
| 251 | 10-6 | fT(16-0) | 24.78 | |
| 754 | 12-0½ | fE(6-9½) | 26.84 | |
| 818 | 12-0½ | fT(16-0) | 25.98 | |
| 860 | 10-6 | fE(6-9½) | 25.10 | |
| 861 | 12-0 | fE(6-9½) | 24.60 | |
| 905 | 12-0 | E(10-0) | 23.87 | |
| 907 | 11-10 | E(10-0) | 23.96 | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|--------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| Route 1 | | | | | | | | |
| DY | 1.0490 | 14.21 | 5.28 | 120 | | 0.069147 | 0-0 | Pf 1.94 |
| 2010 | 23-2 | 14.21 | 4.2 | 11.45 | | Sprinkler, | 28-0 | Pe -1.28 |
| 203 | 26-1½ | | | 12.10 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.21 | 2.05 | 120 | | 0.006937 | 13-0 | Pf 0.19 |
| 203 | 26-1½ | | | 12.10 | | | 14-10 | Pe 0.77 |
| 218 | 24-4 | | | 13.07 | | 2LtE(2-5½), PO(9-11) | 27-10 | Pv |
| CM | 3.2600 | 82.21 | 3.16 | 120 | | 0.007111 | 2-7½ | Pf 0.02 |
| 218 | 24-4 | 68.00 | | 13.07 | | Flow (q) from Route 2 | | Pe |
| 217 | 24-4 | | | 13.09 | | | 2-7½ | Pv |
| CM | 3.2600 | 135.64 | 5.21 | 120 | | 0.017955 | 9-8½ | Pf 0.17 |
| 217 | 24-4 | 53.42 | | 13.09 | | Flow (q) from Route 4 | | Pe |
| 216 | 24-4 | | | 13.26 | | | 9-8½ | Pv |
| CM | 3.2600 | 176.63 | 6.79 | 120 | | 0.029266 | 1-0 | Pf 0.03 |
| 216 | 24-4 | 41.00 | | 13.26 | | Flow (q) from Route 12 | | Pe |
| 215 | 24-4 | | | 13.29 | | | 1-0 | Pv |
| CM | 3.2600 | 205.50 | 7.90 | 120 | | 0.038723 | 5-3½ | Pf 0.20 |
| 215 | 24-4 | 28.86 | | 13.29 | | Flow (q) from Route 28 | | Pe |
| 214 | 24-4 | | | 13.50 | | | 5-3½ | Pv |
| CM | 3.2600 | 233.79 | 8.99 | 120 | | 0.049161 | 1-2½ | Pf 0.06 |
| 214 | 24-4 | 28.30 | | 13.50 | | Flow (q) from Route 25 | | Pe |
| 213 | 24-4 | | | 13.56 | | | 1-2½ | Pv |
| CM | 3.2600 | 248.26 | 9.54 | 120 | | 0.054936 | 1-8 | Pf 0.09 |
| 213 | 24-4 | 14.47 | | 13.56 | | Flow (q) from Route 33 | | Pe |
| 212 | 24-4 | | | 13.65 | | | 1-8 | Pv |
| CM | 3.2600 | 262.88 | 10.10 | 120 | | 0.061070 | 40-4½ | Pf 3.08 |
| 212 | 24-4 | 14.62 | | 13.65 | | Flow (q) from Route 35 | 10-0 | Pe 0.38 |
| 211 | 23-5½ | | | 17.11 | | 2fE(5-0) | 50-4½ | Pv |
| CM | 4.2600 | 262.88 | 5.92 | 120 | | 0.016595 | 38-9½ | Pf 1.31 |
| 211 | 23-5½ | | | 17.11 | | | 39-11 | Pe 2.20 |
| 244 | 18-4½ | | | 20.61 | | 2fE(6-9½), PO(26-4) | 78-8½ | Pv |
| CM | 4.2600 | 247.96 | 5.58 | 120 | | 0.014895 | 6-4½ | Pf 0.29 |
| 244 | 18-4½ | | | 20.61 | | | 13-2 | Pe 2.76 |
| 245 | 12-0 | | | 23.67 | | E(13-2) | 19-6½ | Pv |
| CM | 4.0260 | 247.96 | 6.25 | 120 | | 0.019612 | 0-0 | Pf 0.20 |
| 245 | 12-0 | | | 23.67 | | | 10-0 | Pe 0.00 |
| 905 | 12-0 | | | 23.87 | | E(10-0) | 10-0 | Pv |
| CM | 4.2600 | 247.96 | 5.58 | 120 | | 0.014895 | 1-6 | Pf 0.26 |
| 905 | 12-0 | | | 23.87 | | | 16-0 | Pe 0.65 |
| 250 | 10-6 | | | 24.78 | | fT(16-0) | 17-6 | Pv |
| CM | 4.2600 | 248.81 | 5.60 | 120 | | 0.014989 | 81-7½ | Pf 1.87 |
| 250 | 10-6 | 0.85 | | 24.78 | | Flow (q) from Route 36 | 43-2 | Pe -0.66 |
| 818 | 12-0½ | | | 25.98 | | 4fE(6-9½), fT(16-0) | 124-9½ | Pv |
| CM | 4.2600 | 484.73 | 10.91 | 120 | | 0.051477 | 9-10½ | Pf 0.86 |
| 818 | 12-0½ | 235.93 | | 25.98 | | Flow (q) from Route 3 | 6-9½ | Pe |
| 754 | 12-0½ | | | 26.84 | | fE(6-9½) | 16-8 | Pv |
| CM | 4.0260 | 484.73 | 12.22 | 120 | | 0.067780 | 11-0 | Pf 3.84 |
| 754 | 12-0½ | | | 26.84 | | | 45-7 | Pe 4.35 |
| 9 | 2-0 | | | 35.03 | | 2fE(6-9½), BV(12-0), PO(20-0) | 56-7 | Pv |
| UG | 6.3570 | 484.73 | 4.90 | 120 | | 0.007328 | 2-10 | Pf 0.10 |
| 9 | 2-0 | | | 35.03 | | | 11-4 | Pe 0.87 |
| 7 | 0-0 | | | 36.00 | | LtE(11-4) | 14-2 | Pv |
| UG | 6.2800 | 484.73 | 5.02 | 140 | | 0.005847 | 168-7 | Pf 6.78 |
| 7 | 0-0 | | | 36.00 | | | 135-6½ | Pe 1.73 |
| 8 | -4-0 | | | 44.51 | | 4E(22-1), BFP(-5.00), T(47-3½) | 304-1 | Pv |
| UG | 8.3900 | 484.73 | 2.81 | 140 | | 0.001426 | 50-8½ | Pf 0.07 |
| 8 | -4-0 | | | 44.51 | | | | Pe |
| 1 | -4-0 | | | 44.58 | | Water Supply | 50-8½ | Pv |
| | | 100.00 | | | | Hose Allowance At Source | | |
| 1 | | 584.73 | | | | | | |
| Route 2 | | | | | | | | |
| DY | 1.0490 | 14.22 | 5.28 | 120 | | 0.069225 | 0-0 | Pf 1.94 |
| 2019 | 23-2 | 14.22 | 4.2 | 11.46 | | Sprinkler, | 28-0 | Pe -0.78 |
| 205 | 24-11½ | | | 12.62 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.22 | 2.05 | 120 | | 0.006945 | 9-0½ | Pf 0.15 |
| 205 | 24-11½ | | | 12.62 | | | 12-4½ | Pe 0.28 |
| 220 | 24-4 | | | 13.04 | | LtE(2-5½), PO(9-11) | 21-5 | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| CM | 3.2600 | 14.83 | 0.57 | 120 | | 0.000299 | 10-7½ | Pf 0.00 |
| 220 | 24-4 | 0.61 | | 13.04 | | Flow (q) from Route 38 | | Pe |
| 219 | 24-4 | | | 13.05 | | | 10-7½ | Pv |
| CM | 3.2600 | 68.00 | 2.61 | 120 | | 0.005006 | 5-0½ | Pf 0.03 |
| 219 | 24-4 | 53.18 | | 13.05 | | Flow (q) from Route 5 | | Pe |
| 218 | 24-4 | | | 13.07 | | | 5-0½ | Pv |
| Route 3 | | | | | | | | |
| DY | 1.0490 | 13.96 | 5.18 | 120 | | 0.066900 | 0-0 | Pf 1.87 |
| 2029 | 22-8 | 13.96 | 4.2 | 11.05 | | Sprinkler, | 28-0 | Pe -0.99 |
| 229 | 24-11½ | | | 11.92 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 42.08 | 6.08 | 120 | | 0.051695 | 5-5 | Pf 0.92 |
| 229 | 24-11½ | 28.12 | | 11.92 | | Flow (q) from Route 20 | 12-4½ | Pe 0.27 |
| 224 | 24-4 | | | 13.12 | | LtE(2-5½), PO(9-11) | 17-9½ | Pv |
| CM | 3.2600 | 137.31 | 5.28 | 120 | | 0.018368 | 0-6 | Pf 0.01 |
| 224 | 24-4 | 95.23 | | 13.12 | | Flow (q) from Route 6 | | Pe |
| 225 | 24-4 | | | 13.12 | | | 0-6 | Pv |
| CM | 3.2600 | 165.12 | 6.35 | 120 | | 0.025835 | 7-6½ | Pf 0.45 |
| 225 | 24-4 | 27.80 | | 13.12 | | Flow (q) from Route 22 | 10-0 | Pe 0.00 |
| 208 | 24-4 | | | 13.58 | | 2fE(5-0) | 17-6½ | Pv |
| CM | 3.2600 | 193.14 | 7.42 | 120 | | 0.034526 | 0-9 | Pf 0.03 |
| 208 | 24-4 | 28.02 | | 13.58 | | Flow (q) from Route 24 | | Pe |
| 209 | 24-4 | | | 13.60 | | | 0-9 | Pv |
| CM | 3.2600 | 221.86 | 8.53 | 120 | | 0.044619 | 50-10 | Pf 3.38 |
| 209 | 24-4 | 28.72 | | 13.60 | | Flow (q) from Route 31 | 25-0 | Pe -0.01 |
| 226 | 24-4 | | | 16.98 | | 5fE(5-0) | 75-10 | Pv |
| CM | 4.2600 | 221.86 | 4.99 | 120 | | 0.012125 | 37-7½ | Pf 1.10 |
| 226 | 24-4 | | | 16.98 | | | 53-6 | Pe 2.59 |
| 247 | 18-4½ | | | 20.68 | | 4fE(6-9½), PO(26-4) | 91-1½ | Pv |
| CM | 4.2600 | 236.78 | 5.33 | 120 | | 0.013676 | 6-6½ | Pf 0.27 |
| 247 | 18-4½ | 14.92 | | 20.68 | | Flow (q) from Route 37 | 13-2 | Pe 2.84 |
| 246 | 11-10 | | | 23.78 | | E(13-2) | 19-8½ | Pv |
| CM | 4.0260 | 236.78 | 5.97 | 120 | | 0.018007 | 0-0 | Pf 0.18 |
| 246 | 11-10 | | | 23.78 | | | 10-0 | Pe -0.00 |
| 907 | 11-10 | | | 23.96 | | E(10-0) | 10-0 | Pv |
| CM | 4.2600 | 236.78 | 5.33 | 120 | | 0.013676 | 1-4 | Pf 0.24 |
| 907 | 11-10 | | | 23.96 | | | 16-0 | Pe 0.58 |
| 251 | 10-6 | | | 24.78 | | fT(16-0) | 17-4 | Pv |
| CM | 4.2600 | 235.93 | 5.31 | 120 | | 0.013585 | 16-11½ | Pf 0.32 |
| 251 | 10-6 | | | 24.78 | | | 6-9½ | Pe |
| 860 | 10-6 | | | 25.10 | | fE(6-9½) | 23-9 | Pv |
| CM | 4.0260 | 235.93 | 5.95 | 120 | | 0.017888 | 1-6 | Pf 0.15 |
| 860 | 10-6 | | | 25.10 | | | 6-9½ | Pe -0.65 |
| 861 | 12-0 | | | 24.60 | | fE(6-9½) | 8-3½ | Pv |
| CM | 4.2600 | 235.93 | 5.31 | 120 | | 0.013585 | 87-0½ | Pf 1.40 |
| 861 | 12-0 | | | 24.60 | | | 16-0 | Pe -0.01 |
| 818 | 12-0½ | | | 25.98 | | fT(16-0) | 103-0½ | Pv |
| Route 4 | | | | | | | | |
| BL | 1.0490 | 13.05 | 4.84 | 120 | | 0.059037 | 0-8½ | Pf 0.34 |
| 2013 | 26-9½ | 13.05 | 4.2 | 9.65 | | Sprinkler, | 5-0 | Pe |
| 240 | 26-9½ | | | 9.99 | | PO(5-0) | 5-8½ | Pv |
| BL | 1.6820 | 26.57 | 3.84 | 120 | | 0.022088 | 8-1 | Pf 0.29 |
| 240 | 26-9½ | 13.53 | | 9.99 | | Flow (q) from Route 13 | 4-11½ | Pe 0.79 |
| 236 | 24-11½ | | | 11.07 | | 2LtE(2-5½) | 13-0½ | Pv |
| BL | 1.6820 | 40.06 | 5.78 | 120 | | 0.047187 | 10-0½ | Pf 0.47 |
| 236 | 24-11½ | 13.48 | | 11.07 | | Flow (q) from Route 11 | | Pe 0.01 |
| 227 | 24-11½ | | | 11.55 | | | 10-0½ | Pv |
| BL | 1.6820 | 53.42 | 7.71 | 120 | | 0.080381 | 3-5 | Pf 1.27 |
| 227 | 24-11½ | 13.37 | | 11.55 | | Flow (q) from Route 9 | 12-4½ | Pe 0.27 |
| 217 | 24-4 | | | 13.09 | | LtE(2-5½), PO(9-11) | 15-9½ | Pv |
| Route 5 | | | | | | | | |
| DY | 1.0490 | 13.05 | 4.84 | 120 | | 0.059058 | 0-0 | Pf 2.30 |
| 2016 | 22-8 | 13.05 | 4.2 | 9.65 | | Sprinkler, | 39-0 | Pe -0.99 |
| 237 | 24-11½ | | | 10.97 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| BL | 1.6820 | 39.94 | 5.77 | 120 | | 0.046924 | 7-6½ | Pf 0.35 |
| 237 | 24-11½ | 26.89 | | 10.97 | | Flow (q) from Route 8 | | Pe -0.00 |
| 230 | 24-11½ | | | 11.32 | | | 7-6½ | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|------------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| BL | 1.6820 | 53.18 | 7.68 | 120 | | 0.079707 | 5-11 | Pf 1.46 |
| 230 | 24-11½ | 13.24 | | 11.32 | | Flow (q) from Route 7 | 12-4½ | Pe 0.27 |
| 219 | 24-4 | | | 13.05 | | LtE(2-5½), PO(9-11) | 18-3½ | Pv |
| Route 6 | | | | | | | | |
| BL | 1.6820 | 26.77 | 3.87 | 120 | | 0.022396 | 12-6½ | Pf 0.45 |
| 2022 | 26-3 | 13.55 | 4.2 | 9.92 | | Sprinkler,, Flow (q) from Route 14 | 7-5 | Pe 0.56 |
| 238 | 24-11½ | | | 10.93 | | 3LtE(2-5½) | 20-0 | Pv |
| BL | 1.6820 | 40.18 | 5.80 | 120 | | 0.047448 | 7-6½ | Pf 0.36 |
| 238 | 24-11½ | 13.40 | | 10.93 | | Flow (q) from Route 10 | | Pe -0.00 |
| 231 | 24-11½ | | | 11.29 | | | 7-6½ | Pv |
| BL | 1.6820 | 53.78 | 7.77 | 120 | | 0.081380 | 5-11 | Pf 1.49 |
| 231 | 24-11½ | 13.60 | | 11.29 | | Flow (q) from Route 16 | 12-4½ | Pe 0.27 |
| 221 | 24-4 | | | 13.04 | | LtE(2-5½), PO(9-11) | 18-3½ | Pv |
| CM | 3.2600 | 53.17 | 2.04 | 120 | | 0.003175 | 6-6½ | Pf 0.02 |
| 221 | 24-4 | | | 13.04 | | | | Pe |
| 222 | 24-4 | | | 13.06 | | | 6-6½ | Pv |
| CM | 3.2600 | 80.89 | 3.11 | 120 | | 0.006901 | 1-7½ | Pf 0.01 |
| 222 | 24-4 | 27.72 | | 13.06 | | Flow (q) from Route 19 | | Pe |
| 223 | 24-4 | | | 13.07 | | | 1-7½ | Pv |
| CM | 3.2600 | 95.23 | 3.66 | 120 | | 0.009333 | 4-5½ | Pf 0.04 |
| 223 | 24-4 | 14.34 | | 13.07 | | Flow (q) from Route 30 | | Pe |
| 224 | 24-4 | | | 13.12 | | | 4-5½ | Pv |
| Route 7 | | | | | | | | |
| DY | 1.0490 | 13.24 | 4.92 | 120 | | 0.060699 | 0-0 | Pf 2.37 |
| 2015 | 22-8 | 13.24 | 4.2 | 9.94 | | Sprinkler, | 39-0 | Pe -0.99 |
| 230 | 24-11½ | | | 11.32 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| Route 8 | | | | | | | | |
| BL | 1.6820 | 26.89 | 3.88 | 120 | | 0.022570 | 10-3½ | Pf 0.40 |
| 2017 | 26-3 | 13.60 | 4.2 | 10.01 | | Sprinkler,, Flow (q) from Route 15 | 7-5 | Pe 0.56 |
| 237 | 24-11½ | | | 10.97 | | 3LtE(2-5½) | 17-8½ | Pv |
| Route 9 | | | | | | | | |
| DY | 1.0490 | 13.37 | 4.96 | 120 | | 0.061734 | 0-0 | Pf 2.41 |
| 2011 | 22-8 | 13.37 | 4.2 | 10.13 | | Sprinkler, | 39-0 | Pe -0.99 |
| 227 | 24-11½ | | | 11.55 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| Route 10 | | | | | | | | |
| DY | 1.0490 | 13.40 | 4.97 | 120 | | 0.062042 | 0-0 | Pf 1.74 |
| 2021 | 22-8 | 13.40 | 4.2 | 10.18 | | Sprinkler, | 28-0 | Pe -0.99 |
| 238 | 24-11½ | | | 10.93 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 11 | | | | | | | | |
| DY | 1.0490 | 13.48 | 5.00 | 120 | | 0.062730 | 0-0 | Pf 1.76 |
| 2012 | 22-8 | 13.48 | 4.2 | 10.30 | | Sprinkler, | 28-0 | Pe -0.99 |
| 236 | 24-11½ | | | 11.07 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 12 | | | | | | | | |
| BL | 1.6820 | 27.29 | 3.94 | 120 | | 0.023194 | 10-3½ | Pf 0.53 |
| 2008 | 26-5 | 13.80 | 4.2 | 10.31 | | Sprinkler,, Flow (q) from Route 18 | 12-4½ | Pe 0.93 |
| 235 | 24-3½ | | | 11.77 | | 5LtE(2-5½) | 22-8 | Pv |
| BL | 1.6820 | 41.00 | 5.92 | 120 | | 0.049259 | 13-5½ | Pf 1.52 |
| 235 | 24-3½ | 13.71 | | 11.77 | | Flow (q) from Route 17 | 17-4 | Pe -0.02 |
| 216 | 24-4 | | | 13.26 | | 3LtE(2-5½), PO(9-11) | 30-9½ | Pv |
| Route 13 | | | | | | | | |
| BL | 1.0490 | 13.53 | 5.02 | 120 | | 0.063140 | 3-7½ | Pf 0.35 |
| 2014 | 24-9½ | 13.53 | 4.2 | 10.38 | | Sprinkler, | 2-0 | Pe |
| 243 | 24-9½ | | | 10.73 | | E(2-0) | 5-7½ | Pv |
| BL | 1.6820 | 13.53 | 1.95 | 120 | | 0.006334 | 16-8½ | Pf 0.12 |
| 243 | 24-9½ | | | 10.73 | | | 2-5½ | Pe -0.87 |
| 240 | 26-9½ | | | 9.99 | | LtE(2-5½) | 19-2 | Pv |
| Route 14 | | | | | | | | |
| BL | 1.6820 | 13.55 | 1.96 | 120 | | 0.006349 | 8-1 | Pf 0.05 |
| 2023 | 25-0 | 13.55 | 4.2 | 10.40 | | Sprinkler | | Pe -0.53 |
| 2022 | 26-3 | | | 9.92 | | | 8-1 | Pv |
| Route 15 | | | | | | | | |
| BL | 1.6820 | 13.60 | 1.96 | 120 | | 0.006397 | 8-1 | Pf 0.05 |
| 2018 | 25-0 | 13.60 | 4.2 | 10.49 | | Sprinkler | | Pe -0.53 |
| 2017 | 26-3 | | | 10.01 | | | 8-1 | Pv |
| Route 16 | | | | | | | | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| DY | 1.0490 | 13.60 | 5.05 | 120 | 0.063785 | 0-0 | Pf 1.79 |
| 2020 | 22-8 | 13.60 | 4.2 | 10.49 | Sprinkler, | 28-0 | Pe -0.99 |
| 231 | 24-11½ | | 11.29 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 17 | | | | | | | |
| DY | 1.0490 | 13.71 | 5.09 | 120 | 0.064726 | 0-0 | Pf 1.81 |
| 2007 | 22-8 | 13.71 | 4.2 | 10.66 | Sprinkler, | 28-0 | Pe -0.70 |
| 235 | 24-3½ | | 11.77 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 18 | | | | | | | |
| BL | 1.6820 | 13.80 | 1.99 | 120 | 0.006569 | 8-0½ | Pf 0.05 |
| 2009 | 25-2½ | 13.80 | 4.2 | 10.79 | Sprinkler | 8-0½ | Pe -0.53 |
| 2008 | 26-5 | | 10.31 | | | | Pv |
| Route 19 | | | | | | | |
| DY | 1.0490 | 13.84 | 5.14 | 120 | 0.065840 | 0-0 | Pf 1.84 |
| 2024 | 24-3 | 13.84 | 4.2 | 10.86 | Sprinkler, | 28-0 | Pe -0.32 |
| 201 | 24-11½ | | 12.38 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 13.84 | 2.00 | 120 | 0.006605 | 11-5½ | Pf 0.08 |
| 201 | 24-11½ | | 12.38 | | | | Pe 0.01 |
| 207 | 24-11½ | | 12.47 | | | 11-5½ | Pv |
| BL | 1.6820 | 27.72 | 4.00 | 120 | 0.023879 | 1-2 | Pf 0.32 |
| 207 | 24-11½ | 13.88 | | 12.47 | Flow (q) from Route 21 | 12-4½ | Pe 0.27 |
| 222 | 24-4 | | 13.06 | | LtE(2-5½), PO(9-11) | 13-6½ | Pv |
| Route 20 | | | | | | | |
| DY | 1.0490 | 13.84 | 5.14 | 120 | 0.065847 | 0-0 | Pf 1.84 |
| 2030 | 22-8 | 13.84 | 4.2 | 10.86 | Sprinkler, | 28-0 | Pe -0.99 |
| 239 | 24-11½ | | 11.71 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 28.12 | 4.06 | 120 | 0.024527 | 8-10½ | Pf 0.22 |
| 239 | 24-11½ | 14.28 | 11.71 | | Flow (q) from Route 29 | | Pe |
| 229 | 24-11½ | | 11.92 | | | 8-10½ | Pv |
| Route 21 | | | | | | | |
| DY | 1.0490 | 13.88 | 5.15 | 120 | 0.066208 | 0-0 | Pf 1.85 |
| 2025 | 24-3 | 13.88 | 4.2 | 10.92 | Sprinkler, | 28-0 | Pe -0.31 |
| 207 | 24-11½ | | 12.47 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 22 | | | | | | | |
| DY | 1.0490 | 13.88 | 5.15 | 120 | 0.066222 | 0-0 | Pf 1.85 |
| 2027 | 24-3 | 13.88 | 4.2 | 10.92 | Sprinkler, | 28-0 | Pe -0.31 |
| 202 | 24-11½ | | 12.46 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 13.88 | 2.00 | 120 | 0.006644 | 11-2 | Pf 0.07 |
| 202 | 24-11½ | | 12.46 | | | | Pe 0.01 |
| 210 | 24-11½ | | 12.55 | | | 11-2 | Pv |
| BL | 1.6820 | 27.80 | 4.01 | 120 | 0.024015 | 0-5½ | Pf 0.31 |
| 210 | 24-11½ | 13.92 | 12.55 | | Flow (q) from Route 23 | 12-4½ | Pe 0.27 |
| 225 | 24-4 | | 13.12 | | LtE(2-5½), PO(9-11) | 12-10 | Pv |
| Route 23 | | | | | | | |
| DY | 1.0490 | 13.92 | 5.17 | 120 | 0.066581 | 0-0 | Pf 1.86 |
| 2028 | 24-3 | 13.92 | 4.2 | 10.99 | Sprinkler, | 28-0 | Pe -0.31 |
| 210 | 24-11½ | | 12.55 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 24 | | | | | | | |
| DY | 1.0490 | 13.97 | 5.19 | 120 | 0.067006 | 0-0 | Pf 2.61 |
| 2035 | 22-8 | 13.97 | 4.2 | 11.06 | Sprinkler, | 39-0 | Pe -1.91 |
| 241 | 27-1 | | 11.76 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| BL | 1.6820 | 13.97 | 2.02 | 120 | 0.006722 | 15-6 | Pf 0.15 |
| 241 | 27-1 | | 11.76 | | | 7-5 | Pe 0.92 |
| 232 | 24-11½ | | 12.84 | | 3LtE(2-5½) | 22-11 | Pv |
| BL | 1.6820 | 28.02 | 4.05 | 120 | 0.024362 | 6-10½ | Pf 0.47 |
| 232 | 24-11½ | 14.05 | 12.84 | | Flow (q) from Route 26 | 12-4½ | Pe 0.27 |
| 208 | 24-4 | | 13.58 | | LtE(2-5½), PO(9-11) | 19-3 | Pv |
| Route 25 | | | | | | | |
| DY | 1.0490 | 14.03 | 5.21 | 120 | 0.067492 | 0-0 | Pf 2.63 |
| 2003 | 22-8 | 14.03 | 4.2 | 11.15 | Sprinkler, | 39-0 | Pe -0.99 |
| 228 | 24-11½ | | 12.79 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| BL | 1.6820 | 28.30 | 4.09 | 120 | 0.024807 | 5-2½ | Pf 0.44 |
| 228 | 24-11½ | 14.27 | 12.79 | | Flow (q) from Route 27 | 12-4½ | Pe 0.27 |
| 214 | 24-4 | | 13.50 | | LtE(2-5½), PO(9-11) | 17-7 | Pv |
| Route 26 | | | | | | | |
| DY | 1.0490 | 14.05 | 5.22 | 120 | 0.067714 | 0-0 | Pf 2.64 |
| 2034 | 22-8 | 14.05 | 4.2 | 11.19 | Sprinkler, | 39-0 | Pe -0.99 |
| 232 | 24-11½ | | 12.84 | | PO(5-0), fd(34-0) | 39-0 | Pv |
| Route 27 | | | | | | | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|----------------------|-----------|-----------|----------|-------|---------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| DY | 1.0490 | 14.27 | 5.30 | 120 | 0.069698 | 0-0 | Pf 1.95 |
| 2004 | 23-2 | 14.27 | 4.2 | 11.55 | Sprinkler, | 28-0 | Pe -0.49 |
| 233 | 24-3½ | | | 13.01 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.27 | 2.06 | 120 | 0.006992 | 4-11½ | Pf 0.07 |
| 233 | 24-3½ | | | 13.01 | | 4-11½ | Pe -0.29 |
| 228 | 24-11½ | | | 12.79 | 2LtE(2-5½) | 9-11 | Pv |
| ***** Route 28 ***** | | | | | | | |
| BL | 1.6820 | 28.86 | 4.17 | 120 | 0.025736 | 7-3½ | Pf 0.57 |
| 2006 | 27-0½ | 14.59 | 4.2 | 11.56 | Sprinkler,, Flow (q) from Route | 14-10 | Pe 1.17 |
| 215 | 24-4 | | | 13.29 | 34 | 22-1½ | Pv |
| | | | | | 2LtE(2-5½), PO(9-11) | | |
| ***** Route 29 ***** | | | | | | | |
| DY | 1.0490 | 14.28 | 5.30 | 120 | 0.069813 | 0-0 | Pf 1.95 |
| 2031 | 20-7 | 14.28 | 4.2 | 11.57 | Sprinkler, | 28-0 | Pe -1.41 |
| 242 | 23-10 | | | 12.11 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.28 | 2.06 | 120 | 0.007004 | 12-0½ | Pf 0.08 |
| 242 | 23-10 | | | 12.11 | | | Pe -0.48 |
| 239 | 24-11½ | | | 11.71 | | 12-0½ | Pv |
| ***** Route 30 ***** | | | | | | | |
| DY | 1.0490 | 14.34 | 5.32 | 120 | 0.070335 | 0-0 | Pf 1.97 |
| 2026 | 22-8 | 14.34 | 4.2 | 11.66 | Sprinkler, | 28-0 | Pe -0.99 |
| 234 | 24-11½ | | | 12.64 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.34 | 2.07 | 120 | 0.007056 | 11-4½ | Pf 0.17 |
| 234 | 24-11½ | | | 12.64 | | 12-4½ | Pe 0.27 |
| 223 | 24-4 | | | 13.07 | LtE(2-5½), PO(9-11) | 23-9 | Pv |
| ***** Route 31 ***** | | | | | | | |
| DY | 1.0490 | 14.34 | 5.33 | 120 | 0.070365 | 0-0 | Pf 1.97 |
| 2032 | 23-2 | 14.34 | 4.2 | 11.67 | Sprinkler, | 28-0 | Pe -0.79 |
| 200 | 24-11½ | | | 12.85 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.34 | 2.07 | 120 | 0.007059 | 7-9 | Pf 0.05 |
| 200 | 24-11½ | | | 12.85 | | | Pe 0.00 |
| 206 | 24-11½ | | | 12.90 | | 7-9 | Pv |
| BL | 1.6820 | 28.72 | 4.15 | 120 | 0.025497 | 4-5½ | Pf 0.43 |
| 206 | 24-11½ | 14.37 | | 12.90 | Flow (q) from Route 32 | 12-4½ | Pe 0.27 |
| 209 | 24-4 | | | 13.60 | LtE(2-5½), PO(9-11) | 16-10 | Pv |
| ***** Route 32 ***** | | | | | | | |
| DY | 1.0490 | 14.37 | 5.34 | 120 | 0.070630 | 0-0 | Pf 1.98 |
| 2033 | 23-2 | 14.37 | 4.2 | 11.71 | Sprinkler, | 28-0 | Pe -0.79 |
| 206 | 24-11½ | | | 12.90 | PO(5-0), fd(23-0) | 28-0 | Pv |
| ***** Route 33 ***** | | | | | | | |
| DY | 1.0490 | 14.47 | 5.37 | 120 | 0.071467 | 0-0 | Pf 2.00 |
| 2001 | 23-2 | 14.47 | 4.2 | 11.86 | Sprinkler, | 28-0 | Pe -1.29 |
| 204 | 26-1½ | | | 12.58 | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 14.47 | 2.09 | 120 | 0.007170 | 12-10½ | Pf 0.20 |
| 204 | 26-1½ | | | 12.58 | | 14-10 | Pe 0.78 |
| 213 | 24-4 | | | 13.56 | 2LtE(2-5½), PO(9-11) | 27-9 | Pv |
| ***** Route 34 ***** | | | | | | | |
| BL | 1.6820 | 14.59 | 2.11 | 120 | 0.007281 | 8-2 | Pf 0.06 |
| 2005 | 25-8½ | 14.59 | 4.2 | 12.06 | Sprinkler | | Pe -0.57 |
| 2006 | 27-0½ | | | 11.56 | | 8-2 | Pv |
| ***** Route 35 ***** | | | | | | | |
| DY | 1.0490 | 14.62 | 5.43 | 120 | 0.072866 | 0-0 | Pf 2.04 |
| 2002 | 23-2 | 14.62 | 4.2 | 12.11 | Sprinkler, | 28-0 | Pe -0.51 |
| 212 | 24-4 | | | 13.65 | PO(5-0), fd(23-0) | 28-0 | Pv |
| ***** Route 36 ***** | | | | | | | |
| CM | 3.2600 | 0.85 | 0.03 | 120 | 0.000002 | 181-0 | Pf 0.00 |
| 251 | 10-6 | | | 24.78 | | 20-0 | Pe |
| 250 | 10-6 | | | 24.78 | 4fE(5-0) | 201-0 | Pv |
| ***** Route 37 ***** | | | | | | | |
| CM | 4.2600 | 14.92 | 0.34 | 120 | 0.000082 | 35-10½ | Pf 0.01 |
| 244 | 18-4½ | | | 20.61 | PO(26-4) | 53-6 | Pe -0.84 |
| 248 | 20-3½ | | | 19.79 | 4fE(6-9½) | 89-4½ | Pv |
| CM | 3.2600 | 14.92 | 0.57 | 120 | 0.000303 | 147-8 | Pf 0.05 |
| 248 | 20-3½ | | | 19.79 | | 6-9½ | Pe -0.02 |
| 249 | 20-4 | | | 19.81 | fE(6-9½) | 154-5½ | Pv |
| CM | 4.2600 | 14.92 | 0.34 | 120 | 0.000082 | 35-11½ | Pf 0.01 |
| 249 | 20-4 | | | 19.81 | | 46-8½ | Pe 0.85 |
| 247 | 18-4½ | | | 20.68 | 3fE(6-9½), PO(26-4) | 82-8 | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Light Hazard - Level 2 - Reception - Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | | Length | Pressure |
|------------|-----------|-----------|----------|-------|---------------|----------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| Route 38 | | | | | | | | |
| CM | 3.2600 | 0.61 | 0.02 | 120 | | 0.000001 | 1-4½ | Pf 0.00 |
| 221 | 24-4 | | | 13.04 | | | | Pe |
| 220 | 24-4 | | | 13.04 | | | 1-4½ | Pv |

| Equivalent Pipe Lengths of Valves and Fittings (C=120 only) | | | | C Value Multiplier | | | |
|-----------------------------------------------------------------------------------------------------------------------------|--|--|--|--------------------|-------|------|------|
| $\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$ | | | | Value Of C | 100 | 130 | 140 |
| | | | | Multiplying Factor | 0.713 | 1.16 | 1.33 |
| | | | | | | | 150 |
| | | | | | | | 1.51 |

| Pipe Type Legend | | Units Legend | | Fittings Legend | |
|------------------|---------------|---------------|---------------------------------------------------------------|-----------------|----------------------------|
| AO | Arm-Over | Diameter | Inch | ALV | Alarm Valve |
| BL | Branch Line | Elevation | Foot | AngV | Angle Valve |
| CM | Cross Main | Flow | gpm | b | Bushing |
| DN | Drain | Discharge | gpm | BaV | Ball Valve |
| DR | Drop | Velocity | fps | BFP | Backflow Preventer |
| DY | Dynamic | Pressure | psi | BV | Butterfly Valve |
| FM | Feed Main | Length | Foot | C | Cross Flow Turn 90° |
| FR | Feed Riser | Friction Loss | psi/Foot | cplg | Coupling |
| MS | Miscellaneous | HWC | Hazen-Williams Constant | Cr | Cross Run |
| OR | Outrigger | Pt | Total pressure at a point in a pipe | CV | Check Valve |
| RN | Riser Nipple | Pn | Normal pressure at a point in a pipe | DeV | Deluge Valve |
| SP | Sprig | Pf | Pressure loss due to friction between points | DPV | Dry Pipe Valve |
| ST | Stand Pipe | Pe | Pressure due to elevation difference between indicated points | E | 90° Elbow |
| UG | Underground | Pv | Velocity pressure at a point in a pipe | EE | 45° Elbow |
| | | | | Ee1 | 11¼° Elbow |
| | | | | Ee2 | 22½° Elbow |
| | | | | f | Flow Device |
| | | | | fd | Flex Drop |
| | | | | FDC | Fire Department Connection |
| | | | | fE | 90° FireLock(TM) Elbow |
| | | | | fEE | 45° FireLock(TM) Elbow |
| | | | | flg | Flange |
| | | | | FN | Floating Node |
| | | | | fT | FireLock(TM) Tee |
| | | | | g | Gauge |
| | | | | GloV | Globe Valve |
| | | | | GV | Gate Valve |
| | | | | Ho | Hose |
| | | | | Hose | Hose |
| | | | | HV | Hose Valve |
| | | | | Hyd | Hydrant |
| | | | | LtE | Long Turn Elbow |
| | | | | mecT | Mechanical Tee |
| | | | | Noz | Nozzle |
| | | | | P1 | Pump In |
| | | | | P2 | Pump Out |
| | | | | PIV | Post Indicating Valve |
| | | | | PO | Pipe Outlet |
| | | | | PRV | Pressure Reducing Valve |
| | | | | PrV | Pressure Relief Valve |
| | | | | red | Reducer/Adapter |
| | | | | S | Supply |
| | | | | sCV | Swing Check Valve |
| | | | | Spr | Sprinkler |
| | | | | St | Strainer |
| | | | | T | Tee Flow Turn 90° |
| | | | | Tr | Tee Run |
| | | | | U | Union |
| | | | | WirF | Wirsbo |
| | | | | WMV | Water Meter Valve |
| | | | | Z | Cap |



Hydraulic Summary

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clean/Dry Floor Area

| | |
|-----------------------------------|------------------------------------------------------------------|
| Job | |
| Job Number S23-90 | Design Engineer Queen |
| Job Name: CHC Puyallup Cannery | State Certification/License Number ARCHEI*219DR |
| Address 1 201 W. Main St | AHU Puyallup |
| Address 2 Puyallup, WA 98371 | Job Site/Building Cannery |
| Address 3 | Drawing Name S23-090 - CHC Puyallup Cannery - 1-8th scale - L |

| | | | |
|-------------------------------------------------------------|-----------------------------------------------------|--------------------------------------------------------------------------------|--|
| System | | Remote Area(s) | |
| Most Demanding Sprinkler Data 4.2 K-Factor 11.11 at 7.00 | Occupancy Ordinary Group I - Level 2 - Clean/Dry | Job Suffix | |
| Hose Allowance At Source 250.00 | Density 0.12gpm/ft ² | Area of Application 3000.00ft ² (Actual 3029.16ft ²) | |
| Additional Hose Supplies Node Flow(gpm) | Number Of Sprinklers Calculated 44 | Coverage Per Sprinkler 225.00ft ² | |

REVOL

| | |
|----------------------------------------------------------------|-----------------------------------------------------------|
| Total Hose Streams 250.00 | |
| System Flow Demand 544.67 | Total Water Required (Including Hose Allowance) 794.67 |
| Maximum Pressure Unbalance In Loops 0.00 | |
| Maximum Velocity Above Ground 13.73 between nodes 9 and 754 | |
| Maximum Velocity Under Ground 5.64 between nodes 8 and 7 | |
| Volume capacity of Wet Pipes 1275.90gal | Volume capacity of Dry Pipes |

| | |
|---------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|
| Expires DEC 31, 24 | WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS |
| Theodore M. Queen 4930-0205-C Level 3 Archer Construction, Inc. ARCHEI*219DR | |
| <i>Jul Queen</i> Signature | 3-14-24 Date |

Supplies


| Node | Name | Hose Flow (gpm) | Static (psi) | Residual (psi) | @ Flow (gpm) | Available (psi) | @ Total Demand (gpm) | Required (psi) | Safety Margin (psi) |
|------|--------------|-----------------|--------------|----------------|--------------|-----------------|----------------------|----------------|---------------------|
| 1 | Water Supply | 250.00 | 51.00 | 38.00 | 2460.00 | 49.39 | 794.67 | 43.65 | 5.74 |

Contractor

| | | |
|--------------------------------------------|--------------|---------------|
| Contractor Number 22 | Contact Name | Contact Title |
| Name of Contractor: Archer Construction | Phone | Extension |
| Address 1 7855 South 206th ST | FAX | |
| Address 2 Kent, WA 98032 | E-mail | |
| Address 3 | Web Site | |



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static Pressure

51.00

Residual Pressure

38.00 @ 2460.00

Available Pressure at Time of Test

49.39 @ 794.67

System Demand

43.65 @ 544.67

System Demand (Including Hose Allowance at Source)

43.65 @ 794.67



Summary Of Outflowing Devices

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clean/Dry Floor Area

| Device | | Actual Flow (gpm) | Minimum Flow (gpm) | K-Factor (K) | Pressure (psi) | | |
|-------------|------|----------------------|-----------------------|-----------------|-------------------|--|--|
| Sprinkler | 3001 | 12.36 | 11.11 | 4.2 | 8.66 | | |
| Sprinkler | 3002 | 12.42 | 11.11 | 4.2 | 8.75 | | |
| Sprinkler | 3003 | 12.62 | 11.11 | 4.2 | 9.02 | | |
| Sprinkler | 3004 | 12.81 | 11.11 | 4.2 | 9.30 | | |
| Sprinkler | 3005 | 11.31 | 11.11 | 4.2 | 7.25 | | |
| ⇒ Sprinkler | 3006 | 11.11 | 11.11 | 4.2 | 7.00 | | |
| Sprinkler | 3007 | 11.44 | 11.11 | 4.2 | 7.42 | | |
| Sprinkler | 3008 | 11.45 | 11.11 | 4.2 | 7.43 | | |
| Sprinkler | 3009 | 12.23 | 11.11 | 4.2 | 8.47 | | |
| Sprinkler | 3010 | 13.44 | 11.11 | 4.2 | 10.24 | | |
| Sprinkler | 3011 | 11.28 | 11.11 | 4.2 | 7.22 | | |
| Sprinkler | 3012 | 11.17 | 11.11 | 4.2 | 7.08 | | |
| Sprinkler | 3013 | 11.63 | 11.11 | 4.2 | 7.67 | | |
| Sprinkler | 3014 | 12.01 | 11.11 | 4.2 | 8.18 | | |
| Sprinkler | 3015 | 12.94 | 11.11 | 4.2 | 9.50 | | |
| Sprinkler | 3016 | 13.16 | 11.11 | 4.2 | 9.82 | | |
| Sprinkler | 3017 | 12.12 | 11.11 | 4.2 | 8.33 | | |
| Sprinkler | 3018 | 11.82 | 11.11 | 4.2 | 7.93 | | |
| Sprinkler | 3019 | 12.32 | 11.11 | 4.2 | 8.60 | | |
| Sprinkler | 3020 | 12.05 | 11.11 | 4.2 | 8.24 | | |
| Sprinkler | 3021 | 13.30 | 11.11 | 4.2 | 10.02 | | |
| Sprinkler | 3022 | 13.29 | 11.11 | 4.2 | 10.01 | | |
| Sprinkler | 3023 | 14.13 | 11.11 | 4.2 | 11.32 | | |
| Sprinkler | 3024 | 11.40 | 11.11 | 4.2 | 7.37 | | |
| Sprinkler | 3025 | 11.46 | 11.11 | 4.2 | 7.44 | | |
| Sprinkler | 3026 | 11.65 | 11.11 | 4.2 | 7.69 | | |
| Sprinkler | 3027 | 12.06 | 11.11 | 4.2 | 8.25 | | |
| Sprinkler | 3028 | 12.89 | 11.11 | 4.2 | 9.43 | | |
| Sprinkler | 3029 | 13.11 | 11.11 | 4.2 | 9.74 | | |
| Sprinkler | 3030 | 11.96 | 11.11 | 4.2 | 8.11 | | |
| Sprinkler | 3031 | 11.78 | 11.11 | 4.2 | 7.87 | | |
| Sprinkler | 3032 | 12.14 | 11.11 | 4.2 | 8.36 | | |
| Sprinkler | 3033 | 12.12 | 11.11 | 4.2 | 8.33 | | |
| Sprinkler | 3034 | 12.58 | 11.11 | 4.2 | 8.97 | | |
| Sprinkler | 3035 | 14.14 | 11.11 | 4.2 | 11.34 | | |
| Sprinkler | 3036 | 13.42 | 11.11 | 4.2 | 10.21 | | |
| Sprinkler | 3037 | 13.55 | 11.11 | 4.2 | 10.40 | | |
| Sprinkler | 3038 | 13.66 | 11.11 | 4.2 | 10.57 | | |
| Sprinkler | 3039 | 11.71 | 11.11 | 4.2 | 7.77 | | |
| Sprinkler | 3040 | 11.73 | 11.11 | 4.2 | 7.80 | | |
| Sprinkler | 3041 | 12.22 | 11.11 | 4.2 | 8.47 | | |
| Sprinkler | 3042 | 12.08 | 11.11 | 4.2 | 8.27 | | |
| Sprinkler | 3043 | 12.40 | 11.11 | 4.2 | 8.72 | | |
| Sprinkler | 3044 | 14.21 | 11.11 | 4.2 | 11.44 | | |

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Cienan/Dry Floor Area

| Node | Elevation(Foot) | Fittings | Pressure(psi) | Discharge(gpm) |
|------|-----------------|-----------------------|---------------|----------------|
| 1 | -4-0 | S | 43.65 | 544.67 |
| 3001 | 22-5½ | Spr(-8.66) | 8.66 | 12.36 |
| 3002 | 22-4 | Spr(-8.75) | 8.75 | 12.42 |
| 3003 | 22-3½ | Spr(-9.02) | 9.02 | 12.62 |
| 3004 | 21-4½ | Spr(-9.30) | 9.30 | 12.81 |
| 3005 | 22-5 | Spr(-7.25) | 7.25 | 11.31 |
| 3006 | 20-3 | Spr(-7.00), fd(23-0) | 7.00 | 11.11 |
| 3007 | 22-3½ | Spr(-7.42) | 7.42 | 11.44 |
| 3008 | 19-9 | Spr(-7.43), fd(23-0) | 7.43 | 11.45 |
| 3009 | 20-8½ | Spr(-8.47) | 8.47 | 12.23 |
| 3010 | 19-5 | Spr(-10.24) | 10.24 | 13.44 |
| 3011 | 22-5 | Spr(-7.22) | 7.22 | 11.28 |
| 3012 | 20-3 | Spr(-7.08), fd(23-0) | 7.08 | 11.17 |
| 3013 | 22-3 | Spr(-7.67) | 7.67 | 11.63 |
| 3014 | 21-10 | Spr(-8.18) | 8.18 | 12.01 |
| 3015 | 20-8 | Spr(-9.50) | 9.50 | 12.94 |
| 3016 | 19-10 | Spr(-9.82) | 9.82 | 13.16 |
| 3017 | 22-5 | Spr(-8.33) | 8.33 | 12.12 |
| 3018 | 20-3 | Spr(-7.93), fd(23-0) | 7.93 | 11.82 |
| 3019 | 22-3½ | Spr(-8.60) | 8.60 | 12.32 |
| 3020 | 19-2½ | Spr(-8.24), fd(34-0) | 8.24 | 12.05 |
| 3021 | 19-3 | Spr(-10.02), fd(23-0) | 10.02 | 13.30 |
| 3022 | 19-3 | Spr(-10.01), fd(23-0) | 10.01 | 13.29 |
| 3023 | 19-10 | Spr(-11.32) | 11.32 | 14.13 |
| 3024 | 22-5 | Spr(-7.37) | 7.37 | 11.40 |
| 3025 | 22-4 | Spr(-7.44) | 7.44 | 11.46 |
| 3026 | 22-3 | Spr(-7.69) | 7.69 | 11.65 |
| 3027 | 21-8 | Spr(-8.25) | 8.25 | 12.06 |
| 3028 | 20-8 | Spr(-9.43) | 9.43 | 12.89 |
| 3029 | 19-10 | Spr(-9.74) | 9.74 | 13.11 |
| 3030 | 22-2½ | Spr(-8.11) | 8.11 | 11.96 |
| 3031 | 22-2½ | Spr(-7.87) | 7.87 | 11.78 |
| 3032 | 22-2½ | Spr(-8.36) | 8.36 | 12.14 |
| 3033 | 19-9 | Spr(-8.33), fd(23-0) | 8.33 | 12.12 |
| 3034 | 18-9 | Spr(-8.97), fd(23-0) | 8.97 | 12.58 |
| 3035 | 19-6½ | Spr(-11.34) | 11.34 | 14.14 |
| 3036 | 22-1 | Spr(-10.21) | 10.21 | 13.42 |
| 3037 | 20-11 | Spr(-10.40) | 10.40 | 13.55 |
| 3038 | 20-1½ | Spr(-10.57) | 10.57 | 13.66 |
| 3039 | 20-3 | Spr(-7.77), fd(23-0) | 7.77 | 11.71 |
| 3040 | 20-3 | Spr(-7.80), fd(23-0) | 7.80 | 11.73 |
| 3041 | 22-2½ | Spr(-8.47) | 8.47 | 12.22 |
| 3042 | 19-9 | Spr(-8.27), fd(23-0) | 8.27 | 12.08 |
| 3043 | 19-9 | Spr(-8.72), fd(23-0) | 8.72 | 12.40 |
| 3044 | 20-5 | Spr(-11.44) | 11.44 | 14.21 |
| 7 | 0-0 | | 34.62 | |
| 8 | -4-0 | T(47-3½) | 43.56 | |
| 9 | 2-0 | PO(20-0) | 33.63 | |
| 211 | 23-5½ | fE(5-0) | 15.30 | |
| 226 | 24-4 | fE(5-0) | 14.90 | |
| 244 | 18-4½ | PO(26-4) | 17.50 | |
| 245 | 12-0 | E(13-2) | 20.61 | |
| 246 | 11-10 | E(13-2) | 20.67 | |
| 247 | 18-4½ | PO(26-4) | 17.49 | |
| 248 | 20-3½ | fE(6-9½) | 15.26 | |
| 249 | 20-4 | fE(6-9½) | 15.11 | |
| 250 | 10-6 | fT(16-0) | 21.80 | |
| 251 | 10-6 | fT(16-0) | 21.79 | |
| 269 | 22-5 | E(2-0) | 7.34 | |
| 275 | 22-2½ | PO(5-0) | 8.27 | |
| 284 | 22-2½ | PO(5-0) | 8.15 | |
| 292 | 22-4 | PO(5-0) | 7.32 | |



Node Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clenan/Dry Floor Area

| Node | Elevation(Foot) | Fittings | Pressure(psi) | Discharge(gpm) |
|------|-----------------|----------|---------------|----------------|
| 293 | 22-4 | PO(5-0) | 7.41 | |
| 294 | 22-4 | PO(5-0) | 8.40 | |
| 329 | 22-11½ | PO(5-0) | 7.71 | |
| 332 | 22-0½ | PO(5-0) | 9.01 | |
| 334 | 22-1 | E(2-0) | 10.37 | |
| 344 | 21-11 | PO(5-0) | 9.53 | |
| 346 | 21-8½ | PO(5-0) | 8.91 | |
| 357 | 21-3½ | PO(5-0) | 8.51 | |
| 358 | 21-5½ | PO(5-0) | 9.47 | |
| 359 | 21-2½ | PO(5-0) | 9.44 | |
| 362 | 21-5 | PO(5-0) | 10.70 | |
| 367 | 20-4 | PO(9-11) | 11.72 | |
| 368 | 20-4 | PO(9-11) | 11.46 | |
| 369 | 20-4 | PO(9-11) | 11.30 | |
| 370 | 20-4 | PO(5-0) | 11.26 | |
| 371 | 20-4 | PO(9-11) | 11.25 | |
| 372 | 20-4 | PO(9-11) | 11.24 | |
| 373 | 20-4 | PO(5-0) | 11.24 | |
| 374 | 20-4 | PO(9-11) | 11.24 | |
| 375 | 20-4 | PO(9-11) | 11.30 | |
| 376 | 20-4 | PO(9-11) | 11.32 | |
| 381 | 20-4 | PO(5-0) | 11.47 | |
| 382 | 20-4 | PO(9-11) | 11.53 | |
| 383 | 20-4 | PO(9-11) | 11.68 | |
| 384 | 20-4 | PO(9-11) | 11.93 | |
| 408 | 20-11½ | T(9-11) | 9.85 | |
| 410 | 20-11½ | T(9-11) | 9.57 | |
| 418 | 20-11½ | T(9-11) | 9.64 | |
| 429 | 20-11 | PO(5-0) | 11.60 | |
| 431 | 19-11½ | E(2-0) | 10.17 | |
| 432 | 19-11 | E(2-0) | 11.33 | |
| 610 | 22-2½ | PO(5-0) | 8.30 | |
| 659 | 22-2½ | PO(5-0) | 8.64 | |
| 754 | 12-0½ | fE(6-9½) | 24.52 | |
| 818 | 12-0½ | fT(16-0) | 23.45 | |
| 860 | 10-6 | fE(6-9½) | 22.19 | |
| 861 | 12-0 | fE(6-9½) | 21.72 | |
| 905 | 12-0 | E(10-0) | 20.84 | |
| 907 | 11-10 | E(10-0) | 20.90 | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clean/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|--------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| Route 1 | | | | | | | | |
| DY | 1.0490 | 11.11 | 4.13 | 120 | | 0.043874 | 0-0 | Pf 1.23 |
| 3006 | 20-3 | 11.11 | 4.2 | 7.00 | | Sprinkler, | 28-0 | Pe -0.90 |
| 292 | 22-4 | | | 7.32 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 22.42 | 3.24 | 120 | | 0.016124 | 4-4½ | Pf 0.07 |
| 292 | 22-4 | 11.31 | | 7.32 | | Flow (q) from Route 4 | 4-4½ | Pe 0.02 |
| 3007 | 22-3½ | | | 7.42 | | | 4-4½ | Pv |
| BL | 1.6820 | 33.86 | 4.89 | 120 | | 0.034570 | 6-2½ | Pf 0.21 |
| 3007 | 22-3½ | 11.44 | 4.2 | 7.42 | | Sprinkler | 6-2½ | Pe 0.07 |
| 329 | 22-1½ | | | 7.71 | | | 6-2½ | Pv |
| BL | 1.6820 | 45.31 | 6.54 | 120 | | 0.059261 | 7-7 | Pf 0.45 |
| 329 | 22-1½ | 11.45 | | 7.71 | | Flow (q) from Route 6 | 7-7 | Pe 0.35 |
| 357 | 21-3½ | | | 8.51 | | | 7-7 | Pv |
| BL | 1.6820 | 57.53 | 8.31 | 120 | | 0.092198 | 3-1 | Pf 1.20 |
| 357 | 21-3½ | 12.23 | | 8.51 | | Flow (q) from Route 16 | 9-11 | Pe 0.14 |
| 408 | 20-11½ | | | 9.85 | | T(9-11) | 13-0 | Pv |
| DY | 1.6820 | 70.97 | 10.25 | 120 | | 0.135953 | 0-0 | Pf 1.35 |
| 408 | 20-11½ | 13.44 | | 9.85 | | Flow (q) from Route 28 | 9-11 | Pe 0.27 |
| 368 | 20-4 | | | 11.46 | | PO(9-11) | 9-11 | Pv |
| CM | 3.2600 | 216.16 | 8.31 | 120 | | 0.042522 | 6-0½ | Pf 0.26 |
| 368 | 20-4 | 145.19 | | 11.46 | | Flow (q) from Route 2 | 6-0½ | Pe |
| 367 | 20-4 | | | 11.72 | | | 6-0½ | Pv |
| CM | 3.2600 | 266.36 | 10.24 | 120 | | 0.062577 | 49-5½ | Pf 3.52 |
| 367 | 20-4 | 50.20 | | 11.72 | | Flow (q) from Route 17 | 6-9½ | Pe 0.02 |
| 248 | 20-3½ | | | 15.26 | | fE(6-9½) | 56-3 | Pv |
| CM | 4.2600 | 266.36 | 6.00 | 120 | | 0.017004 | 35-10½ | Pf 1.40 |
| 248 | 20-3½ | | | 15.26 | | | 46-8½ | Pe 0.84 |
| 244 | 18-4½ | | | 17.50 | | 3fE(6-9½), PO(26-4) | 82-7 | Pv |
| CM | 4.2600 | 272.38 | 6.13 | 120 | | 0.017722 | 6-4½ | Pf 0.35 |
| 244 | 18-4½ | 6.02 | | 17.50 | | Flow (q) from Route 34 | 13-2 | Pe 2.76 |
| 245 | 12-0 | | | 20.61 | | E(13-2) | 19-6½ | Pv |
| CM | 4.0260 | 272.38 | 6.86 | 120 | | 0.023334 | 0-0 | Pf 0.23 |
| 245 | 12-0 | | | 20.61 | | | 10-0 | Pe 0.00 |
| 905 | 12-0 | | | 20.84 | | E(10-0) | 10-0 | Pv |
| CM | 4.2600 | 272.38 | 6.13 | 120 | | 0.017722 | 1-6 | Pf 0.31 |
| 905 | 12-0 | | | 20.84 | | | 16-0 | Pe 0.65 |
| 250 | 10-6 | | | 21.80 | | fT(16-0) | 17-6 | Pv |
| CM | 4.2600 | 279.14 | 6.28 | 120 | | 0.018543 | 81-7½ | Pf 2.31 |
| 250 | 10-6 | 6.75 | | 21.80 | | Flow (q) from Route 35 | 43-2 | Pe -0.66 |
| 818 | 12-0½ | | | 23.45 | | 4fE(6-9½), fT(16-0) | 124-9½ | Pv |
| CM | 4.2600 | 544.67 | 12.26 | 120 | | 0.063866 | 9-10½ | Pf 1.06 |
| 818 | 12-0½ | 265.53 | | 23.45 | | Flow (q) from Route 5 | 6-9½ | Pe |
| 754 | 12-0½ | | | 24.52 | | fE(6-9½) | 16-8 | Pv |
| CM | 4.0260 | 544.67 | 13.73 | 120 | | 0.084093 | 11-0 | Pf 4.76 |
| 754 | 12-0½ | | | 24.52 | | | 45-7 | Pe 4.35 |
| 9 | 2-0 | | | 33.63 | | 2fE(6-9½), BV(12-0), PO(20-0) | 56-7 | Pv |
| UG | 6.3570 | 544.67 | 5.51 | 120 | | 0.009092 | 2-10 | Pf 0.13 |
| 9 | 2-0 | | | 33.63 | | | 11-4 | Pe 0.87 |
| 7 | 0-0 | | | 34.62 | | LtE(11-4) | 14-2 | Pv |
| UG | 6.2800 | 544.67 | 5.64 | 140 | | 0.007254 | 168-7 | Pf 7.21 |
| 7 | 0-0 | | | 34.62 | | | 135-6½ | Pe 1.73 |
| 8 | -4-0 | | | 43.56 | | 4E(22-1), BFP(-5.00), T(47-3½) | 304-1 | Pv |
| UG | 8.3900 | 544.67 | 3.16 | 140 | | 0.001770 | 50-8½ | Pf 0.09 |
| 8 | -4-0 | | | 43.56 | | | 50-8½ | Pe |
| 1 | -4-0 | | | 43.65 | | Water Supply | 50-8½ | Pv |
| | | 250.00 | | | | Hose Allowance At Source | | |
| 1 | | 794.67 | | | | | | |
| Route 2 | | | | | | | | |
| DY | 1.0490 | 11.17 | 4.15 | 120 | | 0.044333 | 0-0 | Pf 1.24 |
| 3012 | 20-3 | 11.17 | 4.2 | 7.08 | | Sprinkler, | 28-0 | Pe -0.91 |
| 293 | 22-4 | | | 7.41 | | PO(5-0), fd(23-0) | 28-0 | Pv |
| BL | 1.6820 | 22.46 | 3.24 | 120 | | 0.016176 | 8-11½ | Pf 0.23 |
| 293 | 22-4 | 11.28 | | 7.41 | | Flow (q) from Route 3 | 4-11½ | Pe 0.04 |
| 3013 | 22-3 | | | 7.67 | | 2LtE(2-5½) | 13-11 | Pv |
| BL | 1.6820 | 34.09 | 4.92 | 120 | | 0.035013 | 8-10 | Pf 0.31 |
| 3013 | 22-3 | 11.63 | 4.2 | 7.67 | | Sprinkler | 8-10 | Pe 0.19 |
| 3014 | 21-10 | | | 8.18 | | | 8-10 | Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clenan/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| BL | 1.6820 | 46.10 | 6.66 | 120 | | 0.061196 | 8-0 | Pf 1.10 |
| 3014 | 21-10 | 12.01 | 4.2 | 8.18 | | Sprinkler, | 9-11 | Pe 0.37 |
| 418 | 20-11½ | | | 9.64 | | T(9-11) | 17-11 | Pv |
| DY | 1.6820 | 72.20 | 10.43 | 120 | | 0.140355 | 0-0 | Pf 1.39 |
| 418 | 20-11½ | 26.10 | | 9.64 | | Flow (q) from Route 22 | 9-11 | Pe 0.27 |
| 369 | 20-4 | | | 11.30 | | PO(9-11) | 9-11 | Pv |
| CM | 3.2600 | 145.19 | 5.58 | 120 | | 0.020364 | 8-0½ | Pf 0.16 |
| 369 | 20-4 | 72.98 | | 11.30 | | Flow (q) from Route 25 | | Pe |
| 368 | 20-4 | | | 11.46 | | | 8-0½ | Pv |
| Route 3 | | | | | | | | |
| BL | 1.0490 | 11.28 | 4.19 | 120 | | 0.045119 | 0-10½ | Pf 0.13 |
| 3011 | 22-5 | 11.28 | 4.2 | 7.22 | | Sprinkler, | 2-0 | Pe |
| 269 | 22-5 | | | 7.34 | | E(2-0) | 2-10½ | Pv |
| BL | 1.6820 | 11.28 | 1.63 | 120 | | 0.004526 | 7-0½ | Pf 0.03 |
| 269 | 22-5 | | | 7.34 | | | | Pe 0.03 |
| 293 | 22-4 | | | 7.41 | | | 7-0½ | Pv |
| Route 4 | | | | | | | | |
| BL | 1.6820 | 11.31 | 1.63 | 120 | | 0.004545 | 8-5½ | Pf 0.04 |
| 3005 | 22-5 | 11.31 | 4.2 | 7.25 | | Sprinkler | | Pe 0.04 |
| 292 | 22-4 | | | 7.32 | | | 8-5½ | Pv |
| Route 5 | | | | | | | | |
| BL | 1.6820 | 11.40 | 1.65 | 120 | | 0.004618 | 7-6 | Pf 0.03 |
| 3024 | 22-5 | 11.40 | 4.2 | 7.37 | | Sprinkler | | Pe 0.04 |
| 3025 | 22-4 | | | 7.44 | | | 7-6 | Pv |
| BL | 1.6820 | 22.86 | 3.30 | 120 | | 0.016721 | 8-0 | Pf 0.22 |
| 3025 | 22-4 | 11.46 | 4.2 | 7.44 | | Sprinkler, | 4-11½ | Pe 0.03 |
| 3026 | 22-3 | | | 7.69 | | 2LtE(2-5½) | 12-11½ | Pv |
| BL | 1.6820 | 34.51 | 4.98 | 120 | | 0.035820 | 8-4½ | Pf 0.30 |
| 3026 | 22-3 | 11.65 | 4.2 | 7.69 | | Sprinkler | | Pe 0.26 |
| 3027 | 21-8 | | | 8.25 | | | 8-4½ | Pv |
| BL | 1.6820 | 46.57 | 6.72 | 120 | | 0.062366 | 6-6 | Pf 1.02 |
| 3027 | 21-8 | 12.06 | 4.2 | 8.25 | | Sprinkler, | 9-11 | Pe 0.30 |
| 410 | 20-11½ | | | 9.57 | | T(9-11) | 16-4½ | Pv |
| DY | 1.6820 | 72.58 | 10.48 | 120 | | 0.141695 | 0-0 | Pf 1.40 |
| 410 | 20-11½ | 26.00 | | 9.57 | | Flow (q) from Route 21 | 9-11 | Pe 0.27 |
| 374 | 20-4 | | | 11.24 | | PO(9-11) | 9-11 | Pv |
| CM | 3.2600 | 88.62 | 3.41 | 120 | | 0.008170 | 7-4½ | Pf 0.06 |
| 374 | 20-4 | 16.05 | | 11.24 | | Flow (q) from Route 10 | | Pe |
| 375 | 20-4 | | | 11.30 | | | 7-4½ | Pv |
| CM | 3.2600 | 102.76 | 3.95 | 120 | | 0.010745 | 2-0 | Pf 0.02 |
| 375 | 20-4 | 14.14 | | 11.30 | | Flow (q) from Route 32 | | Pe |
| 376 | 20-4 | | | 11.32 | | | 2-0 | Pv |
| CM | 3.2600 | 163.34 | 6.28 | 120 | | 0.025323 | 6-0½ | Pf 0.15 |
| 376 | 20-4 | 60.58 | | 11.32 | | Flow (q) from Route 9 | | Pe -0.00 |
| 381 | 20-4 | | | 11.47 | | | 6-0½ | Pv |
| CM | 3.2600 | 177.00 | 6.80 | 120 | | 0.029378 | 2-0 | Pf 0.06 |
| 381 | 20-4 | 13.66 | | 11.47 | | Flow (q) from Route 30 | | Pe 0.00 |
| 382 | 20-4 | | | 11.53 | | | 2-0 | Pv |
| CM | 3.2600 | 203.97 | 7.84 | 120 | | 0.038191 | 3-11½ | Pf 0.15 |
| 382 | 20-4 | 26.97 | | 11.53 | | Flow (q) from Route 27 | | Pe |
| 383 | 20-4 | | | 11.68 | | | 3-11½ | Pv |
| CM | 3.2600 | 264.10 | 10.15 | 120 | | 0.061595 | 4-0½ | Pf 0.25 |
| 383 | 20-4 | 60.13 | | 11.68 | | Flow (q) from Route 7 | | Pe |
| 384 | 20-4 | | | 11.93 | | | 4-0½ | Pv |
| CM | 3.2600 | 278.30 | 10.70 | 120 | | 0.067864 | 39-11½ | Pf 3.17 |
| 384 | 20-4 | 14.21 | | 11.93 | | Flow (q) from Route 33 | 6-9½ | Pe |
| 249 | 20-4 | | | 15.11 | | fE(6-9½) | 46-9 | Pv |
| CM | 4.2600 | 278.30 | 6.26 | 120 | | 0.018441 | 35-11½ | Pf 1.52 |
| 249 | 20-4 | | | 15.11 | | | 46-8½ | Pe 0.85 |
| 247 | 18-4½ | | | 17.49 | | 3fE(6-9½), PO(26-4) | 82-8 | Pv |
| CM | 4.2600 | 272.29 | 6.13 | 120 | | 0.017710 | 6-6½ | Pf 0.35 |
| 247 | 18-4½ | | | 17.49 | | | 13-2 | Pe 2.84 |
| 246 | 11-10 | | | 20.67 | | E(13-2) | 19-8½ | Pv |
| CM | 4.0260 | 272.29 | 6.86 | 120 | | 0.023319 | 0-0 | Pf 0.23 |
| 246 | 11-10 | | | 20.67 | | | 10-0 | Pe -0.00 |
| 907 | 11-10 | | | 20.90 | | E(10-0) | 10-0 | Pv |



Hydraulic Analysis

Job Number: S23-90
Report Description: Ordinary Group I - Level 2 - Clean/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Pn | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|----|------------------------|--------------|----------------|
| Downstream | Elevation | Discharge | K-Factor | Pt | | Fittings | Eq. Length | Summary |
| Upstream | | | | | | | Total Length | |
| CM | 4.2600 | 272.29 | 6.13 | 120 | | 0.017710 | | 1-4 Pf 0.31 |
| 907 | 11-10 | | | 20.90 | | | | 16-0 Pe 0.58 |
| 251 | 10-6 | | | 21.79 | | fT(16-0) | | 17-4 Pv |
| CM | 4.2600 | 265.53 | 5.98 | 120 | | 0.016906 | | 16-11½ Pf 0.40 |
| 251 | 10-6 | | | 21.79 | | | | 6-9½ Pe |
| 860 | 10-6 | | | 22.19 | | fE(6-9½) | | 23-9 Pv |
| CM | 4.0260 | 265.53 | 6.69 | 120 | | 0.022260 | | 1-6 Pf 0.18 |
| 860 | 10-6 | | | 22.19 | | | | 6-9½ Pe -0.65 |
| 861 | 12-0 | | | 21.72 | | fE(6-9½) | | 8-3½ Pv |
| CM | 4.2600 | 265.53 | 5.98 | 120 | | 0.016906 | | 87-0½ Pf 1.74 |
| 861 | 12-0 | | | 21.72 | | | | 16-0 Pe -0.01 |
| 818 | 12-0½ | | | 23.45 | | fT(16-0) | | 103-0½ Pv |
| Route 6 | | | | | | | | |
| DY | 1.0490 | 11.45 | 4.25 | 120 | | 0.046373 | | 0-0 Pf 1.30 |
| 3008 | 19-9 | 11.45 | 4.2 | 7.43 | | Sprinkler, | | 28-0 Pe -1.02 |
| 329 | 22-1½ | | | 7.71 | | PO(5-0), fd(23-0) | | 28-0 Pv |
| Route 7 | | | | | | | | |
| DY | 1.0490 | 11.71 | 4.35 | 120 | | 0.048315 | | 0-0 Pf 1.35 |
| 3039 | 20-3 | 11.71 | 4.2 | 7.77 | | Sprinkler, | | 28-0 Pe -0.85 |
| 275 | 22-2½ | | | 8.27 | | PO(5-0), fd(23-0) | | 28-0 Pv |
| BL | 1.6820 | 11.71 | 1.69 | 120 | | 0.004847 | | 6-3½ Pf 0.03 |
| 275 | 22-2½ | | | 8.27 | | | | Pe 0.00 |
| 610 | 22-2½ | | | 8.30 | | | | 6-3½ Pv |
| BL | 1.6820 | 23.43 | 3.38 | 120 | | 0.017501 | | 4-2½ Pf 0.16 |
| 610 | 22-2½ | 11.73 | | 8.30 | | Flow (q) from Route 8 | | 4-11½ Pe 0.00 |
| 3041 | 22-2½ | | | 8.47 | | 2LtE(2-5½) | | 9-2 Pv |
| BL | 1.6820 | 35.65 | 5.15 | 120 | | 0.038042 | | 4-6 Pf 0.17 |
| 3041 | 22-2½ | 12.22 | 4.2 | 8.47 | | Sprinkler | | Pe 0.00 |
| 659 | 22-2½ | | | 8.64 | | | | 4-6 Pv |
| BL | 1.6820 | 47.73 | 6.89 | 120 | | 0.065260 | | 8-0 Pf 0.52 |
| 659 | 22-2½ | 12.08 | | 8.64 | | Flow (q) from Route 13 | | Pe 0.31 |
| 358 | 21-5½ | | | 9.47 | | | | 8-0 Pv |
| BL | 1.6820 | 60.13 | 8.68 | 120 | | 0.100051 | | 4-10 Pf 1.72 |
| 358 | 21-5½ | 12.40 | | 9.47 | | Flow (q) from Route 18 | | 12-4½ Pe 0.49 |
| 383 | 20-4 | | | 11.68 | | LtE(2-5½), PO(9-11) | | 17-2½ Pv |
| Route 8 | | | | | | | | |
| DY | 1.0490 | 11.73 | 4.35 | 120 | | 0.048467 | | 0-0 Pf 1.36 |
| 3040 | 20-3 | 11.73 | 4.2 | 7.80 | | Sprinkler, | | 28-0 Pe -0.85 |
| 610 | 22-2½ | | | 8.30 | | PO(5-0), fd(23-0) | | 28-0 Pv |
| Route 9 | | | | | | | | |
| BL | 1.0490 | 11.78 | 4.37 | 120 | | 0.048903 | | 0-7½ Pf 0.28 |
| 3031 | 22-2½ | 11.78 | 4.2 | 7.87 | | Sprinkler, | | 5-0 Pe |
| 284 | 22-2½ | | | 8.15 | | PO(5-0) | | 5-7½ Pv |
| BL | 1.6820 | 23.74 | 3.43 | 120 | | 0.017929 | | 6-8 Pf 0.21 |
| 284 | 22-2½ | 11.96 | | 8.15 | | Flow (q) from Route 11 | | 4-11½ Pe 0.00 |
| 3032 | 22-2½ | | | 8.36 | | 2LtE(2-5½) | | 11-7½ Pv |
| BL | 1.6820 | 35.88 | 5.18 | 120 | | 0.038493 | | 9-0½ Pf 0.35 |
| 3032 | 22-2½ | 12.14 | 4.2 | 8.36 | | Sprinkler | | Pe 0.21 |
| 346 | 21-8½ | | | 8.91 | | | | 9-0½ Pv |
| BL | 1.6820 | 48.00 | 6.93 | 120 | | 0.065944 | | 4-8½ Pf 0.31 |
| 346 | 21-8½ | 12.12 | | 8.91 | | Flow (q) from Route 14 | | Pe 0.22 |
| 359 | 21-2½ | | | 9.44 | | | | 4-8½ Pv |
| BL | 1.6820 | 60.58 | 8.75 | 120 | | 0.101430 | | 2-5½ Pf 1.50 |
| 359 | 21-2½ | 12.58 | | 9.44 | | Flow (q) from Route 19 | | 12-4½ Pe 0.38 |
| 376 | 20-4 | | | 11.32 | | LtE(2-5½), PO(9-11) | | 14-10 Pv |
| Route 10 | | | | | | | | |
| DY | 1.0490 | 11.82 | 4.39 | 120 | | 0.049211 | | 0-0 Pf 1.38 |
| 3018 | 20-3 | 11.82 | 4.2 | 7.93 | | Sprinkler, | | 28-0 Pe -0.90 |
| 294 | 22-4 | | | 8.40 | | PO(5-0), fd(23-0) | | 28-0 Pv |
| BL | 1.6820 | 23.94 | 3.46 | 120 | | 0.018214 | | 5-1½ Pf 0.18 |
| 294 | 22-4 | 12.12 | | 8.40 | | Flow (q) from Route 15 | | 4-11½ Pe 0.02 |
| 3019 | 22-3½ | | | 8.60 | | 2LtE(2-5½) | | 10-1 Pv |
| BL | 1.6820 | 36.26 | 5.24 | 120 | | 0.039251 | | 7-7 Pf 0.30 |
| 3019 | 22-3½ | 12.32 | 4.2 | 8.60 | | Sprinkler | | Pe 0.11 |
| 332 | 22-0½ | | | 9.01 | | | | 7-7 Pv |
| BL | 1.6820 | 48.32 | 6.98 | 120 | | 0.066749 | | 10-0½ Pf 1.50 |
| 332 | 22-0½ | 12.05 | | 9.01 | | Flow (q) from Route 12 | | 12-4½ Pe 0.73 |
| 372 | 20-4 | | | 11.24 | | LtE(2-5½), PO(9-11) | | 22-5 Pv |



Hydraulic Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clenan/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|---------------------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| CM | 3.2600 | 16.05 | 0.62 | 120 | 0.000346 | | |
| 372 | 20-4 | | | 11.24 | | 4-1 | Pf 0.00 |
| 374 | 20-4 | | | 11.24 | | 4-1 | Pe Pv |
| Route 11 | | | | | | | |
| BL | 1.6820 | 11.96 | 1.73 | 120 | 0.005041 | 8-0 | Pf 0.04 |
| 3030 | 22-2½ | 11.96 | 4.2 | 8.11 | Sprinkler | | Pe 0.00 |
| 284 | 22-2½ | | | 8.15 | | 8-0 | Pv |
| Route 12 | | | | | | | |
| DY | 1.0490 | 12.05 | 4.47 | 120 | 0.051003 | 0-0 | Pf 1.99 |
| 3020 | 19-2½ | 12.05 | 4.2 | 8.24 | Sprinkler, | 39-0 | Pe -1.21 |
| 332 | 22-0½ | | | 9.01 | PO(5-0), fd(34-0) | 39-0 | Pv |
| Route 13 | | | | | | | |
| DY | 1.0490 | 12.08 | 4.48 | 120 | 0.051179 | 0-0 | Pf 1.43 |
| 3042 | 19-9 | 12.08 | 4.2 | 8.27 | Sprinkler, | 28-0 | Pe -1.06 |
| 659 | 22-2½ | | | 8.64 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 14 | | | | | | | |
| DY | 1.0490 | 12.12 | 4.50 | 120 | 0.051506 | 0-0 | Pf 1.44 |
| 3033 | 19-9 | 12.12 | 4.2 | 8.33 | Sprinkler, | 28-0 | Pe -0.86 |
| 346 | 21-8½ | | | 8.91 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 15 | | | | | | | |
| BL | 1.6820 | 12.12 | 1.75 | 120 | 0.005169 | 6-10 | Pf 0.04 |
| 3017 | 22-5 | 12.12 | 4.2 | 8.33 | Sprinkler | | Pe 0.04 |
| 294 | 22-4 | | | 8.40 | | 6-10 | Pv |
| Route 16 | | | | | | | |
| BL | 1.0490 | 12.23 | 4.54 | 120 | 0.052359 | 0-7½ | Pf 0.29 |
| 3009 | 20-8½ | 12.23 | 4.2 | 8.47 | Sprinkler, | 5-0 | Pe -0.26 |
| 357 | 21-3½ | | | 8.51 | PO(5-0) | 5-7½ | Pv |
| Route 17 | | | | | | | |
| BL | 1.6820 | 12.36 | 1.78 | 120 | 0.005359 | 8-9½ | Pf 0.05 |
| 3001 | 22-5½ | 12.36 | 4.2 | 8.66 | Sprinkler | | Pe 0.04 |
| 3002 | 22-4 | | | 8.75 | | 8-9½ | Pv |
| BL | 1.6820 | 24.78 | 3.58 | 120 | 0.019412 | 8-3½ | Pf 0.26 |
| 3002 | 22-4 | 12.42 | 4.2 | 8.75 | Sprinkler, | 4-11½ | Pe 0.02 |
| 3003 | 22-3½ | | | 9.02 | 2LtE(2-5½) | 13-2½ | Pv |
| BL | 1.6820 | 37.40 | 5.40 | 120 | 0.041558 | 8-2 | Pf 0.34 |
| 3003 | 22-3½ | 12.62 | 4.2 | 9.02 | Sprinkler | | Pe 0.17 |
| 344 | 21-11 | | | 9.53 | | 8-2 | Pv |
| BL | 1.6820 | 50.20 | 7.25 | 120 | 0.071657 | 8-8½ | Pf 1.51 |
| 344 | 21-11 | 12.81 | | 9.53 | Flow (q) from Route 20 | 12-4½ | Pe 0.68 |
| 367 | 20-4 | | | 11.72 | LtE(2-5½), PO(9-11) | 21-1 | Pv |
| Route 18 | | | | | | | |
| DY | 1.0490 | 12.40 | 4.60 | 120 | 0.053752 | 0-0 | Pf 1.51 |
| 3043 | 19-9 | 12.40 | 4.2 | 8.72 | Sprinkler, | 28-0 | Pe -0.75 |
| 358 | 21-5½ | | | 9.47 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 19 | | | | | | | |
| DY | 1.0490 | 12.58 | 4.67 | 120 | 0.055182 | 0-0 | Pf 1.55 |
| 3034 | 18-9 | 12.58 | 4.2 | 8.97 | Sprinkler, | 28-0 | Pe -1.08 |
| 359 | 21-2½ | | | 9.44 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 20 | | | | | | | |
| BL | 1.0490 | 12.81 | 4.75 | 120 | 0.057044 | 1-1 | Pf 0.46 |
| 3004 | 21-4½ | 12.81 | 4.2 | 9.30 | Sprinkler, | 7-0 | Pe -0.23 |
| 344 | 21-11 | | | 9.53 | E(2-0), PO(5-0) | 8-1 | Pv |
| Route 21 | | | | | | | |
| BL | 1.6820 | 26.00 | 3.75 | 120 | 0.021215 | 2-10½ | Pf 0.27 |
| 3028 | 20-8 | 13.11 | 4.2 | 9.43 | Sprinkler,, Flow (q) from Route | 9-11 | Pe -0.13 |
| 410 | 20-11½ | | | 9.57 | 23 | 12-9 | Pv |
| | | | | | T(9-11) | | |
| Route 22 | | | | | | | |
| BL | 1.6820 | 26.10 | 3.77 | 120 | 0.021371 | 2-10½ | Pf 0.27 |
| 3015 | 20-8 | 13.16 | 4.2 | 9.50 | Sprinkler,, Flow (q) from Route | 9-11 | Pe -0.13 |
| 418 | 20-11½ | | | 9.64 | 24 | 12-9 | Pv |
| | | | | | T(9-11) | | |
| Route 23 | | | | | | | |
| BL | 1.6820 | 13.11 | 1.89 | 120 | 0.005974 | 8-0½ | Pf 0.05 |
| 3029 | 19-10 | 13.11 | 4.2 | 9.74 | Sprinkler | | Pe -0.36 |
| 3028 | 20-8 | | | 9.43 | | 8-0½ | Pv |
| Route 24 | | | | | | | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Clean/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|------------------------|--------------|---------------------------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| BL | 1.6820 | 13.16 | 1.90 | 120 | 0.006019 | | |
| 3016 | 19-10 | 13.16 | 4.2 | 9.82 | Sprinkler | 8-0½ | Pf 0.05 Pe -0.37 Pv |
| 3015 | 20-8 | | | 9.50 | | 8-0½ | |
| Route 25 | | | | | | | |
| DY | 1.0490 | 13.29 | 4.93 | 120 | 0.061060 | 0-0 | Pf 1.71 |
| 3022 | 19-3 | 13.29 | 4.2 | 10.01 | Sprinkler, | 28-0 | Pe -0.48 |
| 373 | 20-4 | | | 11.24 | PO(5-0), fd(23-0) | 28-0 | Pv |
| CM | 3.2600 | 45.56 | 1.75 | 120 | 0.002386 | 2-9 | Pf 0.01 |
| 373 | 20-4 | 32.27 | | 11.24 | Flow (q) from Route 37 | | Pe |
| 371 | 20-4 | | | 11.25 | | 2-9 | Pv |
| CM | 3.2600 | 59.69 | 2.29 | 120 | 0.003932 | 3-3 | Pf 0.01 |
| 371 | 20-4 | 14.13 | | 11.25 | Flow (q) from Route 31 | | Pe |
| 370 | 20-4 | | | 11.26 | | 3-3 | Pv |
| CM | 3.2600 | 72.98 | 2.81 | 120 | 0.005705 | 6-9½ | Pf 0.04 |
| 370 | 20-4 | 13.30 | | 11.26 | Flow (q) from Route 26 | | Pe |
| 369 | 20-4 | | | 11.30 | | 6-9½ | Pv |
| Route 26 | | | | | | | |
| DY | 1.0490 | 13.30 | 4.94 | 120 | 0.061154 | 0-0 | Pf 1.71 |
| 3021 | 19-3 | 13.30 | 4.2 | 10.02 | Sprinkler, | 28-0 | Pe -0.48 |
| 370 | 20-4 | | | 11.26 | PO(5-0), fd(23-0) | 28-0 | Pv |
| Route 27 | | | | | | | |
| BL | 1.0490 | 13.42 | 4.98 | 120 | 0.062223 | 0-7 | Pf 0.16 |
| 3036 | 22-1 | 13.42 | 4.2 | 10.21 | Sprinkler, | 2-0 | Pe |
| 334 | 22-1 | | | 10.37 | E(2-0) | 2-7 | Pv |
| BL | 1.6820 | 13.42 | 1.94 | 120 | 0.006242 | 6-4½ | Pf 0.04 |
| 334 | 22-1 | | | 10.37 | | | Pe 0.29 |
| 362 | 21-5 | | | 10.70 | | 6-4½ | Pv |
| BL | 1.6820 | 26.97 | 3.89 | 120 | 0.022697 | 4-0½ | Pf 0.37 |
| 362 | 21-5 | 13.55 | | 10.70 | Flow (q) from Route 29 | 12-4½ | Pe 0.46 |
| 382 | 20-4 | | | 11.53 | LtE(2-5½), PO(9-11) | 16-5 | Pv |
| Route 28 | | | | | | | |
| DR | 1.0490 | 13.44 | 4.99 | 120 | 0.062369 | 0-6½ | Pf 0.16 |
| 3010 | 19-5 | 13.44 | 4.2 | 10.24 | Sprinkler, | 2-0 | Pe -0.23 |
| 431 | 19-11½ | | | 10.17 | E(2-0) | 2-6½ | Pv |
| BL | 1.6820 | 13.44 | 1.94 | 120 | 0.006257 | 9-8½ | Pf 0.12 |
| 431 | 19-11½ | | | 10.17 | | 9-11 | Pe -0.44 |
| 408 | 20-11½ | | | 9.85 | T(9-11) | 19-7 | Pv |
| Route 29 | | | | | | | |
| BL | 1.0490 | 13.55 | 5.03 | 120 | 0.063292 | 1-0 | Pf 0.51 |
| 3037 | 20-11 | 13.55 | 4.2 | 10.40 | Sprinkler, | 7-0 | Pe -0.21 |
| 362 | 21-5 | | | 10.70 | E(2-0), PO(5-0) | 8-0 | Pv |
| Route 30 | | | | | | | |
| BL | 1.0490 | 13.66 | 5.07 | 120 | 0.064234 | 8-6½ | Pf 1.00 |
| 3038 | 20-1½ | 13.66 | 4.2 | 10.57 | Sprinkler, | 7-0 | Pe -0.09 |
| 381 | 20-4 | | | 11.47 | E(2-0), PO(5-0) | 15-6½ | Pv |
| Route 31 | | | | | | | |
| BL | 1.6820 | 14.13 | 2.04 | 120 | 0.006865 | 10-11 | Pf 0.16 |
| 3023 | 19-10 | 14.13 | 4.2 | 11.32 | Sprinkler, | 12-4½ | Pe -0.23 |
| 371 | 20-4 | | | 11.25 | LtE(2-5½), PO(9-11) | 23-3½ | Pv |
| Route 32 | | | | | | | |
| BL | 1.0490 | 14.14 | 5.25 | 120 | 0.068541 | 0-5 | Pf 0.16 |
| 3035 | 19-6½ | 14.14 | 4.2 | 11.34 | Sprinkler, | 2-0 | Pe -0.17 |
| 432 | 19-11 | | | 11.33 | E(2-0) | 2-5 | Pv |
| BL | 1.6820 | 14.14 | 2.04 | 120 | 0.006876 | 9-10 | Pf 0.15 |
| 432 | 19-11 | | | 11.33 | | 12-4½ | Pe -0.18 |
| 375 | 20-4 | | | 11.30 | LtE(2-5½), PO(9-11) | 22-2½ | Pv |
| Route 33 | | | | | | | |
| BL | 1.0490 | 14.21 | 5.27 | 120 | 0.069109 | 0-6 | Pf 0.38 |
| 3044 | 20-5 | 14.21 | 4.2 | 11.44 | Sprinkler, | 5-0 | Pe -0.22 |
| 429 | 20-11 | | | 11.60 | PO(5-0) | 5-6 | Pv |
| BL | 1.6820 | 14.21 | 2.05 | 120 | 0.006933 | 0-7½ | Pf 0.09 |
| 429 | 20-11 | | | 11.60 | | 12-4½ | Pe 0.24 |
| 384 | 20-4 | | | 11.93 | LtE(2-5½), PO(9-11) | 13-0 | Pv |
| Route 34 | | | | | | | |
| CM | 4.2600 | 6.02 | 0.14 | 120 | 0.000015 | 38-9½ | Pf 0.00 |
| 211 | 23-5½ | 6.02 | | 15.30 | Flow (q) from Route 36 | 39-11 | Pe 2.20 |
| 244 | 18-4½ | | | 17.50 | 2fE(6-9½), PO(26-4) | 78-8½ | Pv |
| Route 35 | | | | | | | |



Hydraulic Analysis

Job Number: S23-90

Report Description: Ordinary Group I - Level 2 - Cienan/Dry Floor Area

| Pipe Type | Diameter | Flow | Velocity | HWC | Friction Loss | Length | Pressure |
|------------|-----------|-----------|----------|-------|--------------------|--------------|----------|
| Downstream | Elevation | Discharge | K-Factor | Pt | Pn | Eq. Length | Summary |
| Upstream | | | | | | Total Length | |
| CM | 3.2600 | 6.75 | 0.26 | 120 | | 0.000070 | |
| 251 | 10-6 | | | 21.79 | | | Pf 0.01 |
| 250 | 10-6 | | | 21.80 | | | Pe 0.39 |
| | | | | | 4fE(5-0) | | Pv |
| Route 36 | | | | | | | |
| CM | 3.2600 | 6.02 | 0.23 | 120 | | 0.000056 | |
| 226 | 24-4 | | | 14.90 | | | Pf 0.01 |
| 211 | 23-5½ | | | 15.30 | | | Pe 0.39 |
| | | | | | 8fE(5-0) | | Pv |
| Route 37 | | | | | | | |
| CM | 3.2600 | 32.27 | 1.24 | 120 | | 0.001261 | |
| 372 | 20-4 | | | 11.24 | | | Pf 0.00 |
| 373 | 20-4 | | | 11.24 | | | Pe |
| | | | | | | 1-10½ | Pv |
| Route 38 | | | | | | | |
| CM | 4.2600 | 6.02 | 0.14 | 120 | | 0.000015 | |
| 247 | 18-4½ | | | 17.49 | | | Pf 0.00 |
| 226 | 24-4 | | | 14.90 | | | Pe -2.59 |
| | | | | | PO(26-4) | | Pv |
| | | | | | 4fE(6-9½), fE(5-0) | | |

| Equivalent Pipe Lengths of Valves and Fittings (C=120 only) | | C Value Multiplier | | | | |
|-----------------------------------------------------------------------------------------------------------------------------|--|--------------------|-------|------|------|------|
| $\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$ | | Value Of C | 100 | 130 | 140 | 150 |
| | | Multiplying Factor | 0.713 | 1.16 | 1.33 | 1.51 |

| Pipe Type Legend | Units Legend | Fittings Legend |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AO Arm-Over BL Branch Line CM Cross Main DN Drain DR Drop DY Dynamic FM Feed Main FR Feed Riser MS Miscellaneous OR Outrigger RN Riser Nipple SP Sprig ST Stand Pipe UG Underground | Diameter Inch Elevation Foot Flow gpm Discharge gpm Velocity fps Pressure psi Length Foot Friction Loss psi/Foot HWC Hazen-Williams Constant Pt Total pressure at a point in a pipe Pn Normal pressure at a point in a pipe Pf Pressure loss due to friction between points Pe Pressure due to elevation difference between indicated points Pv Velocity pressure at a point in a pipe | ALV Alarm Valve AngV Angle Valve b Bushing BalV Ball Valve BFP Backflow Preventer BV Butterfly Valve C Cross Flow Turn 90° cplg Coupling Cr Cross Run CV Check Valve DelV Deluge Valve DPV Dry Pipe Valve E 90° Elbow EE 45° Elbow Ee1 11¼° Elbow Ee2 22½° Elbow f Flow Device fd Flex Drop FDC Fire Department Connection fE 90° FireLock(TM) Elbow fEE 45° FireLock(TM) Elbow flg Flange FN Floating Node fT FireLock(TM) Tee g Gauge GloV Globe Valve GV Gate Valve Ho Hose Hose Hose HV Hose Valve Hyd Hydrant LtE Long Turn Elbow mecT Mechanical Tee Noz Nozzle P1 Pump In P2 Pump Out PIV Post Indicating Valve PO Pipe Outlet PRV Pressure Reducing Valve PrV Pressure Relief Valve red Reducer/Adapter S Supply sCV Swing Check Valve Spr Sprinkler St Strainer T Tee Flow Turn 90° Tr Tee Run U Union WirF Wirsbo WMV Water Meter Valve Z Cap |