

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Apr 03, 2024	Inspection Result:	FAILED
Permit Number: Property Address:	PRCTI20231087 4621 S MERIDIAN, Unit: A915, PUYALLUP, WA 98373;		
	ORANGE CONSTRUCTIC		
	CHANGE OF USE OR OC	CUPANCY - PETCARE CL	INIC

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

2 1; provide 1 hour rated door frame and door hardware at 1 hour room, and seal penetrations at walls and ceiling.

2 ; complete thresholds at exterior exit doors not to exceed 1/2 max in height as discussed with contractor.

- 3 ; sinks in restroom not to exceed 34" above finish floor to flood rim level of sink .
- 4 ; complete all faucets, and eye wash stations as per city approved plans.
- 5; kitchen break room sink not to exceed 34" above finish floor as discussed with contractor.
- 6 ; provide U.P.C hair traps on all animal wash stations.
- 7 ; complete labeling of non potable water as discussed with contractor.
- 8 ; provide min. 1" air gap at t.p.r. valve drain of hot water heater.
- 9 ; complete insulation of hot water lines next to hot water heater.
- 10; remove slide bolt lock from rear exit door.
- 11; complete plumbing boots at supply lines and drain at restroom sinks.
- 12 ' provide ladder at next building final for roof top access to inspect.
- 13 ; complete floor reducers at floor transitions as discussed with contractor.

Sincerely,





Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684