

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 04, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and

student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS

(NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1 SE STAIR WELL

1.complete firestop

2.complete insulation as discussed with contractor

LEVEL THREE

- 1.complete rigid insulation at header as discussed with contractor
- 2 1. SE stairwell level o, 1, 2, exterior walls and rated walls ok to cover
 - 2. level three SE stair well complete insulation and putty packs at electrical boxes do not cover

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org