



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 04, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRFO20240187

Property Address: 1023 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Installation of concrete pad foundations for standby generators and exterior electrical equipment. - CENTERIS VOLTAGE PARK

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. transformer pad and generator pads 3, 4, and 5 approved per special inspection
2. ok to pour

Corrections:

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590