



April 4, 2024

**Corrections Response Letter - Permit #PRCTI20240313**

Dear Janelle,

Please note the following corrections to Permit **#PRCTI20240313**:

1. The engineering drawings M0.1 – M3.01 have been revised to show the date 4/3/2024, along with an updated engineer seal and signature.
2. The project is located in a medical office building, not with in the Good Samaritan Hospital. As such, the partitions around the soiled utility room are not rated assemblies, terminating 12” above the ceiling grid.
  - a. See revised detail 1/A8.0
  - b. Delete detail 2/A8.0
  - c. Revise wall legend on Sheet A2.13
3. The engineering drawings P0.1 – P3.01 have been revised to show the date 4/3/2024, along with
4. The index on Sheet T0.0 has been revised to show that the Electrical Sheets are a separate permit.

Sincerely,

Karsea Langlois